



**NORTH DUFFERIN COMMUNITY CENTRE
BOARD OF MANAGEMENT
AGENDA
TUESDAY, JANUARY 14, 2020 - 7:00 - 9:00 P.M.
NORTH DUFFERIN COMMUNITY CENTRE**



- 1. Call to order by Chair**
- 2. Additions/Deletions/Approval of the Agenda**
- 3. Declaration of Pecuniary Interest or Conflict of Interest**
- 4. Approval of Draft Minutes - December 12, 2019**
- 5. Business Arising from the Minutes**
- 6. Facility Manager's Report**
- 7. General Business**
 1. Financial
 1. Accounts
 2. YTD vs. Budget comparison
 3. A/R update
 4. 2020 Budget Draft #2
 2. NDCC Board of Management Meeting Dates for 2020
 3. Other
 4. Unfinished Business
 1. Arena Manager and Part time staff Pay Grids
- 8. Information**
 1. Mulmur Motion regarding Recreation RFP
 2. Burnside Energy Efficient Plan Volume 3 NDCC, Honeywood Arena Energy Audit Report
- 9. Notice of Motion**
- 10. Confirmation Motion**
- 11. Adjournment and Date of Next Meeting - Wednesday February 12, 2020 - 7:00 - 9:00 p.m. - North Dufferin Community Centre**



**NORTH DUFFERIN COMMUNITY CENTRE BOARD OF
MANAGEMENT
MINUTES
THURSDAY, DECEMBER 12, 2019 – 7:00 P.M.
NORTH DUFFERIN COMMUNITY CENTRE**



The North Dufferin Community Centre Board of Management known as “The Board” held its meeting on the 12th day of December, 2019 at 7:00 p.m., in the Norduff Room at The North Dufferin Community Centre. Those present:

Those present:

Chester Tupling, Chair, Mulmur
Keith Lowry, Mulmur
Patricia Clark, Councillor, Mulmur
Dave Besley, Deputy Mayor, Melancthon
Debbie Fawcett, Melancthon, Melancthon
Donna Funston, NDCC Secretary, Melancthon
Heather Boston, Mulmur, Treasurer
Tracey Atkinson, Mulmur, CAO

Regrets:

Bert Tupling, Vice-Chair, Melancthon
Nancy Noble, Mulmur
Clayton Rowbotham, Melancthon

#1 Call to Order by Chair

Chair Tupling called the meeting to order at 7:04 p.m.

#2 Additions/Deletions/Approval of Agenda

-Moved by Clark, Seconded by Besley the Agenda be approved as circulated. Carried.

#3 Declaration of Pecuniary Interest or Conflict of Interest

None.

#4 Approval of Draft Minutes

-Moved by Besley, Seconded by Clark, that the minutes of the North Dufferin Community Centre Board of Management held on November 14, 2019 be approved as circulated. Carried.

#5 Business Arising from the Minutes

1. Grant Funding – Need a solid plan in place before able to apply
2. Was time clock donated by Highland Companies? Is food first paying for advertising?
3. Heather explain capital expense versus just an expense

#1 Burnside Energy Efficient Plan (Community Energy Volume 3 North Dufferin Community Centre Energy Audit) is available on Mulmur Township website.

Grants are available for funding, ex. solar projects, Heather will forward to Donna. Heather reports the roof will not hold solar panels. It was recommended when the RFP is complete and energy report complete put both together to make a plan which will include everything.

#2 The clock was donated by Highland Companies and Heather will look into advertising fees if there are any. Sign Receivable includes Zamboni advertising, Heather to find out how old the time clock is. The clock is starting to break down, James got new box installed and working again for now. The old clock control box is being sent back to be repaired (refurbished) to have as a backup.

#3 Capital Expense will last more than one year, ex. windows, Zamboni which is also over \$2500 in cost. Guideline is basically under \$2500 it is expensed and over \$2500 it is capitalized. Capital is amortized over the expected life of the equipment and will see the expense as amortized each month.

#6 Facility Manager's Report

1. Removal of Signs and User Group Signed Contracts
2. Unfinished Business
 1. Update on hot water tank

James Woods was in attendance for this portion of the meeting.

Donna requested James to send his managers report one week ahead of the meeting date so that it can be included in the Agenda Package and reviewed by each board member before the meeting.

James reports the ice will be out earlier this year as the ladies tournament that is new this year will be in March instead of April.

James will contact Human Response regarding the false alarm calls he can't remember the other two times the alarm was set off. Human Response is going to tell him if OPP were dispatched or not. Mulmur has sent a bill for \$500 to the Arena due to the false alarm report. Board has directed Heather to not pay the Mulmur false alarm bill until James gets the report from the Human Response company.

Arena is open Dec 25, 26 and 31 as some ice time has already been rented.

Ice was low in the centre so James had to do lots of floods to build it back up to make the ice surface even.

James is directed to change the sign outside to read "Seasons Greetings"

#1 Signs have been removed. Contracts are being signed and faxed to Mulmur office. James is to contact Roseann to compare contracts that are missing. James reports all staff is good and no issues.

#2 Hot water tank is ready to run and is on propane now not hydro. Delmar to install two outlets to run safely and remove excess wires.

Member Fawcett offers to make new curtains for the Norduff Room. James is to get her the measurements.

A washer and dryer have been donated so James will be able to wash all cleaning clothes instead of throwing out.

#7 General Business

1. Financial
 1. Accounts
 2. YTD vs. Budget comparison
 3. A/R update
 4. 2020 Budget Draft #2
2. AON Insurance inspection – Park items to be Repaired
3. Other
4. Unfinished Business
 1. Arena Manager and Part time staff Pay Grids

#1.1 -Moved by Lowry, Seconded by Fawcett, be it resolved that the accounts in the amount of \$23,909.43 be approved to be paid with the exception of the false alarm report from Mulmur Township. Carried.

#1.2 Discussion around YTD figures, Board is requesting that the previous year amounts be included in financials every time. Board is most interested in comparing current year to last year numbers as well as budget figures.

#1.3 Board reviewed the A/R balances. Signs are automatically renewed once per year.

#1.4 Board will wait until January before approving budget for 2020, would like to see more actual numbers rather than estimates.

#2 Chain link fence has been broken for many years due to snow being dumped on it. Question was raised why the Board should pay for repairs when the fence has been broken for many years and was reported to Mulmur Council already in an AON report. Board directed Member Clark to take back to Mulmur Council that Mulmur be

responsible for repairs to the chain link fence. Board will do stone wall and player benches by looking for volunteers to fix.

#3 Discussed changing the date of the Board meetings. Board decided to change the meeting dates to the second Wednesday of each month starting in February 2020. Tuesday January 14 will be the first meeting of 2020 the Board is hoping to have most A/P in before that date and possibly approve budget.

#4.1 Heather to email other Arenas to determine current wage scale for Arena Manager and part-time employee positions. Discussion on how pay grids are determined, depends on things like responsibilities, handling cash, task and duties.

#8 Information

-Moved by Fawcett, Seconded by Lowry, be it resolved that items 8.1 be received as information. Carried.

#10 Closed Session

1. Approval of Draft Minutes – March 14, 2019
2. Section 239 (2)(b) of the Municipal Act, 2001 as amended, - Personal matters about an identifiable individual, including municipal or local board employees – Facility and Board Personnel Issues

-Moved by Besley, Seconded by Clark, be it resolved that we move into closed session at 8:42 p.m. Carried.

-Moved by Clark, Seconded by Besley, be it resolved that we rise from closed session at 9:28 p.m. without report. Carried.

-Moved by Clark, Seconded by Besley, be it resolved that the Arena Manager move up 1 step on Mulmur Townships pay grid and also receive the Cost of Living increase as set by Mulmur Township for the 2020 year
AND THAT both increases be effective January 1, 2020. Carried.

#9 Notice of Motion

-None

#10 Confirmation Motion

-Moved by Fawcett, Seconded by Lowry be it resolved that: all actions of the Members and Officers of the North Dufferin Community Centre Board of Management with respect to every matter addressed and or adopted by the Board on the above date are hereby adopted, ratified and confirmed; and each motion, resolution and other actions taken by the Board Members

and Officers at the meeting held on the above date are hereby adopted, ratified and confirmed.
Carried.

#11 Adjournment

-Moved by Lowry, Seconded by Fawcett that we adjourn the North Dufferin Community Centre Board of Management meeting at 9:42 p.m. to meet again on Tuesday January 14, 2020 at 7:00 p.m. at the North Dufferin Community Centre or at the call of the Chair. Carried.

CHAIR

SECRETARY

Accounts Payable

NDCC AP: Dec 1 - 31, 2019

Vendor 000000 Through 999999

Invoice Entry Date 01/01/2019 to 08/01/2020 Paid Invoices Cheque Date 01/12/2019 to 08/01/2020

Vendor Number	Vendor Name	Invoice Number	Invoice Desc	Chq Nbr	Invoice Date	Entry Date	Amount
000050	2638451 ONTARIO INC./LATTE 1420		SERVICE CALL - KITCHEN DRAIN	000298	17/12/2019	18/12/2019	783.68
			01-2000-7220 SERVICE CALL - KITCHEN DRAIN				783.68
000046	BARCLAY WHOLESAL	23747	CLARKE 20" FLOOR SCRUBBER	000289	25/11/2019	06/12/2019	6,517.22
			01-2000-7500 CLARKE 20" FLOOR SCRUBBER				6,517.22
000046	BARCLAY WHOLESAL	23775	FLOOR SCRUBBER PADS/BRUSHES	000289	25/11/2019	06/12/2019	230.19
			01-2000-7500 FLOOR SCRUBBER PADS/BRUSHES				230.19
000046	BARCLAY WHOLESAL	23564	HOCKEY FRAMES/NETS	000299	16/12/2019	18/12/2019	2,819.35
			01-2000-7500 HOCKEY FRAMES/NETS				2,819.35
000046	BARCLAY WHOLESAL	24735	ZAMBONI SPREADER CLOTH	000307	23/12/2019	31/12/2019	95.99
			01-2000-7240 ZAMBONI SPREADER CLOTH				95.99
000046	BARCLAY WHOLESAL	24914	BLADE SHARPENING	000307	23/12/2019	31/12/2019	102.55
			01-2000-7240 BLADE SHARPENING				102.55
Vendor Total							9,765.30
000040	BAYSHORE BROADCASTING (189429		HONEYWOOD BBQ ADVERTISING	000083	28/07/2019	20/11/2019	561.38
			01-2000-7300 HONEYWOOD BBQ ADVERTISING				561.38
000081	BRYAN'S ELECTRIC MOTORS 75441		ZAMBONI FILL PUMP REPAIR	000308	02/12/2019	31/12/2019	1,519.35
			01-2000-7240 ZAMBONI FILL PUMP REPAIR				1,519.35
000079	CHAMPION COMMERCIAL PR(533816		LIGHTS FOR ARENA FLOOR	000300	18/11/2019	18/12/2019	796.48
			01-2000-7220 LIGHTS FOR ARENA FLOOR				796.48
000005	DELMAR ELECTRIC	12840	PARKING LOT LIGHT REPLACEMENT	000291	20/11/2019	06/12/2019	918.13
			01-2000-7220 PARKING LOT LIGHT REPLACEMENT				918.13
000062	GFL ENVIRONMENTAL INC.	SD-0000287462	NOVEMBER - 2 LIFTS	000292	30/11/2019	10/12/2019	106.79
			01-2000-7220 NOVEMBER - 2 LIFTS				106.79
000062	GFL ENVIRONMENTAL INC.	SD-0000289511	DEC - 3 LIFTS	000309	31/12/2019	31/12/2019	160.18
			01-2000-7220 DEC - 3 LIFTS				160.18
Vendor Total							266.97
000001	HURONIA/MED-E-OX LTD	151850	ARENA FURNACE PROPANE	000293	12/11/2019	10/12/2019	120.01
			01-2000-7210 ARENA FURNACE PROPANE				120.01
000001	HURONIA/MED-E-OX LTD	171663	ARENA FURNACE PROPANE	000293	26/11/2019	10/12/2019	154.67
			01-2000-7210 ARENA FURNACE PROPANE				154.67
000001	HURONIA/MED-E-OX LTD	R2051661	ARENA FURNACE PROPANE CAGE	000293	30/11/2019	10/12/2019	7.91
			01-2000-7210 ARENA FURNACE PROPANE CAGE				7.91
000001	HURONIA/MED-E-OX LTD	172219	ARENA FURNACE PROPANE	000315	26/12/2019	31/12/2019	116.01
			01-2000-7210 ARENA FURNACE PROPANE				116.01

CB#7.1.1
JAN 14 2020

Accounts Payable

NDCC AP: Dec 1 - 31, 2019

Vendor 000000 Through 999999

Invoice Entry Date 01/01/2019 to 08/01/2020 Paid Invoices Cheque Date 01/12/2019 to 08/01/2020

Vendor Number Name	Invoice Number	Invoice Desc	Chq Nbr	Invoice Date	Entry Date	Amount
000001 HURONIA/MED-E-OX LTD	R2057057	PROPANE CAGE	000315	31/12/2019	31/12/2019	23.73
		01-2000-7210 PROPANE CAGE				23.73
000001 HURONIA/MED-E-OX LTD	172142	ARENA FURNACE PROPANE	000315	11/12/2019	31/12/2019	116.01
		01-2000-7210 ARENA FURNACE PROPANE				116.01
Vendor Total						538.34
000016 HYDRO ONE	Dec 5 2019	ICE PLANT: NOV 2019	000084	31/12/2019	31/12/2019	6,772.84
		01-2000-7200 ICE PLANT: NOV 2019				6,772.84
000016 HYDRO ONE	Nov 12 2019	BLDG: OCT 2019	000084	31/12/2019	31/12/2019	834.27
		01-2000-7200 BLDG: OCT 2019				834.27
000016 HYDRO ONE	Dec 10 2019	BLDG: NOV 2019	000084	31/12/2019	31/12/2019	809.92
		01-2000-7200 BLDG: NOV 2019				809.92
Vendor Total						8,417.03
000009 J.L. WILSON AND SONS LIMIT JL-1672186		COMPRESSOR/CONDENSER REPAIR	000301	13/12/2019	17/12/2019	4,738.15
		01-2000-7240 COMPRESSOR/CONDENSER REPAIR				4,738.15
000004 MCDONALD HOME HARDWAR 84578		SHOWER CURTAIN/CLEANER	000294	06/12/2019	10/12/2019	18.40
		01-2000-7220 SHOWER CURTAIN/CLEANER				18.40
000004 MCDONALD HOME HARDWAR 84999		STAPLES/PAINT	000311	20/12/2019	31/12/2019	47.88
		01-2000-7220 STAPLES/PAINT				47.88
000004 MCDONALD HOME HARDWAR 85082		CLEARNERS/BATTERIES	000311	23/12/2019	31/12/2019	60.13
		01-2000-7220 CLEARNERS/BATTERIES				60.13
000004 MCDONALD HOME HARDWAR 85157		VENT KIT	000311	27/12/2019	31/12/2019	30.50
		01-2000-7220 VENT KIT				30.50
Vendor Total						156.91
000014 RECEIVER GENERAL	Nov 2019	NOV REMITTANCES	000085	31/12/2019	31/12/2019	3,416.13
		01-1000-2201 NOV REMITTANCES: TAX				1,894.71
		01-1000-2203 NOV REMITTANCES: CPP				1,071.20
		01-1000-2202 NOV REMITTANCES: EI				450.22
000036 SHELBURNE FREE PRESS	6463	STRAWBERRY SUPPER THANK YOU	000295	11/07/2019	06/12/2019	18.08
		01-2000-7300 STRAWBERRY SUPPER THANK YOU				18.08
000058 SOUND BARRIERS	20818	PUCKBOARD/TEMPERED GLASS/CLIPS	000296	29/11/2019	06/12/2019	1,438.55
		01-2000-7500 PUCKBOARD/TEMPERED GLASS/CLIPS				1,438.55
000011 SPARLINGS PROPANE	88725066963443	ARENA BOOTH PROPANE	000302	06/12/2019	17/12/2019	150.45
		01-2000-7230 ARENA BOOTH PROPANE				150.45
000011 SPARLINGS PROPANE	88725066963444	ARENA BOOTH PROPANE	000302	12/12/2019	20/12/2019	1,063.59
		01-2000-7230 ARENA BOOTH PROPANE				1,063.59
000011 SPARLINGS PROPANE	88725066963446	ARENA BOOTH PROPANE	000314	26/12/2019	31/12/2019	75.03

Accounts Payable

NDCC AP: Dec 1 - 31, 2019

Vendor 000000 Through 999999

Invoice Entry Date 01/01/2019 to 08/01/2020 Paid Invoices Cheque Date 01/12/2019 to 08/01/2020

Vendor Number Name	Invoice Number	Invoice Desc	Chq Nbr	Invoice Date	Entry Date	Amount
		01-2000-7230		ARENA BOOTH PROPANE		75.03
				Vendor Total		1,289.07
000020	TD BANK	Dec 2019		DEC BANK CHARGES: EDI/EFT	000086 31/12/2019 31/12/2019	95.73
				01-2000-7150	DEC BANK CHARGES: EDI/EFT	95.73
000020	TD BANK	Dec 16 2019		BMO BANK FEE	000086 31/12/2019 31/12/2019	28.25
				01-2000-7150	BMO BANK FEE	28.25
				Vendor Total		123.98
000080	TECHNICAL STANDARDS & S	3419215		REFRIGERATION PLANT INSPECTION	000303 13/12/2019 20/12/2019	448.61
				01-2000-7240	REFRIGERATION PLANT INSPECTION	448.61
000006	TELIZON INC	03500420191213		ACCT #35004 - ARENA DEC	000304 13/12/2019 18/12/2019	67.47
				01-2000-7110	ACCT #35004 - ARENA DEC	67.47
000013	WAYNE BIRD FUELS	565586		ARENA FURNACE OIL	000297 27/11/2019 06/12/2019	449.12
				01-2000-7210	ARENA FURNACE OIL	449.12
000013	WAYNE BIRD FUELS	565587		ARENA FURNACE OIL	000297 27/11/2019 06/12/2019	1,156.91
				01-2000-7210	ARENA FURNACE OIL	1,156.91
000013	WAYNE BIRD FUELS	569451		ARENA FURNACE OIL	000305 12/12/2019 17/12/2019	109.12
				01-2000-7210	ARENA FURNACE OIL	109.12
000013	WAYNE BIRD FUELS	570800		ARENA FURNACE OIL	000312 19/12/2019 31/12/2019	745.97
				01-2000-7210	ARENA FURNACE OIL	745.97
000013	WAYNE BIRD FUELS	570772		ARENA FURNACE OIL	000312 19/12/2019 31/12/2019	750.87
				01-2000-7210	ARENA FURNACE OIL	750.87
				Vendor Total		3,211.99
000017	WORKPLACE SAFETY & INSUI	Dec 2019		4TH QTR WSIB	000087 31/12/2019 31/12/2019	203.15
				01-1000-2205	4TH QTR WSIB	203.15
000056	ZAMBONI COMPANY LTD.	103548		ZAMBONI REPAIR	000313 16/12/2019 31/12/2019	618.68
				01-2000-7240	ZAMBONI REPAIR	618.68
000061	ZEKE AIR HEATING & COOLIN	7608		2 WATER HEATERS/ UNIT HEATER	000306 17/12/2019 18/12/2019	10,885.06
				01-2000-7500	2 WATER HEATERS/ UNIT HEATER	10,885.06
				Unpaid Invoices		0.00
				Paid Invoices		50,182.49
				Invoices Total		50,182.49
				Selected G/L Account Total		50,182.49

PAYROLL: \$6,023.91

GRAND TOTAL: \$56,206.40

General Ledger
Annual Department Budget vs. Actual Comparison Report
 Fiscal Year Ending: DEC 31,2019 - From Period 1 To Period 12 Ending DEC 31,2019

Account	Description	Previous Year Total		Current Year To Date		Budget Remaining
		Actual	Budget	Actual	Budget	

Fund: 01 OPERATING FUND

Category: 2???

2000 INCOME STATEMENT

Revenue						
01-2000-4000	MULMUR GRANT	25,276.51	25,276.50	55,023.65	55,023.65	0.00
01-2000-4010	MELANCTHON GRANT	25,276.51	25,276.50	55,023.65	55,023.65	0.00
01-2000-4015	GRANT REVENUE	0.00	0.00	0.00	0.00	0.00
01-2000-4020	DONATION REVENUE	100.00	0.00	2,819.35	0.00	(2,819.35)
01-2000-4030	FUNDRAISING REVENUE	20,272.50	20,000.00	19,046.55	20,000.00	953.45
01-2000-4100	MINOR RATE ICE RENTAL REVEN	45,901.31	45,000.00	54,020.55	45,000.00	(9,020.55)
01-2000-4110	ICE RENTAL REVENUE (PRIME)	47,663.05	52,000.00	50,822.88	52,000.00	1,177.12
01-2000-4115	ICE RENTAL REVENUE (NON-PRIM	696.90	500.00	1,632.74	500.00	(1,132.74)
01-2000-4120	NON-RESIDENT USER FEES	3,578.13	3,000.00	3,696.16	3,250.00	(446.16)
01-2000-4200	BOOTH RENTAL REVENUE	3,561.30	4,300.00	2,169.96	5,000.00	2,830.04
01-2000-4210	HALL RENTAL REVENUE	2,230.07	2,600.00	4,011.50	2,600.00	(1,411.50)
01-2000-4220	FLOOR RENTAL REVENUE	463.35	0.00	97.34	0.00	(97.34)
01-2000-4230	SIGN RENTAL REVENUE	3,980.00	4,160.00	4,020.00	4,160.00	140.00
01-2000-4240	VENDING MACHINE REVENUE	237.92	250.00	109.39	0.00	(109.39)
01-2000-4300	PENALTIES & INTEREST	773.32	525.00	869.44	525.00	(344.44)
01-2000-4500	PR YR SURPLUS/DEFICIT	0.00	0.00	(29,582.29)	(29,582.30)	(0.01)
Total Revenue		180,010.87	182,888.00	223,780.87	213,500.00	(10,280.87)
Expense						
01-2000-7000	WAGES	52,760.48	45,000.00	66,060.81	55,000.00	(11,060.81)
01-2000-7005	BENEFITS-EI/CPP/WSIB/EHT	5,066.02	5,600.00	5,539.58	5,600.00	60.42
01-2000-7010	BENEFITS-OMERS	1,740.40	3,000.00	0.00	0.00	0.00
01-2000-7012	MILEAGE	0.00	0.00	284.23	0.00	(284.23)
01-2000-7015	STAFF TRAINING/DUES, FEES, SU	1,555.76	300.00	1,149.12	300.00	(849.12)
01-2000-7100	OFFICE/COMPUTER SUPPLIES	1,901.41	1,200.00	2,427.87	1,700.00	(727.87)
01-2000-7110	COMMUNICATION	2,511.70	3,000.00	1,968.35	3,000.00	1,031.65
01-2000-7115	INSURANCE	11,763.24	12,200.00	12,518.16	12,200.00	(318.16)
01-2000-7120	HEALTH & SAFETY	2,086.80	2,800.00	38.84	2,800.00	2,761.16
01-2000-7125	PROF FEES - AUDIT	1,403.12	1,188.00	610.56	1,400.00	789.44
01-2000-7130	PROF FEES - WATER TESTING	231.99	300.00	317.81	300.00	(17.81)
01-2000-7150	BANK CHARGES	387.71	500.00	771.70	400.00	(371.70)
01-2000-7200	HYDRO	55,360.14	60,000.00	43,095.83	60,000.00	16,904.17
01-2000-7210	FURNACE FUEL/ZAMB PROPANE	15,067.35	12,000.00	14,711.62	12,000.00	(2,711.62)
01-2000-7220	BLDG & GROUNDS MAINTENANCI	23,665.01	15,000.00	16,730.55	20,000.00	3,269.45
01-2000-7230	BOOTH MAINTENANCE	4,462.00	1,300.00	1,667.85	1,300.00	(367.85)
01-2000-7240	ICE PLANT/MACH MAINTENANCE	18,770.67	9,000.00	18,153.39	12,000.00	(6,153.39)
01-2000-7300	FUNDRAISING EXPENSE	10,859.36	10,500.00	10,992.69	10,500.00	(492.69)
01-2000-7400	BAD DEBT	0.00	0.00	220.63	0.00	(220.63)
01-2000-7500	CAPITAL PURCHASES	0.00	0.00	19,372.01	15,000.00	(4,372.01)
Total Expense		209,593.16	182,888.00	216,631.60	213,500.00	(3,131.60)
Dept Excess Revenue Over (Under) Expenditures		(29,582.29)	0.00	7,149.27	0.00	(7,149.27)

GB#7.1.2
 JAN 14 2020

General Ledger
Annual Department Budget vs. Actual Comparison Report
Fiscal Year Ending: DEC 31,2019 - From Period 1 To Period 12 Ending DEC 31,2019

Account	Description	Previous Year Total		Current Year To Date		Budget Remaining
		Actual	Budget	Actual	Budget	
Category Excess Revenue Over (Under) Expenditures		(29,582.29)	0.00	7,149.27	0.00	(7,149.27)

General Ledger
Annual Department Budget vs. Actual Comparison Report
 Fiscal Year Ending: DEC 31,2019 - From Period 1 To Period 12 Ending DEC 31,2019

Account	Description	Previous Year Total		Current Year To Date		Budget Remaining
		Actual	Budget	Actual	Budget	
REPORT SUMMARY						
01-2000	INCOME STATEMENT	180,010.87	182,888.00	223,780.87	213,500.00	(10,280.87)
	Fund 01 Total Revenue	180,010.87	182,888.00	223,780.87	213,500.00	(10,280.87)
01-2000	INCOME STATEMENT	209,593.16	182,888.00	216,631.60	213,500.00	(3,131.60)
	Fund 01 Total Expenditure	209,593.16	182,888.00	216,631.60	213,500.00	(3,131.60)
	Fund 01 Excess Revenue Over (Under) Expenditures	(29,582.29)	0.00	7,149.27	0.00	(7,149.27)
	Report Total Revenue	180,010.87	182,888.00	223,780.87	213,500.00	(10,280.87)
	Report Total Expenditure	209,593.16	182,888.00	216,631.60	213,500.00	(3,131.60)
	Report Excess Revenue Over (Under) Expenditures	(29,582.29)	0.00	7,149.27	0.00	(7,149.27)

**NDCC Board of Management
2020 Budget**

Account	Description	2018 Actuals	2018 Budget	2019 Actual	2019 Budget	Draft #1 2020 Budget	Draft #2 2020 Budget	Draft #3 2020 Budget	Budget Variance	Comments
REVENUES										
01-2000-4000	MULMUR GRANT	25,277	25,277	55,024	55,024	48,948	48,812	52,427	(6,212)	-11.04%
01-2000-4010	MELANCTHON GRANT	25,277	25,277	55,024	55,024	48,948	48,812	52,427	(6,212)	-11.04%
01-2000-4020	DONATION REVENUE	100	-	2,819	-				0	
01-2000-4030	FUNDRAISING REVENUE	20,273	20,000	19,047	20,000	20,000	20,000	20,000	0	BBQ, Straw, Supper
01-2000-4100	MINOR RATE RENTAL REVENUE	45,901	45,000	54,021	45,000	45,000	45,000	45,000	0	
01-2000-4110	ICE RENTAL REVENUE (PRIME)	47,663	52,000	50,823	52,000	51,000	51,000	51,000	(1,000)	
01-2000-4115	ICE RENTAL REVENUE (NON-PRIME)	697	500	1,633	500	500	500	500	0	
01-2000-4120	NON-RESIDENT USER FEES	3,578	3,000	3,696	3,250	3,250	3,250	3,250	0	
01-2000-4200	BOOTH RENTAL REVENUE	3,561	4,300	2,170	5,000	3,500	3,500	3,500	(1,500)	
01-2000-4210	HALL RENTAL REVENUE	2,230	2,600	4,012	2,600	2,600	2,600	2,600	0	
01-2000-4220	FLOOR RENTAL REVENUE	463	-	97	-				0	
01-2000-4230	SIGN RENTAL REVENUE	3,980	4,160	4,020	4,160	3,700	3,700	3,700	(460)	
01-2000-4240	VENDING MACHINE REVENUE	238	250	109	-	-	-	-	0	
01-2000-4300	PENALTIES & INTEREST	773	525	869	525	1,304	788	1,956	263	
01-2000-4500	PRIOR YEAR DEFICIT			(29,582)	(29,582)				29,582	
	TOTAL REVENUE	180,011	182,888	223,781	213,500	228,750	227,961	236,361		
EXPENSES										
01-2000-7000	WAGES	52,760	45,000	66,061	55,000	65,000	65,000	65,000		
01-2000-7005	BENEFITS-EI/PPP/WSIB/EHT	5,066	5,600	5,540	5,600	5,600	5,600	5,600		
01-2000-7010	BENEFITS-OMERS	1,740	3,000	-	-	4,950	4,950	4,950	4,950	
01-2000-7012	MILEAGE			284					0	
01-2000-7015	STAFF TRAINING/DUES, FEES, SUBSCRIP	1,556	300	1,149	300	1,000	1,000	1,000	700	
01-2000-7100	OFFICE/COMPUTER SUPPLIES	1,901	1,200	2,428	1,700	2,000	2,000	2,000	300	
01-2000-7110	COMMUNICATION	2,512	3,000	1,968	3,000	3,000	3,000	3,000	0	
01-2000-7115	INSURANCE	11,763	12,200	12,518	12,200	13,300	13,300	13,300	1,100	
01-2000-7120	HEALTH & SAFETY	2,087	2,800	2,039	2,800	2,500	2,500	2,500	(300)	billed at y/e
01-2000-7125	PROF FEES - AUDIT	1,403	1,188	611	1,400	1,400	611	611	(789)	per quote
01-2000-7130	PROF FEES - WATER TESTING	232	300	318	300	300	300	300	0	
01-2000-7150	BANK CHARGES	388	500	772	400	500	500	500	100	
01-2000-7200	HYDRO	55,360	60,000	59,096	60,000	60,000	60,000	60,000	0	
01-2000-7210	FURNACE FUEL/ZAMB PROPANE	15,067	12,000	14,712	12,000	15,000	15,000	15,000	3,000	
01-2000-7220	BLDG/GROUNDS MAINTENANCE	23,665	15,000	16,731	20,000	17,400	17,400	17,400	(2,600)	
01-2000-7230	BOOTH MAINTENANCE	4,462	1,300	1,668	1,300	1,300	1,300	1,700	400	
01-2000-7240	ICE PLANT/MACH MAINT	18,771	9,000	18,153	12,000	10,000	10,000	18,000	6,000	
01-2000-7300	FUNDRAISING EXPENSE	10,859	10,500	10,993	10,500	10,500	10,500	10,500	0	
01-2000-7400	BAD DEBT	0	-	221	-	-	-	-	0	
01-2000-7500	CAPITAL PURCHASES	0	-	19,372	15,000	15,000	15,000	15,000	0	
	TOTAL EXPENSES	209,593	182,888	234,632	213,500	228,750	227,961	236,361	14,461	6.77%
	Net Income/(Deficit)	(29,582)	0	(10,851)	0	0	0	0		

Operating Reserve Continuity	2018	2019	2020
Opening Reserve Balance	-	40,000	40,000
Operating Levy Mulmur	20,000	-	-
Operating Levy Melancthon	20,000	-	-
Ending Reserve Balance	40,000	40,000	40,000

GIB#7.1.4
JAN 14 2020



**NORTH DUFFERIN COMMUNITY CENTRE BOARD OF
MANAGEMENT**

Meeting Dates for 2020

Meeting Location: North Dufferin Community Centre

Meeting Times: 7:00 p.m. – 9:00 p.m.



TUESDAY JANUARY 14, 2020

WEDNESDAY FEBRUARY 12, 2020

WEDNESDAY MARCH 11, 2020

WEDNESDAY APRIL 8, 2020

WEDNESDAY MAY 13, 2020

WEDNESDAY JUNE 10, 2020

WEDNESDAY JULY 8, 2020

WEDNESDAY AUGUST 12, 2020

WEDNESDAY SEPTEMBER 9, 2020

WEDNESDAY OCTOBER 14, 2020

WEDNESDAY NOVEMBER ?, 2020

WEDNESDAY DECEMBER 9, 2020

CIB # 7.2

JAN 14 2020

Donna Funston

Subject: FW: Council Decision Letter - Recreation RFP

From: Michelle Smibert <msmibert@mulmur.ca>

Sent: December 11, 2019 5:55 PM

To: Tracey Atkinson <tatkinson@mulmur.ca>

Cc: Heather Boston <hboston@mulmur.ca>

Subject: Council Decision Letter - Recreation RFP

This is to advise that at the December 11, 2019 Council meeting, the following resolution was adopted:

THAT Council accepts the proposal from Sierra Planning and Management in the amount of \$54,280 plus HST with contributions of \$16, 197.50 plus HST from Melancthon and \$38,082.50 plus HST from Mulmur. Carried

Michelle Smibert, MPA, CMO | Clerk


Township of Mulmur | 758070 2nd Line East | Mulmur, Ontario L9V 0G8

Phone 705-466-3341 ext. 223 | Fax 705-466-2922 | msmibert@mulmur.ca





BURNSIDE



Community Energy Plan

Volume 3
North Dufferin Community
Centre, Honeywood Arena
Energy Audit Report
Draft

Township of Mulmur



December 2019



INFD#2

JAN 14 2020

Distribution List

No. of Hard Copies	PDF	Email	Organization Name
-	Yes	Yes	Initial Draft Submission to Township of Mulmur

Record of Revisions

Revision	Date	Description
-	December 6, 2019	Initial Draft Submission to Township of Mulmur

R.J. Burnside & Associates Limited**Report Prepared By:**

Spencer Brown, P.Eng., C.E.A.
Project Engineer
SB:sp

Peter Mensinga, M.A.Sc., P.Eng.
Manager, Building Restoration
PM:sp

Report Reviewed By:

Dominic Garisto, C.E.T., L.E.T.
Mechanical Technologist
DG:sp

Lyle Parsons, B.E.S.
Vice President Environment
LP:sp

Executive Summary

Introduction: Project Scope, Objective and Strategies

R.J. Burnside & Associates Limited (Burnside) is engaged by the Township of Mulmur (Mulmur) to develop a Community Energy Plan (CEP). As part of that CEP a number of demonstration projects were included to show the benefits of energy conservation. This particular component of the study was to conduct an Energy Audit (EA) of the North Dufferin Community Center building in Honeywood. Its address is 706114 County Rd 21, Mulmur, ON L0N1H0. These kind of energy audits can be conducted at any building and are case specific to the buildings being assessed.

Energy Efficiency Results and Recommendations without Climate Action Incentive Fund (CAIF)

Seven Energy Efficiency Measures (EEMs) were identified with implementation costs and annual energy savings estimates. The annualized savings of all recommendations totals more than \$16,996.00 (at projected energy prices). If fully implemented, the average weighted payback period¹ from annual energy savings for these EEMs is estimated to be 7.9 years. Details are outlined in the table below.

Table 1: North Dufferin Community Centre Energy Efficiency Recommendations

EEM No.	Energy Efficiency Measure	Measure Type	Approximate Annual Savings	Net Estimated Costs	Simple Payback Years
1	EEM 1 - LED Lighting – Interior Lights	Upgrade Building Systems	\$216.00	\$1,105.00	5.1
2	EEM 2 - LED Lighting – Exterior Parking Lot Lights	Upgrade Building Systems	\$160.00	\$790.00	4.9
3	EEM 3 - Install Programmable Thermostats	Upgrade Building Systems	\$750.00	\$400.00	0.5
4	EEM 4 – Building Envelope Analysis – Roof Insulation	Upgrade Building Envelope	\$1,780.00	\$8,500.00	4.8
7	EEM 7 – Water Conservation -Low Flow Fixtures	Upgrade Building Systems	\$490.00	\$1,800.00	3.7
10	EEM 10 New Zamboni Hot Water System	Upgrade Building Systems	\$1,165.00	\$8,000.00	6.9
12	EEM12 Rooftop Solar	Renewable Technology	\$12,435.00	\$114,375.00	9.2
Totals			\$16,996.00	\$134,970.00	5.0

¹ Average weighted payback is the total approximate savings divided by the total approximate net costs.

Climate Action Incentive Fund (CAIF)

There is a program expected to be announced from the federal government to provide incentives to Municipalities for energy efficiency and renewable energy projects. A similar program for private businesses was operational in 2019 providing 25 percent incentive on capital costs. The tables below outline the revised paybacks for projects (at 25%), should this program be launched.

Table 2: North Dufferin Community Centre Energy Efficiency Recommendations with CAIF Funding

EEM No.	Energy Efficiency Measure	Measure Type	Approximate Annual Savings	CAIF Incentive	Net Estimated Costs	Simple Payback Years
1	EEM 1 - LED Lighting – Interior Lights	Upgrade Building Systems	\$216.00	\$374.00	\$731.00	3.4
2	EEM 2 - LED Lighting – Exterior Parking Lot Lights	Upgrade Building Systems	\$160.00	\$223.00	\$568.00	3.5
3	EEM 3 - Install Programmable Thermostats	Upgrade Building Systems	\$750.00	\$100.00	\$300.00	0.4
4	EEM 4 – Building Envelope Analysis – Roof Insulation	Upgrade Building Envelope	\$1,780.00	\$2,125.00	\$6,375.00	3.6
7	EEM 7 – Water Conservation - Low Flow Fixtures	Upgrade Building Systems	\$490.00	\$450.00	\$1,350.00	2.8
10	EEM 10 New Zamboni Hot Water System	Upgrade Building Systems	\$1,165.00	\$2,000.00	\$6,000.00	5.2
11	EEM11 Desuperheater	Upgrade Building Systems	\$3,710.00	\$10,625.00	\$31,875.00	8.6
12	EEM12 Rooftop Solar	Renewable Technology	\$12,435.00	\$28,594.00	\$85,781.00	6.9
Totals			\$20,706.00	\$44,491.00	\$132,980.00	4.3

Note: Simple payback is an average of all projects

Energy Audit Strategies and Methods

This report review includes all the energy and estimated cost saving measures as follows with regards to both functionality and code upgrades:

- Building Automation Systems (BAS);
- Boilers, furnaces, heaters;
- Toilet and fixture replacement;
- LED lighting;
- Roof insulation;

CEP Volume 3: Energy Audit Report
December 2019

- Rooftop solar; and
- Heat Recovery.

The energy audit method was broken down into four phases which are described as follows:

Baseline Development:

Gathering all pertinent data: billing information histories, drawings, specifications, engineering report, conduct site visit and interview building operators, generate equipment list and identify potential energy saving measures. Interview with building operators, generate equipment list and conduct site inspection for individual system to identify the potential energy saving measures.

Analysis and Energy Efficiency Measures (EEMs)

Collect all historic data for utility and energy consumption simulation, and building assessment report(s), drawings and other related information (provided by the Township). Provide an analysis of potential Energy Efficiency Measures for conventional and renewable energy technologies, taking into consideration of the building behavior, operational schedule changes and deficiencies.

Review and calculation energy consumption before and after a potential retrofit.

Final Draft and Report

Produce the draft energy audit report and energy performance specifications for the North Dufferin Community Centre review and incorporate comments and suggestion for the final report. Issue the energy audit report and apply related incentive initiatives as needed.

Table 3: North Dufferin Community Centre Energy Efficiency Measures Not Recommended

EEM No.	Energy Efficiency Measure	Measure Type	Approx. Annual Savings	Net Estimated Costs	Simple Payback Years
5	EEM 5 – Building Envelope Analysis – New Doors	Upgrade Building Envelope	\$103.00	\$1,500.00	14.6
6	EEM 6 – Building Envelope Analysis – New Windows	Upgrade Building Envelope	\$806.00	\$38,000.00	47.1
8	EEM 8 – Upgrade North Community Centre Furnace to Higher Efficiency	Upgrade Building Systems	\$104.00	\$7,000.00	67.5
9	EEM 9 - Drain Water Heat Recovery	Upgrade Building Systems	\$304.00	\$4,500.00	14.8
11	EEM11 Desuperheater	Upgrade Building Systems	\$3,710.00	\$42,500.00	11.5
Totals			\$5,027.00	\$93,500.00	18.6

Measure Type	Energy Efficiency Measure	Electricity	Oil	CO ₂ e Reduction	Total Savings per Year	Original Cost	Incentives	Net Savings
		kWh	L	MTCDE				
Building Systems	EEM 1 - LED Lighting – Interior Lights	1,300		0	\$216.00	\$1,495.00	\$390.00	\$0.00
Building Systems	EEM 2 - LED Lighting – Exterior Parking Lot Lights	964		0	\$160.00	\$890.00	\$100.00	\$0.00
Building Systems	EEM 3 - Install Programmable Thermostats	0	1000	3	\$750.00	\$400.00	\$0.00	\$0.00
Building Envelope	EEM 4 – Building Envelope Analysis – Roof Insulation	0	2144	6	\$1,780.00	\$8,500.00	\$0.00	\$0.00
Building Envelope	EEM 5 – Building Envelope Analysis – New Doors		136	0	\$103.00	\$1,500.00	\$0.00	\$0.00
Building Envelope	EEM 6 – Building Envelope Analysis – New Windows		1075	3	\$806.00	\$38,000.00	\$0.00	\$0.00
Building Systems	EEM 7 – Water Conservation -Low Flow Fixtures		571	2	\$490.00	\$1,800.00	\$0.00	\$0.00
Building Systems	EEM 8 – Upgrade Furnace to Higher Efficiency		125	0	\$104.00	\$7,000.00	\$0.00	\$0.00
Building Systems	EEM 9 - Drain Water Heat Recovery		367	1	\$304.00	\$4,500.00	\$0.00	\$0.00
Building Systems	EEM 10 New Zamboni Hot Water System		682	2	\$1,165.00	\$8,000.00	\$0.00	\$0.00
Building Systems	EEM11 Desuperheater	0	4,470	12	\$3,710.00	\$42,500.00	\$0.00	\$0.00
Renewable Technology	EEM12 Rooftop Solar	228,000		0	\$12,435.00	\$114,375.00	\$0.00	\$0.00

Table 5: Glossary of Terms

Term	Description
Watt (W)	Unit of Power in Joules/s.
Kilowatt (kW)	1000 Watts
Megawatt (MW)	1000 kilowatts
ekWh	Equivalent Kilo-watt hours, standard unit of energy consumption to compare energy sources.
Watt hour (Wh)	A measure of power over time – 1 Wh is 1W power consumption over 1 hour.
Kilowatt hour (kWh)	1000 Wh
Megawatt Hour (MWh)	1000 kWh
British Thermal Unit (BTU)	A measure of energy.
kBTU	One thousand BTUs.
m ³	Meter cubed a unit of volume.
ECI	The Energy Cost Index (ECI) of the building (expressed in dollars per floor area per year).
GHG	Green house fuel oil.
Source EUI	The Energy Utilization Index (EUI) of the Source (expressed in kBtu/ft ² [MJ/m ²] per year).
Site EUI	The Energy Utilization Index (EUI) of the Site (expressed in kBtu/ft ² [MJ/m ²] per year).
Demand Charge	Charge from Hydro distribution companies based on the capacity amount allocated to your building.
Peak Demand	The largest power consumption for a system, usually over a 1 year time period.
EEM	Energy Efficiency Measure.
ECM	Energy Efficiency Measure.
Blended Rate	A rate \$/kWh for electricity including demand charges, regulatory charges, supply charges, global adjustment, and taxes.
Heating Degree Day (HDD)	The number of degrees that a day's average temperature is below 18 degrees Celsius.
Net Present Value (NPV)	The value of all the future cash flows added up and multiplied with the discount rate.
Discount Rate	Often considered the hurdle rate this is the rate which an entity can receive on other investments. A discount rate is used to discount future cash flows to measure project risk.
Simple Payback	The time in years it takes to recoup an initial capital investment. Comparing paybacks of different investments provides a good way to make financial decisions.
Return on Investment (ROI)	The ROI is the net profit of an investment divided by the capital cost. Comparing ROI's of different investments provides a good way to make financial decisions.

Table of Contents

1.0	Energy Utility Analysis	9
1.1	Audit Scope and Methodology	9
1.1.1	Preliminary Analysis	9
1.1.2	Audit Site Investigation	9
1.1.3	Water Consumption Review.....	9
1.2	Description of the Site and Building	10
1.3	Preliminary End Use Analysis.....	11
1.3.1	Billing Data Review.....	11
1.3.2	Fuel Oil Rates.....	13
1.3.3	Propane Rates.....	13
1.3.4	Water Rates.....	13
1.3.5	Monthly Energy Usage.....	13
1.3.6	Fuel Oil Adjusted Baseline for Heating.....	17
1.3.7	Electricity Adjusted Baseline	17
1.3.8	Breakdown of Energy Charges and Consumption.....	18
1.3.9	End Use Breakdown	19
1.3.10	Energy Benchmark	20
2.0	Building Envelope	21
2.1	Exterior Cladding System	21
2.2	Roofing.....	23
3.0	Building Systems	25
3.1	Lighting Systems.....	25
3.1.1	Interior Lighting.....	25
3.1.2	Exterior Lighting.....	27
3.2	Mechanical Systems	27
3.2.1	HVAC System.....	27
3.2.2	Plumbing and Fixtures	28
3.2.3	Domestic Hot Water.....	30
3.2.4	Zamboni Hot Water.....	30
3.2.5	Ice Refrigeration System.....	31
4.0	Occupancy Schedule	32
5.0	Energy Efficiency Measures	33
5.1	No-Cost/Low-Cost Measures	33
5.1.1	EEM 1 – Interior Lighting Analysis – LED Lighting	34
5.1.2	EEM 2 – Exterior Parking Lot Lights - LED Lighting	34
5.1.3	EEM 3 – Programmable Thermostats	35
5.2	Capital Investment Measures	36
5.2.1	EEM 4 – Building Envelope Analysis – Roof Insulation	36
5.2.2	EEM 5 – Building Envelop Analysis – New Doors	36
5.2.3	EEM 6 – Building Envelop Analysis – New Windows	36
5.2.4	EEM 7 – Water Conservation – Low Flow Fixtures	37
5.2.5	EEM 8 – Upgrade Furnace to Higher Efficiency Furnace	37
5.2.6	EEM 9 – Drain Water Heat Recovery.....	38
5.2.7	EEM 10 – New Zamboni Hot Water System	39

5.2.8	EEM 11 – Desuperheater - Heat Recovery	40
5.3	Distributed Generation/Renewable Energy Measures	40
5.3.1	EEM 12 – Rooftop Solar with Net Metering Connections	40
6.0	Climate Action Initiative Fund	41
6.1	EEMs Recommended with CAIF	42
7.0	Summary	43

Tables

Table 1:	North Dufferin Community Centre Energy Efficiency Recommendations	1
Table 2:	North Dufferin Community Centre Energy Efficiency Recommendations with CAIF Funding	2
Table 3:	North Dufferin Community Centre Energy Efficiency Measures Not Recommended	3
Table 4:	North Dufferin Community Centre Energy Efficiency Details.....	4
Table 5:	Glossary of Terms	5
Table 6:	North Dufferin Community Centre Building Information	10
Table 7:	North Dufferin Community Centre Electricity Charges	12
Table 8:	Hydro One Charges General Service Greater than 50 kW	12
Table 9:	Fuel Oil Charges	13
Table 10:	North Dufferin Community Centre Electricity Consumption Summary.....	14
Table 12:	Average m ³ Consumption Per HDD.....	17
Table 13:	Adjusted Fuel oil Use Baseline	17
Table 14:	Combined kWh Breakdown for North Dufferin Community Centre.....	19
Table 15:	Occupancy Schedule.....	33
Table 16:	North Dufferin Community Centre Energy Efficiency Recommendations with CAIF Funding	43
Table 17:	North Dufferin Community Centre Energy Efficiency Recommendations	44
Table 18:	North Dufferin Community Centre EEMs not Recommended	44

Figures

Figure 1:	North Dufferin Community Centre 2015-2018 Hydro Usage	15
Figure 2:	North Dufferin Community Centre 2016-2018 Fuel Oil Usage	15
Figure 3:	North Dufferin Community Centre 2016 to 2018 Estimated Propane Usage.....	16
Figure 4:	North Dufferin Community Centre 2016-2018 Estimated Fuel Usage.....	16
Figure 5:	North Dufferin Community Centre 2018 Total Energy Usage (kWh)	18
Figure 6:	North Dufferin Community Centre Total Energy Cost 2016 to 2017.....	18
Figure 7:	Total kWh by End Use for North Dufferin Community Centre	20
Figure 8:	Total ekWh/ft ² by End Use for North Dufferin Community Centre	21
Figure 9:	North Dufferin Community Centre Exterior Wall Assembly	22
Figure 10:	Common Area Window	22
Figure 11:	Common Area Single Pane Window to Unheated Arena.....	23
Figure 12:	Sloped Roof Over Rink.....	24
Figure 13:	Changeroom Lighting Example	25
Figure 14:	Rink Lighting	26
Figure 15:	Auditorium Lighting	26
Figure 16:	HPS Parking Lot Lights	27

Figure 17: LED Parking Lot Lights.....	27
Figure 18: Common Area Oil Furnaces.....	28
Figure 19: Typical in Suite Electric Baseboard Heater.....	28
Figure 20: Typical Changeroom.....	29
Figure 21: Typical Sink Fixtures.....	29
Figure 22: Domestic Hot Water Tank.....	30
Figure 23: Zamboni Hot Water Storage Tank.....	31
Figure 24: Zamboni Hot Water Heating Tank and Electrical Heating Wall Mount.....	31
Figure 25: Ice Plant Compressors.....	32
Figure 26: Ice Plant.....	32
Figure 27: Drain Water Heat Recovery System.....	39

Appendices

Appendix A Data

Appendix B Calculations

Appendix C Benchmark Report

Appendix D Drawings

1.0 Energy Utility Analysis

1.1 Audit Scope and Methodology

R.J. Burnside & Associates Limited (Burnside) conducted the site visit at the North Dufferin Community Centre on July 1, 2019. Following the site visit, analysis was performed by Burnside and included a review of mechanical, electrical, building sciences, energy modelling, and renewable energy. Included in the analysis was a preliminary end use analysis, energy audit, and water consumption review. A review of safety features such as ammonia monitoring equipment was not included in this review.

1.1.1 Preliminary Analysis

The preliminary analysis precedes an audit of a building. During the preliminary analysis the historic utility use, peak demand, and cost were analyzed. A comparison of electricity usage to similar buildings, where available (including the source, size and date of the sample) was completed. Monthly energy use and peak demand was reviewed to identify efficiency or behavioral modification opportunities. Sequence of operations reports, floor plan, mechanical, electrical, architectural, and structural drawings for each of the buildings that were received were reviewed.

1.1.2 Audit Site Investigation

During the site investigation a description of the physical characteristics of the facility, as well as its current condition, state of repair and maintenance, approximate date of last major renovation, age and construction type were reviewed. The major existing electricity-using equipment including lighting, main sources of heating and cooling, their energy consumption and fuel type as well as the manufacturer, model number, age, physical condition and estimated remaining years of service were noted.

1.1.3 Water Consumption Review

The water closets and faucets are manually operated and have not been fully retrofitted to low-flow fixtures. They may be consuming significant amounts of water, typically 6 Litres per flush (LPF) for toilet and 5.7 liters per minute (LPM) for lavatory faucet respectively. No significant water leakage is identified per building operator. An estimate of the base case of water consumption calibrated to annual water bills was completed.

1.2 Description of the Site and Building

The North-Dufferin Community Centre, located in Honeywood is an arena, with a two-story community centre complete with an ice rink, auditorium, canteen, changerooms, and viewing area. There are four changerooms, with two smaller changerooms, and two male and two female washrooms. The auditorium and stage are on the 2nd floor above the foyer overlooking the arena. There are two main entrances both on the west side of the building. The parking lot is on the west side of the building, shared with the fire hall to the north. The building is generally occupied from September when ice making ramps up until the end of April with the facility being used sparingly in the summer.

Table 6: North Dufferin Community Centre Building Information

Address	706114 Regional Road 21, Mulmur
Building Type	Recreation Facility
Height	Two Floors Above Grade
Parking Description	Outdoor parking spaces
Building Construction Type	Concrete and Wood
Year Constructed	1965
Gross Floor Area (GFA)	27,724 sq. ft.

Building Energy Audit Summary

The following items highlight the key observations of the Energy Audit by subject area.

Energy Audit of:	North Dufferin Community Centre
Year of Construction	1965
General Description	The North Dufferin Community Center is an arena, with a two-story community centre complete with an ice rink, auditorium, canteen, changerooms, and viewing area. There are four changerooms, with two smaller changerooms, and two male and two female washrooms. There is a community hall and stage on the 2nd floor above the foyer overlooking the arena. There are two main entrances both on the west side of the building. The parking lot is on the west side of the building, shared in part with the fire hall to the north. The building is generally occupied from September when ice making ramps up until the end of April with the facility being used sparingly for special events in the summer.
Building Envelope	Exterior walls are composed of metal siding over insulation and a concrete block back-up wall. Windows are composed of two sets of single pane glazing in metal frames. The Community Centre portion of the building is protected with a flat roof overtop an insulated attic space. The ice rink's is protected by an uninsulated, sloped metal roof with a urethane foam coating to reduce leakage.

Heating, Domestic Hot Water, and Zamboni Hot Water Systems	The domestic hot water heating consists of one John Wood oil-fired tank. Common areas at the front of the arena are heated with two oil furnaces and duct work to heat the areas. An electric heater is used at the back maintenance and Zamboni area in the wintertime. The Zamboni Hot Water heating consists of an oil-fired hot water tank that is pumped into an insulated holding tank. The holding tank is circulated by a Grundfos pump and the insulated water heater is kept hot by electrical resistance heating.
Cooling System	The building doesn't have central cooling system.
Dehumidification System	The building contains two dehumidifiers at opposite corners of the rink.
Ventilation System	The building is equipped with two make-up air unit (MUA) with in-direct fuel oil-fired heaters to supply conditioned (heating only) fresh air in heating season to the common areas in the foyer and the auditorium.
Lighting System	Interior Lighting: Most common area lighting on the 1st level including the foyer, front entrance, canteen, changerooms, bathrooms, front entrance, hallways, laundry and stair ways has been converted to electronic ballasts and LED tubes. It is estimated about 75 percent of lights have been switched to LED. However, some areas are still using fluorescent bulbs so there is still an opportunity for savings by implementing a complete conversion. Exterior Lighting: The lighting on the exterior consists of two mounted 50 w LED fixtures on front face of building, one High-Pressure Sodium (HPS) fixtures on a hydro pole, one HPS fixture on the exterior wall, three wall-mounted LED fixtures. These exterior lights provide lighting to the building and parking area.
Building Automation System (BAS)	There is currently no BAS system in operation.

1.3 Preliminary End Use Analysis

1.3.1 Billing Data Review

Consumption data for 2016 to 2018 was reviewed for Propane, Fuel oil and Electricity. Water bills and consumption for the last year was reviewed. The following section describes the various charges and consumption related data and discusses trends in the data and opportunities for recommending Energy Efficiency Measures (EEM).

1.3.1.1 Electricity Rates**Table 7: North Dufferin Community Centre Electricity Charges**

Charge	Supplier	Current Cost	Forecast Cost c/kwh
Base Electricity Price	Hydro One	2.430	3.013
Global Adjustment	OEB	9.318	11.555
Delivery	Hydro One	0.127	0.157
Regulatory Charges	OEB	0.004	0.005
Debt Retirement Charge	OEB	0.007	0.008
H.S.T.		13%	13%
Total Cost		13.43	16.65

Electricity rates vary with the Ontario electricity market. Mulmur is currently purchasing energy at an average cost of 2.43 c/kWh. The global adjustment rate varies every month and is difficult to predict a rate going forward. Due to Ontario's Fair Hydro Plan the global adjustment was been reduced. This credit is assumed to continue for the foreseeable future. The global adjustment charge over the past year is currently \$9.32 c/kWh; however, electricity rates are expected to increase. Assuming an average rate of increase of 4 percent the average increase over the next 10 years is 24 percent. Therefore, multiplying the current cost by 24 percent yields a forecasted cost of \$16.65 kwh.

Table 8: Hydro One Charges General Service Greater than 50 kW

	Rates	Unit of Measure	Rate as of January 1, 2019
Electricity	RPP – Tiered Rate, Spot Market or Weighted Average Spot Market	Per kWh*	
Delivery	Fixed Monthly Charge	Per Month	\$89.48
	Distribution Volume Charge	Per kW	\$16.0236
	Transmission Network Charge	Per kW	\$1.6048
	Transmission Connection Charge	Per kW	\$1.0743
	Line Loss Adjustment Factor		\$1.061
Regulatory	Wholesale Market Service Charge	Per kWh*	\$0.0030
	Rural Rate Protection Charge	Per kWh*	\$0.0005
	SSS Administration Charge	Per Month	\$0.25

CEP Volume 3: Energy Audit Report
December 2019

1.3.2 Fuel Oil Rates

Table 9: Fuel Oil Charges

Description	Charge
Average Cost for 2016	63.1c/L
Average Cost for 2017	76.1c/L
Average Cost for 2018	88.0c/L

Current Cost of Fuel Oil 83 c/L.

1.3.3 Propane Rates

Current Cost of Propane .49 c/L.

1.3.4 Water Rates

There is no municipal water at North Dufferin Community Centre. Groundwater is pumped from a well onsite.


1.3.5 Monthly Energy Usage

Monthly energy data was received from Mulmur. Below in Table 11 Hydro and Fuel consumption tables are shown. The total for Hydro is averaging approximately 330,000 kWh per year for 2016 to 2018. Total fuel oil usage averages approximately 12,000 L per year for 2016 to 2018. Total Propane usage averages approximately 6400 L per year.

Table 10: North Dufferin Community Centre Electricity Consumption Summary


North Dufferin Community Centre - Utilities Summary													
Year Over Year Hydro consumption in kWh:													
	July	August	September	October	November	December	January	February	March	April	May	June	Total
2016	9,878	8,145	12,122	55,976	43,820	43,560	53,703	44,870	44,597	29,003	16,762	10,167	372,603
2017	2,228	2,090	7,924	49,805	43,825	44,600	47,558	46,909	42,451	24,154	5,398	1,544	318,486
2018	3,760	1,320	20,381	52,373	43,140	46,680	37,129	33,126	37,440	20,121	1,507	1,940	298,917

Figure 1: North Dufferin Community Centre 2015-2018 Hydro Usage




Electricity usage goes up significantly in the winter months as the ice rink is in full operation. The highest usage being in October when ice is being made, and high through November to March when the ice is being used extensively. The total kWh usage in 2018 was approximately 300,00 kWh which is less than 2016, 2017 and the average of the 3 years. This reduction is assumed to be due in large part to the replacement of lighting within the arena to LED. No other large changes in use have been identified during the audit. The average kWh usage per month in 2018 was approximately 24,910 kWh.

Figure 2: North Dufferin Community Centre 2016-2018 Fuel Oil Usage




The amount of fuel oil varies year by year and month by month. Fuel oil consumption increases in the winter as fuel oil provides the main source of heat. The average amount of fuel per year is around 12,000 L.

Figure 3: North Dufferin Community Centre 2016 to 2018 Estimated Propane Usage



The amount of propane varies year by year and month by month. Propane is used to operate the Zamboni as well as the cooking equipment in the canteen. The average amount of propane used per year is around 6,400 L.

Figure 4: North Dufferin Community Centre 2016-2018 Estimated Fuel Usage



CEP Volume 3: Energy Audit Report
December 2019

The amount of propane and fuel oil varies year by year and month by month, however the total fuel use over 2016-2018 has remained fairly constant. The total L of fuel usage has ranged from approximately 17,500 in 2016 to 19,400 L in 2018 for an average amount of approximately 18,500 L.

1.3.6 Fuel Oil Adjusted Baseline for Heating

The average fuel oil consumption from 2016 to 2018 is 12,065 L. Using 2016 to 2018 data, the heating load can be correlated to Heating Degree Data (HDD) to determine the adjusted baseline for an average year. Taking the total fuel and dividing by the heating degree days (HDD) per year gives an average m³ fuel oil used per HDD as shown in Table 12

Table 11: Average m³ Consumption Per HDD

Year	Total Fuel Oil (L)	HDD	L/HDD
2016	12841	3,588	3.58
2017	9234	3,734	2.47
2018	14121	4,018	3.51

The average L/HDD can be multiplied by the average HDD per year, which for Mulmur in the last ten (10) years is approximately 3,855². This results in 12,293L which is the fuel oil consumption that would be used in an average year. This can be used as the fuel oil consumption baseline.

Table 12: Adjusted Fuel oil Use Baseline

HDD Average	L/HDD	Adjusted Average Fuel Oil (L)
3,855	3.2	12,293

1.3.7 Electricity Adjusted Baseline

The average kWh usage for North Dufferin Community Centre over the last three years is 330,002 kWh per year. However, the 2018 performance is likely more indicative of future performance. Occupancy is assumed to have remained constant for the time-period of analysis. Approximately 50 percent of common areas have been retrofitted to LED; as well as the arena area significantly reducing electricity and total energy consumption. The 2018 usage was 298,917 kWh therefore an approximation of the 2018 electricity usage of 300,000 kWh will be carried forward as the electricity baseline usage.

² Environment and Climate Change Canada "Collingwood Historical Heating Degree Days". November 22, 2017. Accessed November 22, 2017. <https://sarnia.weatherstats.ca/metrics/hdd.html>

1.3.8 Breakdown of Energy Charges and Consumption

Figure 5: North Dufferin Community Centre 2018 Total Energy Usage (kWh)





Figure 6: North Dufferin Community Centre Total Energy Cost 2016 to 2017




1.3.9 End Use Breakdown

An end use breakdown for all the different uses within the building was estimated and calibrated to the actual usage from the energy bills.

Table 13: Combined kWh Breakdown for North Dufferin Community Centre


End Use	Input Energy Units		Combined Energy Use	
	Electric	Fuel		
	kWh	Oil/Propane kWh	kWh	Percent
Appliances + Canteen	24,000	5,000	29,000	6%
Space Heating	15,000	49,315	64,315	14%
Cooling	0		-	0%
Lighting - Exterior	2,500		2,500	1%
Lighting - Interior	12,000		12,000	3%
Pumps + Ventilation + Dehumidification	20,000		20,000	4%
Zamboni Hot Water	3,500		3,500	1%
Domestic Hot Water	1,000		1,000	0%
Ice Plant	210,000	55,000	265,000	56%
Well & Septic Pump	2,000	22,685	24,685	5%
Zamboni Propane		40,312	40,312	9%
Plug Loads	10,000		10,000	2%
Total Estimated	300,000	172,312	472,312	100%
Historical Billing	300,000	172,000	472,000	
Percent of Actual	100.0%	100.2%	100.1%	
Total per ft²	11.5	6.6	18.0	

Figure 7: Total kWh by End Use for North Dufferin Community Centre

1.3.10 Energy Benchmark

An energy benchmark is important to compare building usage to similar buildings as well as comparing current usage to past usage. It is an effective way to identify poorly performing buildings, and to establish a baseline for measuring improvement in energy consumptions for all buildings³. A rating has been determined from energy star portfolio manager for North Dufferin Community Centre from details about the buildings, utility bills, and regional and climate data. In Appendix A the score of 86 is shown. This means that the arena is operating in the 86th percentile, compared to other buildings, which means it is operating well. Furthermore, some local data was used to benchmark the building against other local arenas. In Figure 8 summary table is below and a copy of the analysis is in Appendix B.

³ Natural Resources Canada "Energy benchmarking: the basics". Government of Canada June 09, 2017, Accessed November 10, 2017. <http://www.nrcan.gc.ca/energy/efficiency/buildings/energy-benchmarking/building/18260#details-panel20>

Figure 8: Total ekWh/ft² by End Use for North Dufferin Community Centre

Per Survey of Energy Consumption of Arenas 2014⁴, the Energy Use Index (EUI) Benchmark for similar buildings is 29.9 ekWh/ft². The EUI for North Dufferin Community Centre in 2016 was 21.3 ekWh/ft². Benchmarking analysis indicates that North Dufferin Community Centre is operating better than average and is in the first quartile relative to the energy efficiency benchmark window. Although, it is operating at a higher energy intensity than Hillsburgh Arena⁵. Currently the Community Centre is operating well from an energy efficiency perspective, however there are still opportunities for energy efficiency, and renewable generation within the arena.

2.0 Building Envelope

2.1 Exterior Cladding System

The building's exterior walls generally consist of a concrete block back-up wall with insulation and metal siding outboard of it. Based on the depth of the window flashing we estimate that insulation is between 100 to 125 mm thick, however destructive openings to confirm the actual thickness were outside the scope of our review.

The windows generally consist of two, single pane operable (horizontal sliding) and fixed windows. The windows appear to be approximately 30 years old and are nearing the end of their service life. The windows separating the Community Centre to the ice rink are single pane in metal frames.

⁴ <https://www.nrcan.gc.ca/energy-efficiency/energy-star-benchmarking-commercial-and-institutional-buildings/energy-benchmarking-technical-information/building-energy-use-surveys/19454>

⁵ Data from Bumside Energy Conservation Measures for the Hillsburgh and Erin Community Centre Arenas

Figure 9: North Dufferin Community Centre Exterior Wall Assembly



Figure 10: Common Area Window



Figure 11: Common Area Single Pane Window to Unheated Arena

2.2 Roofing

The Community Centre has both a flat roof, located over the community centre, and a sloped roof supported by wood trusses located above the ice rink. The flat roof has an unheated attic space below it that is insulated with 90 mm [3.5 in.] fibreglass batt insulation in ceiling and wall cavities with wood frame construction. The ice rink roof is uninsulated, the Urethane Foam/Gascosil coating is for leak protection rather than thermal insulation.




Figure 12: Community Centre Attic Space Insulation



Figure 12: Sloped Roof Over Rink



3.0 Building Systems

3.1 Lighting Systems

3.1.1 Interior Lighting

Most common area lighting on the first level including the foyer, front entrance, canteen, changerooms, bathrooms front entrance, hallways, laundry and stair ways has been converted to electronic ballasts and LED tubes. It is estimated about 75 percent of lights have been switched to LED. These retrofits have been completed within the last three years. However, some units are still using incandescent, and fluorescent bulbs so there is still a significant opportunity for savings by implementing a complete conversion. The lighting in the rink has been completely converted to LED, and the lighting upstairs in the auditorium is generally still fluorescent. There is no opportunity for improvement in the rink, and in the auditorium, there is limited opportunity as the occupancy of the space is only a few hours per week, not allowing for a benefit to outlay capital.

Figure 13: Changeroom Lighting Example




Figure 14: Rink Lighting



Figure 15: Auditorium Lighting



3.1.2 Exterior Lighting

The lighting on the exterior consists of two mounted 50 W LED fixtures on front face of building, one High-Pressure Sodium (HPS) fixtures on a hydro pole, one HPS fixture on the exterior wall, three wall-mounted LED fixtures.

Figure 16: HPS Parking Lot Lights



Figure 17: LED Parking Lot Lights



3.2 Mechanical Systems

3.2.1 HVAC System

3.2.1.1 Heating

Common areas at the front of the arena are heated with two oil furnaces and duct work to heat the areas. An electric heater is used at the back maintenance and Zamboni area in the wintertime.

Figure 18: Common Area Oil Furnaces**Figure 19: Typical in Suite Electric Baseboard Heater**

3.2.1.2 Ventilation

The building is not equipped with Ventilation units. Only the fans within the oil furnaces deliver air to the heated common areas.

3.2.1.3 Cooling

There is large fan that is used rarely for ventilation in the rink area only required for fumes that are present from maintenance activities.

3.2.2 Plumbing and Fixtures

Plumbing is mostly original to the building. The four changerooms each generally have one toilet, one sink, and one shower. There is also a men's washroom, a women's washroom, a referee's room and a girls changeroom. Upstairs there is a women's and a men's washroom. Upgrades to low flow showerheads and low flow kitchen and bathroom sinks has not taken place.

Figure 20: Typical Changeroom




Figure 21: Typical Sink Fixtures



3.2.3 Domestic Hot Water



The Domestic Hot Water heating consists of one John Wood oil-fired tank.

Figure 22: Domestic Hot Water Tank



3.2.4 Zamboni Hot Water

The Zamboni Hot Water heating consists of an oil-fired hot water tank that is pumped into an insulated holding tank. The holding tank is circulated by a Grundfos pump and the insulated water heater is kept hot by electrical resistance heating. The current hot water system is old and showing signs of wear.

Figure 23: Zamboni Hot Water Storage Tank**Figure 24: Zamboni Hot Water Heating Tank and Electrical Heating Wall Mount**

3.2.5 Ice Refrigeration System

The ice refrigeration system is ammonia based. The primary refrigeration side consists of two compressors, one cooling tower/condenser, one chiller, circulation pumps and piping. The secondary refrigeration side consists of circulation pumps and the arena slab piping. The refrigeration system was replaced in 2009. Typical ammonia-based refrigeration systems last for 30 years⁶. Therefore, only 1/3 into its useable life it was not analyzed for replacement or major retrofit.

⁶ https://www.nrcan.gc.ca/energy/efficiency/buildings/research/publications/16002#_Toc364163192

Figure 25: Ice Plant Compressors**Figure 26: Ice Plant**

4.0 Occupancy Schedule

Below is the occupancy schedule for North Dufferin Community Centre. Typically, the Arena is used in the winter from September to April and follows this occupancy schedule below.

Table 14: Occupancy Schedule

Zone Name / Description	Winter Operation of North Dufferin Community Centre Occupancy (Number of People) Per Hour							
	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Holiday
Days								
0:00 - 1:00								
1:00 - 2:00								
2:00 - 3:00								
3:00 - 4:00								
4:00 - 5:00								
5:00 - 6:00								
6:00 - 7:00							2	2
7:00 - 8:00						2	100	100
8:00 - 9:00						100	100	100
9:00 - 10:00						100	100	100
10:00 - 11:00						100	100	100
11:00 - 12:00						100	100	100
12:00-13:00						100	100	100
13:00-14:00						100	100	100
14:00-15:00						100	100	100
15:00-16:00						100	100	100
16:00-17:00	2	2	2	2	2	100	100	100
17:00-18:00	30	30	30	30	100	125	100	100
18:00-19:00	30	30	30	30	100	125	100	100
19:00-20:00	30	30	30	30	100	125	100	100
20:00-21:00	30	30	30	30	100	125	100	100
21:00-22:00	30	30	30	30	100	125	2	2
22:00-23:00	30	30	30	30	100	125		
23:00-24:00	2	2	2	2	2	2		
Total Showers Estimated	30	12	15	30	30	20	100	
Note: Plus, every other week 50 people for six hours in auditorium.								

5.0 Energy Efficiency Measures

5.1 No-Cost/Low-Cost Measures

Note: Savings calculations reflect savings from individual measures only and do not assume that other recommendations have been implemented. Calculations and assumptions used are solely based on the existing equipment and usage schedules.

5.1.1 EEM 1 – Interior Lighting Analysis – LED Lighting

Budgetary Cost	Annual Utility Savings		MTCDE	Total Savings/Year	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
1,105	1,300	-	-	216.45	390	5.11	6.91

Existing Condition: Inefficient Lighting

Some common area lighting including the foyer, front entrance, changerooms, laundry and stair ways has been converted to electronic ballasts and LED tubes. These retrofits have been completed within the last three years. However, some lighting is still fluorescent bulbs so there is still an opportunity for savings by implementing a complete conversion.

Recommendations

Replace existing fluorescent lighting with LED lighting. The replacement LEDs also have a rated lifespan of 45,000 hours versus approximately 20,000 hours for the existing fluorescent lamps, which will help reduce maintenance costs associated with replacing burn outs.

Implementation

Estimate includes the cost for supply of lamps and fixtures and installation. In order to estimate the electric savings assumptions for daily usage were made based on space type. Save on Energy offers incentives for each of these lamps installed and these incentives are included in the price calculations. Further information regarding assumptions and the calculations made for this EEM can be found in Appendix B.

5.1.2 EEM 2 – Exterior Parking Lot Lights - LED Lighting

Budgetary Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
890	964	-		160	100	5.6	6.2

Existing Condition: Inefficient Lighting

Based on a visual inspection from the ground, the lighting on the exterior consists of two (2) mounted 30 W LED fixtures on front face of building, one High-Pressure Sodium (HPS) fixtures on a hydro pole, one HPS fixture on the exterior wall, and three wall-mounted LED fixtures.

Recommendations

Replace existing lighting with LED lighting when the lamps burn out. There is a significant cost for a lift truck rental (\$500 to 600/day) to reach the height of the lights. Therefore, when the lamps need to be replaced it makes sense to replace the remaining halogen lamps with LED. The replacement LEDs also have a rated lifespan of 45,000 hours versus 2,000 hours for the existing halogen lamps, which will help reduce maintenance costs associated with replacing burn outs. Furthermore, a comment was received at a Public Information Consultation that recommended the lights to be turned off at night. If turning off the lights was acceptable from a safety perspective, there would be additional savings from the reduced electricity during night time hours.

5.1.3 EEM 3 – Programmable Thermostats

Gross Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
400		1,000	2.5	750	-	0.5	0.5

Existing Condition

Currently the heated portion of the arena is heated at 20 degrees during the heating season from mid-October to mid-May.

Recommendations

Replace thermostats with programmable thermostats which would reduce costs by about 15 percent if the heat was turned down from 20 degrees to 16 degrees when unoccupied. Calculations are provided in Appendix B. There would be also be electricity savings from a reduced fan operating schedule.

The auditorium of the arena is mostly unoccupied, and the arena's occupied hours are about 70 hours per week. By reducing the temperature in unoccupied spaces and at night significant savings in heating fuel can be made at a low cost.

5.2 Capital Investment Measures**5.2.1 EEM 4 – Building Envelope Analysis – Roof Insulation**

Gross Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
8,500	0	2,144	6	1,780	0	4.8	4.8

Existing Condition: Low R Value Roof Insulation.

Currently this is just one 3.5 in. layer of insulation in the attic space below the flat roof area with an approximate R-value of R-12.

Recommendations

Blow-in additional insulation into the attic space to bring up to OBC 2012 requirements of R-50.

5.2.2 EEM 5 – Building Envelop Analysis – New Doors

Gross Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
1,500	0	136	0.4	102.8	0	14.6	14.6

Existing Condition: Interior doors from unheated arena to heated foyer have significant air leakage, as well as one exterior door on second floor Auditorium.

Recommendations

Replace doors at the end of their useful life with new doors to limit air leakage. The payback is not appealing enough to replace doors before their useful life is over.

5.2.3 EEM 6 – Building Envelop Analysis – New Windows

Gross Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
38,000	0	1,075	2.9	806	0	47.1	47.1

Existing Condition: Existing windows between the heated area of the arena and the unheated rink part of the arena are single pane.

Recommendations

Install new windows assumed to be equivalent to thermally unbroken aluminum frame with fixed, double glazing, low- $\epsilon=0.2$, 12.7 mm argon space, fire rated coating.

5.2.4 EEM 7 – Water Conservation – Low Flow Fixtures

Gross Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
1,800	100	571	1.5	490	0	3.7	3.7

Existing Condition: Inefficient Plumbing Fixtures.

Our visual inspection revealed the following:

- The showerheads in the units were rated 2.5 GPM;
- The washroom faucet aerators were rated 2.2 GPM; and
- Kitchen aerators were typically rated at 2.2 GPM.

Recommendations

In order to reduce the water consumption and the energy used for DHW, we recommend the following measures:

- Replace all showerheads as 1.6 GPM (or less) showerheads;
- Replace the existing washroom faucet aerators rated with low-flow aerators rated for 0.5 GPM; and
- Replace the existing kitchen faucet aerators rated with low-flow aerators rated for 1.0 GPM.

Note: The cost of pumping and disinfecting water does not allow for significant cost savings to change to low flow toilets.

5.2.5 EEM 8 – Upgrade Furnace to Higher Efficiency Furnace

Gross Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
7,000	-	125	0.3	104	0	67.5	67.5

Existing Condition: Minimal Control of Common Area Heating

The building is equipped with two forced air oil furnaces. The furnaces come with one 1/2 HP supply fan. The units provide approximately 1,000 CFM of ventilation each. The supply fan is manually operating on at full speed. The current efficiency of both units is assumed to be 84.6 percent. Between the two furnaces approximately 5,000 L of oil is used.

Recommendations

When the life of the furnace is over replacement of either a new 90 percent efficiency oil furnace or a 95 percent propane furnace should be installed, or an air source or ground source heat pump. A heat pump could offer cost savings as well as air conditioning in the summer for arena activities. Assuming one furnace uses approximately 2,500 L of oil, an increase in 5 percent efficiency saves approximately 125 L. It is not recommended to replace the furnace until useful life is over.


5.2.6 EEM 9 – Drain Water Heat Recovery

Budgetary Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	NG					
\$	kWh	m ³	Metric Tons	\$	\$	Years	Years
4,500	0	367	1.0	304	0	14.8	14.8

Existing Condition: Heat Recovery Opportunity

Drain-water heat exchangers can recover heat from the hot water used in showers, bathtubs, sinks, dishwashers, and clothes washers. They generally have the ability to store recovered heat for later use.

Figure 27: Drain Water Heat Recovery System



Recommendation

Implementing a drain water heat recover system is not recommended as the payback is close to 15 years.

5.2.7 EEM 10 – New Zamboni Hot Water System

Gross Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
8,000	2,600	682	1.8	1,165	0	6.9	6.9

Existing Condition

The Zamboni Hot Water heating consists of an oil-fired hot water tank that is pumped into an insulated holding tank. The holding tank is circulated by a Grundfos pump and the insulated water heater is kept hot by electrical resistance heating. The existing hot water storage tank is large and has inefficient insulation.

Recommendations

Remove the existing storage tank with electrical resistance heating and circulation pump with two 75-gal propane tanks, this will reduce the Arena's electricity bill. New propane heaters are assumed to have greater efficiency than the existing oil furnace, furthermore, propane delivery prices are more economical for the Arena than oil.

5.2.8 EEM 11 – Desuperheater - Heat Recovery

Budgetary Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	m ³	Metric Tons	\$	\$	Years	Years
42,500		4,470	11.9	3,710		11.5	11.5

Existing Condition

Currently Zamboni hot water is pumped to the oil heater for heating then into the holding tank circulated and heated by electricity. Compressors within the compressor room give off waste heat that is vented to the outside wasting that energy.

Recommendations

A desuperheater can take the waste heat from the compressors and heat the incoming groundwater from the well. This hot water can be used for the Zamboni hot water rather than heating it with propane. The desuperheater is assumed to be functional to pre-heat the water to 120 degrees Fahrenheit (F) approximately 80 percent of the time. Unfortunately, the capital cost is quite high, and the payback period falls outside of 10 years. For that reason, this measure is not recommended at this time. With an incentive from the government this could make this project viable.

5.3 Distributed Generation/Renewable Energy Measures

5.3.1 EEM 12 – Rooftop Solar with Net Metering Connections

Budgetary Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	NG					
\$	kWh	m ³	Metric Tons	\$	\$	Years	Years
114,375	228,000	-	-	12,435	-	7.0	9.3

Existing Condition: Renewable Generation

The roof of the building has been considered for a solar PV installation. Applying safety setbacks from roof edges and impacts of shading, the panels are modeled to cover most of the south facing roof area. This space accommodates a total of approximately 190 kW.

CEP Volume 3: Energy Audit Report
December 2019

Net metering allows you to send electricity generated from Renewable Energy Technologies (RETs) to the distribution system for a credit towards your electricity costs. Excess generation credits can be carried forward for a consecutive 12-month period to offset future electricity costs. Net-metered customers can now pair energy storage with renewable energy systems.

Recommendations

With a total nameplate capacity of approximately 190 kW, and consideration of system losses, the system is modeled to produce approximately 233 MWh of electricity per year. This will offset approximately 77 percent of the Community Centre's electricity use. With a simple payback on the equity of 9.3 years, Mulmur should consider developing this EEM.

Mulmur should keep an eye on the Climate Action Incentive Fund (CAIF) program outlined in the section below. This fund is scheduled to be announced in late 2019 or early 2020. The current program is for private businesses only. It is the writer's opinion that if a program were to be announced for municipalities as scheduled, that fund would likely be similar by providing 25 percent of the capital costs in a rebate. This would significantly improve the economics for the Community Centre solar project.

Investigate a loan from Infrastructure Ontario. Infrastructure Ontario states they have flexible terms designed to match the life of the asset. Receiving a loan for 30 years to match the life of the asset at a low interest rate would maximize the return on investment (ROI) of the system.

The Loan Program provides various benefits to public sector borrowers:

- Affordable interest rates;
- Flexible terms of up to 30 years, designed to match the life of the asset;
- Access to dedicated and experienced staff throughout the loan process;
- Instant access to capital markets with no extra fees or commissions; and
- No need to refinance over the life of the loan.

Implementation

The next step would be a structural and roof assessment of the arena, connection feasibility assessment with Hydro One, and create a bid package for installation pricing.

A ground mount solar project could also be considered, if Mulmur wanted to dedicate some ground space to solar.

6.0 Climate Action Initiative Fund

The Climate Action Incentive Fund (CAIF) SME Project stream provides support to small- and medium-sized enterprises (SMEs) for retrofit projects in sectors such as building, transportation, industry, waste, agriculture, and more. Up to 25 percent of the project's total eligible costs are applicable. Project minimum funding is \$20,000.00 and maximum is \$250,000.00. Currently they are accepting applications.

Eligible project category for building retrofits are below:

Building Retrofits

- Enhancements to building envelope (with direct energy savings), including energy efficient windows/doors/skylights, increased insulation, weatherproofing, and glazing;
- Energy efficient lighting system;
- Heating, ventilation, and air conditioning (HVAC) equipment/systems/controls;
- Water heating retrofits, including high efficiency condensing water heating;
- High-efficiency motors and controls;
- Energy management controls, including building automation systems; and
- Fuel switching to lower emitting energy sources in existing buildings.

Currently this funding is only available for small to medium sized business. However, Funding for municipalities, universities/colleges and hospitals under the Municipalities, Universities, Schools and Hospitals (MUSH) Retrofit stream will be announced later in 2019 to 2020. Additional information about funding for energy efficiency and retrofit projects will be posted on their website as it becomes available.

Presumably, under the MUSH program the government will announce a similar level of funding for municipalities as private businesses. If that is true and an incentive fund of 25 percent becomes available some of the measures for Mulmur would become much more appealing. To illustrate this point, a new table of measures has been outlined below with updated payback periods.

6.1 EEMs Recommended with CAIF

If the CAIF was applied for and received for these energy efficiency projects the updated economics are presented in the below table. Including the potential 25 percent savings from the CAIF fund, eight Energy Efficiency Measures (EEMs) are recommended. The annualized savings of all recommendations totals more than \$20,706.00 (at projected energy prices). If fully implemented, the average weighted payback period from annual energy savings for these EEMs is estimated to be 6.4 years. Details are outlined in the table below.

Table 15: North Dufferin Community Centre Energy Efficiency Recommendations with CAIF Funding

EEM No.	Energy Efficiency Measure	Measure Type	Approx. Annual Savings	CAIF Incentive	Estimated Net Costs	Simple Payback Years
1	EEM 1 - LED Lighting – Interior Lights	Upgrade Building Systems	\$216.00	\$374.00	\$731.00	3.4
2	EEM 2 - LED Lighting – Exterior Parking Lot Lights	Upgrade Building Systems	\$160.00	\$223.00	\$568.00	3.5
3	EEM 3 - Install Programmable Thermostats	Upgrade Building Systems	\$750.00	\$100.00	\$300.00	0.4
4	EEM 4 – Building Envelope Analysis – Roof Insulation	Upgrade Building Envelope	\$1,780.00	\$2,125.00	\$6,375.00	3.6
7	EEM 7 – Water Conservation -Low Flow Fixtures	Upgrade Building Systems	\$490.00	\$450.00	\$1,350.00	2.8
10	EEM 10 – New Zamboni Hot Water System	Upgrade Building Systems	\$1,165.00	\$2,000.00	\$6,000.00	5.2
11	EEM11 – Desuperheater	Upgrade Building Systems	\$3,710.00	\$10,625.00	\$31,875.00	8.6
12	EEM12 – Rooftop Solar	Renewable Technology	\$12,435.00	\$28,594.00	\$85,781.00	6.9
Totals			\$20,706.00	\$44,491.00	\$132,980.00	4.3

7.0 Summary

Twelve separate Energy Efficiency Measures (EEMs) were identified with implementation costs and annual energy savings estimates. Seven Energy Efficiency Measures (EEMs) recommendations were identified with implementation costs and annual energy savings estimates. The annualized savings of all recommendations totals \$16,996.00 (at projected energy prices). If fully implemented, the average weighted payback period from annual energy savings for these EEMs is estimated to be 7.9 years. Details are outlined in the tables below.

Table 16: North Dufferin Community Centre Energy Efficiency Recommendations

EEM No.	Energy Efficiency Measure	Measure Type	Approx. Annual Savings	Estimated Net Costs	Simple Payback Years
1	EEM 1 - LED Lighting – Interior Lights	Upgrade Building Systems	\$216.00	\$1,105.00	5.1
2	EEM 2 - LED Lighting – Exterior Parking Lot Lights	Upgrade Building Systems	\$160.00	\$790.00	4.9
3	EEM 3 - Install Programmable Thermostats	Upgrade Building Systems	\$750.00	\$400.00	0.5
4	EEM 4 – Building Envelope Analysis – Roof Insulation	Upgrade Building Envelope	\$1,780.00	\$8,500.00	4.8
7	EEM 7 – Water Conservation -Low Flow Fixtures	Upgrade Building Systems	\$490.00	\$1,800.00	3.7
10	EEM 10 New Zamboni Hot Water System	Upgrade Building Systems	\$1,165.00	\$8,000.00	6.9
12	EEM12 Rooftop Solar	Renewable Technology	\$12,435.00	\$114,375.00	9.2
Totals			\$16,996.00	\$134,970.00	5.0

Note: Simple payback is an average of all projects.

Table 17: North Dufferin Community Centre EEMs not Recommended

EEM No.	Energy Efficiency Measure	Measure Type	Approx. Annual Savings	Net Costs	Simple Payback Years
5	EEM 5 – Building Envelope Analysis – New Doors	Upgrade Building Envelope	\$103.00	\$1,500.00	14.6
6	EEM 6 – Building Envelope Analysis – New Windows	Upgrade Building Envelope	\$806.00	\$38,000.00	47.1
8	EEM 8 – Upgrade Furnace to Higher Efficiency	Upgrade Building Systems	\$104.00	\$7,000.00	67.5
9	EEM 9 - Drain Water Heat Recovery	Upgrade Building Systems	\$304.00	\$4,500.00	14.8
11	EEM11 Desuperheater	Upgrade Building Systems	\$3,710.00	\$42,500.00	11.5
Totals			\$5,027.00	\$93,500.00	31.1



BURNSIDE

[THE DIFFERENCE IS OUR PEOPLE]



Appendix A

Data

**Honeywood Arena Ice Plant 2000 5377 1313
2016 - 2018**

Year over year Hydro consumption in kWh:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
2006													0
2007													0
2008													0
2009													0
2010													0
2011													0
2012													0
2013													0
2014													0
2016	8,658	7,385	9,422	52,456	40,000	38,960	51,183	42,270	40,997	26,483	16,042	9,167	343,023
2017	1,528	1,273	6,111	46,599	40,000	40,000	43,798	43,289	38,451	22,154	4,838	764	288,805
2018	2,292	509	18,843	48,127	38,451	42,016	33,358	29,029	33,358	18,589	764	764	266,100

**Honeywood Arena Building 2000 6638 4343
2016 - 2018**

Year over year Hydro consumption in kWh:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
2006													0
2007													0
2008													0
2009													0
2010													0
2011													0
2012													0
2013													0
2014													0
2016	1,220	760	2,700	3,520	3,820	4,600	2,520	2,600	3,600	2,520	720	1,000	29,580
2017	700	817	1,813	3,206	3,825	4,600	3,760	3,620	4,000	2,000	560	780	29,681
2018	1,468	811	1,538	4,246	4,689	4,664	3,771	4,097	4,082	1,532	743	1,176	32,817

**Honeywood Arena Building + Ice Plant 2000 6638 4343 + 2000 5377 1313
2016 - 2018**

Year over year Hydro consumption in kWh:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
2006													0
2007													0
2008													0
2009													0
2010													0
2011													0
2012													0
2013													0
2014													0
2016	9,878	8,145	12,122	55,976	43,820	43,560	53,703	44,870	44,597	29,003	16,762	10,167	372,603
2017	2,228	2,090	7,924	49,805	43,825	44,600	47,558	46,909	42,451	24,154	5,398	1,544	318,486
2018	3,760	1,320	20,381	52,373	43,140	46,680	37,129	33,126	37,440	20,121	1,507	1,940	298,917

Year over year Furnace Oil consumption In Litres:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total	kWh/L	Total kWh
2006													0	10.557	0
2007													0	10.557	0
2008													0	10.557	0
2009													0	10.557	0
2010													0	10.557	0
2011													0	10.557	0
2012													0	10.557	0
2013													0	10.557	0
2014													0	10.557	0
2015/2016												2016	12,841	10.557	135,562
2016/2017												2017	9,234	10.557	97,483
2017/2018												2018	14,121	10.557	149,075

Year over year Propane consumption Estimate In Litres:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total	kWh/L	Total kWh
2006													0	7.08	0
2007													0	7.08	0
2008													0	7.08	0
2009													0	7.08	0
2010													0	7.08	0
2011													0	7.08	0
2012													0	7.08	0
2013													0	7.08	0
2014													0	7.08	0
2015/2016												2016	4,695	7.08	33,241
2016/2017												2017	9,461	7.08	66,984
2017/2018												2018	5,259	7.08	37,234

Year over year Total Fuel consumption Estimate In Litres:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total	kWh/L	Total kWh
2006													0		0
2007													0		0
2008													0		0
2009													0		0
2010													0		0
2011													0		0
2012													0		0
2013													0		0
2014													0		0
2015/2016												2016	17,536	9.63	168,803
2016/2017												2017	18,695	8.80	164,467
2017/2018												2018	19,380	9.61	186,309



	Input	Output
Propane	1 L Propane	7.08 kWh
Fuel Oil	1 L Fuel Oil	10.57 kWh

Total Energy Use

	2016	2017	2018
Electricity	372,603	318,486	298,917
Fuel Oil	135,562	97,483	149,075
Propane	33,241	66,984	37,234
Total	541,406	482,953	485,226

2018 Energy Cost

Electricity	\$40,145
Fuel Oil	\$12,437
Propane	\$2,629
Total	\$52,582



NDCC Oil Usage for 2016, 2017, 2018

Date	Litres	Price	Total
12/28/2016	475.2	0.718	341.19
12/28/2016	5.6	0.718	4.02
12/21/2016	544.6	0.709	386.12
12/21/2016	11	0.79	8.69
12/14/2016	25.3	0.701	17.74
12/14/2016	590.1	0.701	413.66
12/7/2016	58.5	0.713	41.71
12/7/2016	1197.7	0.713	853.96
11/25/2016	1500.3	0.689	1,033.71
11/25/2016	361.8	0.689	249.28
9/21/2016	211.5	0.571	120.77
9/21/2016	14.7	0.571	8.39
5/2/2016	1442.6	0.639	921.82
5/2/2016	157.1	0.639	100.39
3/31/2016	668.5	0.689	460.60
3/31/2016	34.1	0.689	23.49
3/18/2016	438.6	0.585	256.58
3/18/2016	93.8	0.585	54.87
3/7/2016	146.4	0.576	84.33
3/7/2016	894.6	0.576	515.29
2/3/2016	681.7	0.565	385.16
2/18/2016	346.3	0.568	196.70
2/18/2016	1024.5	0.568	581.92
2/24/2016	53.5	0.556	29.75
2/24/2016	342.2	0.556	190.26
1/13/2016	13.8	0.572	7.89
1/13/2016	880.4	0.572	503.59
1/22/2016	595	0.54	321.30
1/22/2016	32.5	0.54	17.55
12,841.90	0.631	8,130.73	

Furnace Maintenance	
10/3/2016	470.00

11/22/2017	750.9	0.87	653.28
11/22/2017	19.5	0.87	16.97
11/6/2017	466.6	0.804	375.15
11/6/2017	30.5	0.804	24.52
10/4/2017	42.7	0.767	32.75
10/4/2017	1245.8	0.767	955.53
10/25/2017	56.5	0.776	43.84
10/25/2017	464.8	0.776	360.68

Furnace Maintenance	
11/1/2017	367.25
10/10/2017	470.00
837.25	

4/6/2017	396.9	0.727	288.55
3/16/2017	700	0.705	493.50
3/7/2017	415.6	0.748	310.87
3/23/2017	74.3	0.699	51.94
3/23/2017	278.9	0.699	194.95
3/29/2017	409.8	0.703	288.09
2/28/2017	306.9	0.751	230.48
2/22/2017	24.6	0.75	18.45
2/22/2017	235.9	0.75	176.93
2/15/2017	350.1	0.738	258.37
2/9/2017	568.3	0.778	442.14
2/9/2017	24.3	0.778	18.91
2/1/2017	838.8	0.738	619.03
1/19/2017	395	0.749	295.86
1/13/2017	8.6	0.75	6.45
1/13/2017	600.3	0.75	450.23
1/6/2017	529	0.788	416.85
	<u>9234.6</u>	<u>0.761</u>	<u>7,024.31</u>

Furnace Maintenance

3/8/2018	295.00
12/10/2018	269.99
12/10/2018	269.99
12/20/2018	154.91
12/20/2018	564.47
	<u>1,554.36</u>

12/7/2018	1350.8	0.816	1,102.25
12/7/2018	442.6	0.816	361.16
11/15/2018	189.6	0.879	166.66
11/15/2018	734.1	0.897	658.49
11/2/2018	2275.2	0.926	2,106.84
11/2/2018	466.3	0.926	431.79
4/26/2018	423	0.921	389.58
4/26/2018	176.7	0.921	162.74
4/18/2008	1129.7	0.887	1,002.04
3/29/2018	443.1	0.904	400.56
3/29/2018	44.5	0.904	40.23
3/19/2018	1065.1	0.854	909.60
3/19/2018	209.9	0.854	179.25
2/28/2018	918.8	0.881	809.46
2/28/2018	249.5	0.881	219.81
2/14/2018	290.8	0.832	241.95
2/9/2018	327.25	0.858	280.78
2/9/2018	1762.2	0.858	1,511.97
1/16/2018	1622.6	0.901	1,461.96
	<u>14121.75</u>	<u>0.880</u>	<u>12,437.13</u>

Year	Total Cost	Furnace Oil		Assumed	
		Cost	Propane Cost	Cost/L	Propane L
2016	\$ 10,009	8,130.73	\$ 1,878.27	0.4	4695.7
2017	\$ 11,282	7,024.31	\$ 4,257.69	0.45	9461.5
2018	\$ 15,067	12,437.13	\$ 2,629.87	0.5	5259.7
Average		\$ 9,197.39	\$ 2,921.95		6472.3

**NDCC Board of Management
2018 Budget**

Account	Description	2016 Actual	2016 Budget	2017 Actuals	2017 Budget	2018 Draft 1	2018 Draft 2	Budget Change	Comments
01-2000-4000	MULMUR GRANT	(27,000)	(27,000)	(47,240)	(47,240)	(20,758)	(25,042)	22,199	
01-2000-4010	MELANCTHON GRANT	(17,500)	(17,500)	(17,500)	(17,500)	(20,758)	(25,042)	(7,542)	
01-2000-4020	DONATION REVENUE	(7,200)	0	0	0	0	0	0	
01-2000-4030	FUNDRAISING REVENUE	(19,922)	(14,500)	(17,382)	(19,380)	(20,000)	(20,000)	(620)	Incl. BBQ
01-2000-4100	MINOR RATE RENTAL REVENUE	(55,131)	(53,997)	(48,069)	(56,300)	(50,000)	(45,000)	11,300	half the year at lower amt so next yr lower
01-2000-4110	ICE RENTAL REVENUE (PRIME)	(44,955)	(50,719)	(50,442)	(42,000)	(49,000)	(52,000)	(10,000)	renting more to other groups
01-2000-4115	ICE RENTAL REVENUE (NON-PRIME)	(1,301)	(1,200)	(743)	(500)	(500)	(500)	0	
01-2000-4120	NON-RESIDENT USER FEES	(3,044)		(3,396)	(2,250)	(3,000)	(3,000)	(750)	
01-2000-4200	BOOTH RENTAL REVENUE	(4,331)	(5,000)	(5,328)	(5,000)	(4,300)	(4,300)	700	includes \$1000 for Strawberry supper
01-2000-4210	HALL RENTAL REVENUE	(2,628)	(2,400)	(2,850)	(2,400)	(2,400)	(2,600)	(200)	
01-2000-4220	FLOOR RENTAL REVENUE	(372)	(100)	0	(100)	(100)	0	100	
01-2000-4230	SIGN RENTAL REVENUE	(4,168)	(4,200)	(4,160)	(4,500)	(4,160)	(4,160)	340	
01-2000-4240	VENDING MACHINE REVENUE	(304)	(300)	(251)	(300)	(300)	(250)	50	
01-2000-4300	PENALTIES & INTEREST	(885)	(300)	(527)	(450)	(525)	(525)	(75)	
01-2000-7000	WAGES	50,561	47,000	42,898	50,000	50,000	45,000	(5,000)	
01-2000-7005	BENEFITS-EI/CPP/WSIB/EHT	5,969	5,000	5,192	5,600	6,000	5,600	0	
01-2000-7010	BENEFITS-OMERS	590		2,913	4,500	0	3,000	(1,500)	
01-2000-7015	STAFF TRAINING/DUES, FEES, SUBSCRIP	303	0	145	484	300	300	(184)	billed from County at end of year
01-2000-7100	OFFICE/COMPUTER SUPPLIES	480	100	1,171	1,680	730	730	(950)	
									incls advertising, phone, internet, 1 email acct
01-2000-7110	COMMUNICATION	2,422	1,553	3,075	1,500	2,425	3,000	1,500	\$73.20
01-2000-7115	INSURANCE	20,605	19,000	16,445	21,225	12,200	12,200	(9,025)	RFQ large decrease in insurance
01-2000-7120	HEALTH & SAFETY	2,527	3,248	2,723	2,800	2,600	2,800	0	billed from County at end of year
01-2000-7125	PROF FEES - AUDIT	1,120	1,089	1,153	1,075	1,120	1,188	113	
01-2000-7130	PROF FEES - WATER TESTING	300	300	300	300	300	300	0	
01-2000-7150	BANK CHARGES	251	500	108	250	25	500	250	
01-2000-7200	HYDRO	78,970	56,206	58,050	56,206	56,500	60,000	3,794	increase in hydro rates
01-2000-7210	FURNACE FUEL/ZAMB PROPANE	10,009	16,240	11,282	9,000	10,000	12,000	3,000	
01-2000-7220	BLDG/GROUNDS MAINTENANCE	16,489	12,180	15,863	14,500	14,000	15,000	500	Includes grounds mtne, snow removal
01-2000-7230	BOOTH MAINTENANCE	1,048	1,300	1,280	1,300	1,100	1,300	0	
01-2000-7240	ICE PLANT/MACH MAINT	15,406	6,000	8,581	12,000	8,000	9,000	(3,000)	
01-2000-7300	FUNDRAISING EXPENSE	10,395	7,500	7,324	10,500	10,500	10,500	0	Incl. BBQ
01-2000-7400	BAD DEBT	26		33	0	0	0	0	
01-2000-6010	TSFR TO REC RESERVES			5,000	5,000				
01-2000-6015	TSFR TO BLDG RESERVES			1,105	0				
	Amount needed	28,732	0	(13,245)	0	41,515	50,083		

7.6.4

FEB - 8 2018
MARCH 8, 2018

NDCC Board of Management 2020 Budget

Account	Description	2018 Actuals	2018 Budget	2019 Actual	2019 Budget	Draft #1 2020 Budget	Draft #2 2020 Budget	Budget Variance	Comments
REVENUES									
1-2000-4000	MULMUR GRANT	25,277	25,277	40,966	55,024	49,262	48,812	(6,212)	-10.47%
1-2000-4010	MELANCTHON GRANT	25,277	25,277	40,966	55,024	49,262	48,812	(6,212)	-10.47%
1-2000-4020	DONATION REVENUE	100	-	-	-			0	
1-2000-4030	FUNDRAISING REVENUE	20,273	20,000	19,047	20,000	20,000	20,000	0	BBQ, Straw. Supper
1-2000-4100	MINOR RATE RENTAL REVENUE	45,901	45,000	26,079	45,000	45,000	45,000	0	
1-2000-4110	ICE RENTAL REVENUE (PRIME)	47,663	52,000	25,342	52,000	51,000	51,000	(1,000)	
1-2000-4115	ICE RENTAL REVENUE (NON-PRIME)	697	500	186	500	500	500	0	
1-2000-4120	NON-RESIDENT USER FEES	3,578	3,000	2,617	3,250	3,250	3,250	0	
1-2000-4200	BOOTH RENTAL REVENUE	3,561	4,300	1,120	5,000	3,500	3,500	(1,500)	
1-2000-4210	HALL RENTAL REVENUE	2,230	2,600	3,035	2,600	2,600	2,600	0	
1-2000-4220	FLOOR RENTAL REVENUE	463	-	-	-			0	
1-2000-4230	SIGN RENTAL REVENUE	3,980	4,160	3,620	4,160	3,700	3,700	(460)	
1-2000-4240	VENDING MACHINE REVENUE	238	250	109	-	-	-	0	
1-2000-4300	PENALTIES & INTEREST	773	525	451	525	676	788	263	
1-2000-4500	PRIOR YEAR DEFICIT			(29,582)	(29,582)			29,582	
	TOTAL REVENUE	180,011	182,888	133,955	213,500	228,750	227,961		
EXPENSES									
1-2000-7000	WAGES	52,760	45,000	36,634	55,000	65,000	65,000	10,000	based on 2018/19 actuals
1-2000-7005	BENEFITS-EI/PPP/WSIB/EHT	5,066	5,600	3,510	5,600	5,600	5,600	0	
1-2000-7010	BENEFITS-OMERS	1,740	3,000	-	-	4,950	4,950	4,950	OMERS must be offered
1-2000-7015	STAFF TRAINING/DUES, FEES, SUBSCRIP	1,556	300	940	300	1,000	1,000	700	
1-2000-7100	OFFICE/COMPUTER SUPPLIES	1,901	1,200	1,823	1,700	2,000	2,000	300	
1-2000-7110	COMMUNICATION	2,512	3,000	1,378	3,000	3,000	3,000	0	
1-2000-7115	INSURANCE	11,763	12,200	12,518	12,200	13,300	13,300	1,100	
1-2000-7120	HEALTH & SAFETY	2,087	2,800	39	2,800	2,500	2,500	(300)	billed at y/e
1-2000-7125	PROF FEES - AUDIT	1,403	1,188	-	1,400	1,400	611	(789)	per quote
1-2000-7130	PROF FEES - WATER TESTING	232	300	168	300	300	300	0	
1-2000-7150	BANK CHARGES	388	500	302	400	500	500	100	
1-2000-7200	HYDRO	55,360	60,000	24,049	60,000	60,000	60,000	0	
1-2000-7210	FURNACE FUEL/ZAMB PROPANE	15,067	12,000	8,792	12,000	15,000	15,000	3,000	
1-2000-7220	BLDG/GROUNDS MAINTENANCE	23,665	15,000	9,044	20,000	17,400	17,400	(2,600)	
1-2000-7230	BOOTH MAINTENANCE	4,462	1,300	404	1,300	1,300	1,300	0	
1-2000-7240	ICE PLANT/MACH MAINT	18,771	9,000	3,334	12,000	10,000	10,000	(2,000)	
1-2000-7300	FUNDRAISING EXPENSE	10,859	10,500	9,965	10,500	10,500	10,500	0	
1-2000-7400	BAD DEBT	0	-	203	-	-	-	0	
1-2000-7500	CAPITAL PURCHASES	0	-	-	15,000	15,000	15,000	0	
	TOTAL EXPENSES	209,593	182,888	113,103	213,500	228,750	227,961	14,461	6.77%
	Net Income/(Deficit)	(29,582)	0	20,852	0	0	0		

Operating Reserve Continuity	2018	2019	2020
Opening Reserve Balance	-	40,000	40,000
Operating Levy Mulmur	20,000	-	-
Operating Levy Melancthon	20,000	-	-
Ending Reserve Balance	40,000	40,000	40,000

EB# 1.4



BURNSIDE

[THE DIFFERENCE IS OUR PEOPLE]

Appendix B

Calculations

Appendix B

28w Fluorescent	4	0.06	10	0.24	2.40	250	600.00	0.1665	\$99.90
10w led	4	0.02	10	0.08	0.80	250	200.00	0.1665	\$33.30
28w Fluorescent	2	0.06	10	0.12	1.20	250	300.00	0.1665	\$49.95
28w Fluorescent	2	0.06	10	0.12	1.20	250	300.00	0.1665	\$49.95
28w Fluorescent	2	0.06	10	0.12	1.20	250	300.00	0.1665	\$49.95
32w Fluorescent	3	0.128	12	0.38	4.61	110	506.88	0.1665	\$84.40
100w Incandescent	2	0.1	12	0.20	2.40	110	264.00	0.1665	\$43.96
9w LED	50	0.04	10	2.00	20.00	250	5000.00	0.1665	\$832.50
2x10 watt	4	0.02	10	0.08	0.80	250	200.00	0.1665	\$33.30
2x32 w fluorescent	18	0.064	10	1.15	11.52	20	230.40	0.1665	\$38.36
32w Fluorescent	3	0.128	10	0.38	3.84	20	76.80	0.1665	\$12.79
				4.86	49.73		8801.28		\$1,427.05

Type of Lamp	# Fixtures	KW	hrs/day	Peak Demand (KW)	kwh/day	working days	kwh/year	\$/kwh (variable)	cost per year
10w led	3	0.02	10	0.06	0.60	250	150.00	0.1665	\$24.98
10w led	9	0.02	10	0.18	1.80	250	450.00	0.1665	\$74.93
10w led	4	0.02	10	0.08	0.80	250	200.00	0.1665	\$33.30
10w led	4	0.02	10	0.08	0.80	250	200.00	0.1665	\$33.30
10w led	2	0.02	10	0.04	0.40	250	100.00	0.1665	\$16.65
10w led	2	0.02	10	0.04	0.40	250	100.00	0.1665	\$16.65
10w led	2	0.02	10	0.04	0.40	250	100.00	0.1665	\$16.65
32w Fluorescent	3	0.128	12	0.38	4.61	110	506.88	0.1665	\$84.40
100w Incandescent	2	0.1	12	0.20	2.40	110	264.00	0.1665	\$43.96
9w LED	50	0.04	10	2.00	20.00	250	5000.00	0.1665	\$832.50
2x10 watt	4	0.02	10	0.08	0.80	250	200.00	0.1665	\$33.30
2x32 w fluorescent	18	0.064	10	1.15	11.52	20	230.40	0.1665	\$38.36
32w Fluorescent	3	0.128	10	0.38	3.84	20	76.80	0.1665	\$12.79
				4.72	48.37		7578.08		\$1,261.75

Savings 4 Lamp Replacement

Type of Lamp	# Fixtures	KW	hrs/day	Peak Demand (KW)	kwh/day	working days	kwh/year	\$/kwh (variable)	Savings	Material Cost	Fixture Cost Total	Incentive per fixture	Incentive Total	Labour/ fixture	Labour
10w led	3	0.04	10	0.12	1.20	250	300.00	0.1665	\$49.95	\$75.00	\$225.00	\$30.00	\$90.00	\$40.00	\$120.00
10w led	9	0	10	0.00	0.00	250	0.00	0.1665	\$0.00						
10w led	4	0.04	10	0.16	1.60	250	400.00	0.1665	\$66.60	\$75.00	\$300.00	\$30.00	\$120.00	\$40.00	\$160.00
10w led	4	0	10	0.00	0.00	250	0.00	0.1665							
10w led	2	0.04	10	0.08	0.80	250	200.00	0.1665	\$33.30	\$75.00	\$150.00	\$30.00	\$60.00	\$40.00	\$80.00
10w led	2	0.04	10	0.08	0.80	250	200.00	0.1665	\$33.30	\$75.00	\$150.00	\$30.00	\$60.00	\$40.00	\$80.00
10w led	2	0.04	10	0.08	0.80	250	200.00	0.1665	\$33.30	\$75.00	\$150.00	\$30.00	\$60.00	\$40.00	\$80.00
32w Fluorescent	3	0	12	0.00	0.00	110	0.00	0.1665							
100w Incandescent	2	0	12	0.00	0.00	110	0.00	0.1665							
9w LED	50	0	10	0.00	0.00	250	0.00	0.1665							
2x10 watt	4	0	10	0.00	0.00	250	0.00	0.1665							
2x32 w fluorescent	18	0	10	0.00	0.00	20	0.00	0.1665							
32w Fluorescent	3	0	10	0.00	0.00	20	0.00	0.1665							
				0.52	5.2								\$390.00		
									\$216.45						

30w LED	2	0.03	12	0.06	0.72	365	262.80	0.1665	\$43.76
LED Wall pack	3	0.014	12	0.04	0.50	365	183.96	0.1665	\$30.63
				0.32	3.84		1,848.36		\$233.37

Type of Lamp	# Fixtures	KW	hrs/day	Peak Demand (KW)	kwh/day	working days	kwh/year	\$/kwh (variable)	cost per year
LED Bulb	1	0.03	12	0.03	0.36	365	131.40	0.1665	\$21.88
LED Bulb	1	0.07	12	0.07	0.84	365	306.60	0.1665	\$51.05
				0.10	1.20		438.00		\$72.93

Need to add boom truck or discuss boom truck

Savings 4 Lamp Replacement

Type of Lamp	# Fixtures	KW	hrs/day	Peak Demand (KW)	kwh/day	working days	kwh/year	\$/kwh (variable)	Savings	Material Cost	Fixture Cost Total	Incentive per fixture	Incentive Total	Labour/ fixture	Lift Rental
LED Bulb	1	0.07	12	0.04	0.48	365	175.20	0.1665	\$29.17	\$200.00	\$200.00	\$25.00	\$25.00	\$120.00	\$500.00
LED Bulb	1	0.25	12	0.18	2.16	365	788.40	0.1665	\$131.27	\$600.00	\$600.00	\$75.00	\$75.00	\$70.00	
				0.22			963.60		\$160.44				\$100.00		

Energy & Institutional - Education

- Fuels & schedules
- Electricity and fuels
- Schedules
- Equipment
- Heating
- Furnace
- End-use
- Building envelope
- Building envelope
- Optimize supply
- Summary
- Include measure?
- Comparison

Building envelope

Description: Building envelope

Note:

Building envelope

	Base case				Proposed case			
Building north	350				350			
Schedule	24/7				Schedule			
Incremental initial costs	\$							

		North	East	South	West	North	East	South	West
<input checked="" type="checkbox"/> Walls									
Area	m ²	72	180	72	180	72	180	72	180
Net area	m ²	68.4	162	68.4	171	68.4	162	68.4	171
U-value	(W/m ²)/°C	0.75	0.75	0.75	0.75	0.75	0.75	0.75	0.75
Incremental initial costs	\$								
<input checked="" type="checkbox"/> Windows									
Area	%	5%	10%	5%	5%	5%	10%	5%	5%
R-value	m ² - °C/W								
Solar heat gain coefficient									
Incremental initial costs	\$								
<input checked="" type="checkbox"/> Solar shading - season of use									
Solar shading - winter	%								
Solar shading - summer	%								
Incremental initial costs	\$								
<input type="checkbox"/> Doors									

<input checked="" type="checkbox"/> Roof			
Area	ft ²	4,000	4,000
U-value	(W/m ²)/°C	0.5	0.5
Incremental initial costs	\$		
<input type="checkbox"/> Skylight			
<input type="checkbox"/> Floor			
<input type="checkbox"/> Wall - below-grade			
<input type="checkbox"/> Floor - below-grade			
Natural air infiltration			
Method		Calculated	
Walls		Medium	Medium
Window		Medium	Medium
Doors		Medium	Medium
Natural air infiltration	L/s	269	269
Incremental initial costs	\$		
Incremental initial costs - total	\$		0
Incremental O&M savings	\$		
Number of building envelope units		1	1
System selection		Heating	Heating
Heating system		Furnace	Furnace
Heating	kWh	70,071	59,133
			Energy saved
			10,938
			15.6%

Heat Profile for Lobby to Exterior

			Annual Heating ΔT between Interior and Exterior		
Month	Time (hr)	Avg. Exterior ¹ (°C)	T_{int} ² (°C)	$\Delta T_{int-ext}$ (K)	$\Delta T_{int-ext} \cdot \text{Time}$ (K·h)
January	744	-9	20	29	21576
February	672	-8.4	20	28.4	19085
March	744	-3.1	20	23.1	17186
April	720	4.4	20	15.6	11232
May	744	10.8	20	9.2	6845
June	720	15.6	20	4.4	3168
July	744	18.1	20	1.9	1414
August	744	17.3	20	2.7	2009
September	720	13.5	20	6.5	4680
October	744	7.8	20	12.2	9077
November	720	1.7	20	18.3	13176
December	744	-5.2	20	25.2	18749
				$\Sigma =$	128196

¹Source: RETScreen - Mount Forest Station

²Interior temperature assumed to be constant at 20°C

Energy Efficiency Measure - Roof Insulation

Project Description	R_{imp,existing} (hr·ft²·°F/BTU)	U_{existing} (W/m²·K)	R_{imp,improved} (hr·ft²·°F/BTU)	U_{improved} (W/m²·K)	 ΔU (W/m²·K)	ΔT·Time (K·h)	Roof Area (m²)	Energy (kWh)
Increase Lobby Roof Insulation to R-50	12	0.47	50	0.11	0.36	104940	372	14,024

Oil Furnace Efficiency	Oil L	Cost of Oil Per L	Total Cost of Oil	Comments
0.62	2,144	\$ 0.83	\$ 1,779.48	Lobby Roof Area

OPINION OF COST

Our opinion of costs is based on our experience with contractors specializing in these fields, historical cost data from similar projects, and/or current construction cost data published by the R.S. Means Company. These cost estimates should be used as a guide only, as costs may vary according to the time of year, quality of materials used, volume of work, actual site conditions, etc.

Door Weatherstripping

Item No.	Item	Cost
A	Mobilization/Demobilization	\$ 700
B	Blown Insulation	\$ 6,800
<i>Construction Sub-Total</i>		<i>\$ 7,500</i>
C	HST (13%)	\$ 975
TOTAL (ROUNDED)		\$ 8,500

Heat Profile for Lobby to Exterior and Arena

Month	Time (hr)	Avg. Exterior ¹ (°C)	Estimated Arena ² (°C)	Annual Heating ΔT between Interior and Exterior			Annual Heating ΔT between Interior and Arena		
				T _{int} ³ (°C)	ΔT _{int-ext} (K)	ΔT _{int-ext} ·Time (K·h)	T _{int} ³ (°C)	ΔT _{int-arena} (K)	ΔT _{int-arena} ·Time (K·h)
January	744	-9	-7	20	29	21576	20	27	20088
February	672	-8.4	-6.4	20	28.4	19085	20	26.4	17741
March	744	-3.1	-1.1	20	23.1	17186	20	21.1	15698
April	720	4.4	5.4	20	15.6	11232	20	14.6	10512
May	744	10.8	10.8	20	9.2	6845	20	9.2	6845
June	720	15.6	15.6	20	4.4	3168	20	4.4	3168
July	744	18.1	18.1	20	1.9	1414	20	1.9	1414
August	744	17.3	17.3	20	2.7	2009	20	2.7	2009
September	720	13.5	13.5	20	6.5	4680	20	6.5	4680
October	744	7.8	8.8	20	12.2	9077	20	11.2	8333
November	720	1.7	2.7	20	18.3	13176	20	17.3	12456
December	744	-5.2	-3.2	20	25.2	18749	20	23.2	17261
						Σ=	128196	Σ=	120204

¹Source: RETScreen - Mount Forest Station

²Estimated service room interior temp is +2°C when exterior is <0°C; +1°C when exterior is 0°C to 10°C; same as exterior when >10°C.

³Interior lobby temperature assumed to be constant at 20°C

Energy Efficiency Measure - Door Air Leakage

Door Area ² (m ²)		Air Leakage Rates ¹			U ³ (W/K)	ΔT-Time (K-h)	Energy (kWh)
		Q _{existing} (L/s·m ²)	Q _{improved} (L/s·m ²)	Δq (L/s·m ²)			
Lobby to Arena							
1	2.2	3.0	1.5	1.5	3.9	120204	469
2	2.2	3.0	1.5	1.5	3.9	120204	469
Lobby to Exterior							
3	2.2	3.0	1.5	1.5	3.9	128196	500
ΣE=							1438

L of Fuel	Cost of Fuel	Measure Cost	Simple Payback
10.56kWh/L	\$0.75/L		

136	\$ 102.18	\$ 1,500.00	14.68
-----	-----------	-------------	-------

¹Air Leakage values taken from AAMA/WDMA/CSA 101/1 S.2/A440-17, Table 6.2:
 - Existing air leakage rates of service doors assumed to be double A2 rating (2 x 1.5 L/s·m²)
 - Improved air leakage rates of original doors assumed to be equivalent to A2 air leakage of 1.5 L/s·m²)

²Door dimensions assumed to be 3'-6" wide by 6'-8" tall

³U = Door area x Δq x heat capacity of air

Heat Capacity of Air is 1.0 kJ/kg K = 1.2 W·s/L·K assuming air density of 1.2kg/m³

OPINION OF COST

Our opinion of costs is based on our experience with contractors specializing in these fields, historical cost data from similar projects, and/or current construction cost data published by the R.S. Means Company. These cost estimates should be used as a guide only, as costs may vary according to the time of year, quality of materials used, volume of work, actual site conditions, etc.

Door Weatherstripping

Item No.	Item	Cost
A	Mobilization/Demobilization	\$ 200
B	Door Weatherstripping	\$ 1,100
<i>Construction Sub-Total</i>		<i>\$ 1,300</i>
C	HST (13%)	\$ 169
TOTAL (ROUNDED)		\$ 1,500

Heat Profile for Tank to Service Room Heat Transfer

Month	Time (hr)	Avg. Exterior ¹ (°C)	Estimated Arena ² (°C)	Annual Heating ΔT between Interior and Arena		
				T _{int} ³ (°C)	$\Delta T_{int-arena}$ (K)	$\Delta T_{int-arena} \cdot \text{Time}$ (K·h)
January	744	-9	-7	20	27	20088
February	672	-8.4	-6.4	20	26.4	17741
March	744	-3.1	-1.1	20	21.1	15698
April	720	4.4	5.4	20	14.6	10512
May	744	10.8	10.8	20	9.2	6845
June	720	15.6	15.6	20	4.4	3168
July	744	18.1	18.1	20	1.9	1414
August	744	17.3	17.3	20	2.7	2009
September	720	13.5	13.5	20	6.5	4680
October	744	7.8	8.8	20	11.2	8333
November	720	1.7	2.7	20	17.3	12456
December	744	-5.2	-3.2	20	23.2	17261
					$\Sigma =$	120204

¹Source: RETScreen - Mount Forest Station

²Estimated service room interior temp is +2°C when exterior is <0°C; +1°C when exterior is 0°C to 10°C; same as exterior when >10°C.

³Interior lobby temperature assumed to be constant at 20°C

Energy Efficiency Measure - Interior Window Replacement

Description	U _{existing} (W/m ² ·K)	U _{improved} (W/m ² ·K)	ΔT-Time (K-h)	Area (m ²)	Energy (kWh)
EEM-X Replace Thermally Unbroken Hollow Metal Frame Windows between Arena and Interior Lobby	6.42	3.47	120204	32.0	11347

L of Fuel 10.56kWh/L	Cost of Fuel \$0.75/L	Measure Cost	Simple Payback
1075	\$ 806.14	\$ 38,000.00	47.14

*Window U-values taken from 2011 ASHRAE fundamentals handbook (Table 4, page 30.8):

- Existing windows assumed to be equivalent to thermally unbroken aluminum frame with fixed, 3.2mm thick, single glazing
- Upgraded windows assumed to be equivalent to thermally unbroken aluminum frame with fixed, double glazing, low ε=0.2, 12.7mm argon space, fire rated coating (e.g. Pyrostop by Pilkington). Aluminium frames cannot be thermally broken as the butyl break compromises its fire rating.

OPINION OF COST

Our opinion of costs is based on our experience with contractors specializing in these fields, historical cost data from similar projects, and/or current construction cost data published by the R.S. Means Company. These cost estimates should be used as a guide only, as costs may vary according to the time of year, quality of materials used, volume of work, actual site conditions, etc.

EEM-X: Interior Window Replacement

Item No.	Item	Cost
A	Mobilization/Access/Protection/Demobilization	\$ 2,000
B	Window Replacement	\$ 23,400
C	Allowances	
i)	Building Permit	\$ 200
D	Construction Contingency	\$ 3,000
<i>Construction Sub-Total</i>		<i>\$ 28,600</i>
E1	Engineering Services: Design & Tender	\$ 3,500
E2	Engineering Services: Construction Review (Based on a 1 week construction schedule)	\$ 1,800
<i>Sub-Total</i>		<i>\$ 33,900</i>
F	HST (13%)	\$ 4,407
TOTAL (ROUNDED)		\$ 38,000

Honeywood Arena Water Usage Calculation

Baseline Case: change occupant values to reflect anticipated occupancy

Fixture Type	Number of		Consumption (l)	Daily Uses	Duration (min)	Occupants	Daily Water Use (gal)	Notes
	Fixtures							
3.5 gpf toilet - male (gallons per flush) changerooms	4	3.5	2.5	1	60	525	75 people in the arena per day on average for 8.5 hour day - 60 hours per week Assur	
3.5 gpf toilet - female (gallons per flush)	3	3.5	3	1	15	158		
2.0 gpf urinal - male (gallons per flush) 1st Floor Lobby	2	2	0.5	1	60	60	Only two urinals in lobby - most flushing would be from changerooms toilets	
Commercial Lavatory Faucets - 2.2 gpm	9	2.2	3	0.3	75	149		
Canteen sink - 2.2 gpm	1	2.2	20	0.25	2	22	Used only on weekends	
Dishwasher	1	6	2	1	1	12	Used only on weekends	
Coffee/Tea/Water	1	2			75	150	2 L of water per occupant	
Showerhead - 2.5 gpm	4	2.5	1	4	34	339	237 Showers per week across 4 showers	
Total Daily Volume							1,414	Pumping Costs
Monthly							29,685	Assumption 12Gal/min pump
m^3/month							112	1.1kw pump
Annual Work Days							250	m3 Gal Min hours kwh
Total Annual Usage (g)							353,393	1,337.6 353,354.3 29,446.2 490.8 539.8
Total Annual Usage (m^3)							1,338	Heating Costs
								L/Year Cost per year
								2098.6 \$1,741.83

Calculator: To determine estimated savings, insert occupant values (same as Baseline) and consumption values based on fixtures and fixture fittings installed

Fixture Type	Number of		Consumption	Daily Uses	Duration	Occupants	Daily Water Use (gal)	Notes
	Fixtures							
3.5 gpf toilet - male (gallons per flush) changerooms	4	3.5	2.5	1	60	525		
3.5 gpf toilet - female (gallons per flush)	3	3.5	3	1	15	158		
2.0 gpf urinal - male (gallons per flush) 1st Floor Lobby	2	2	0.5	1	60	60		
Commercial Lavatory Faucet - 0.5 gpm	9	0.5	3	0.3	75	34		
Canteen sink - 1.0 gpm	1	1	20	0.25	2	10		
Dishwasher	1	6	2	1	1	12		
Coffee/Tea/Water	1	2			75	150		
Low Flow Showerhead - 1.6 gpm	4	1.6	1	4	34	217		
Total Daily Volume							1,165	Assumption 12Gal/min pump
Monthly							24,464	1.1kw pump
m^3/month							93	m3 Gal Min hours kwh
Annual Operation Days							250	235.3 62,152.2 5,179.3 86.3 95.0
Total Annual Usage (g)							291,234	Heating Costs
Total Annual Usage (m^3)							1,102	L/Year Cost per year
Annual Savings							62,159	1527.8 \$1,268.04
% Reduction							-17.6%	Yearly Savings
m^3 reduction							235	Pumping kwh saved 94.95
								\$ (\$0.01665/kwh) \$ 15.81
								Cost Savings \$ 489.60
								Implementation Cost \$ 1,800.00
								Total Savings \$ 1,800.00
								Simple Payback 3.68 years

Low Flow Fixtures Domestic Water Heater Cost Savings from Reduced Oil Consumption
Yearly Savings

Fixture	# of Fixtures	Cost per fixture	Installation cost/fixture	Total Cost
Commercial Lavatory Faucet - 0.5 gpm	9	\$100	\$100	\$1,800
Kitchen sink - 0.5 gpm	1	\$100	\$100	\$200
Dishwasher	1			\$0
Low Flow Shower Head	4	\$25	\$10	\$140
Total				\$1,800
			Simple payback (years)	3.68

John wood Efficiency is 0.62

Oil Water Heater Savings	Gallons Heated	BTU/Gallon of Water	BTU Required	BTU/gal/no. 2 oil	Gal of Fuel Oil/Day	Days in Peak Season	Gal/Year	L/Year	Cost per year
Before	365.6	846.8	309604.8	139600.0	2.2	250.0	554.4	2098.6	\$1,741.83
After	266.2	846.8	225389.5	139600.0	1.6	250.0	403.6	1527.8	\$1,268.04
Savings								570.84	\$473.79

**Honeywood Arena
Furnace Oil Consumption Calculation**

2018 Consumption	12,841
2017 Consumption	9,234
2016 Consumption	14,121

	Average 3 Year Oil Usage		
	L of Oil	kWh/L	kWh
Annual	12,085	10 5570	127,374
DHW	2,000	10 5570	21,114
Zamboni	5,200	10 5570	54,896
Furnace	4,865	10 5570	51,363

L of Oil
 Replace 1
 Furnace 5%
 More Efficient
 Savings 121.63

Estimated Oil Usage by Arena Use

1		
2	<u>2018</u>	
3	Total Oil	12,841
4	DHW	2,000
	Zamboni Hot Water	5,200
5	Total Heating Load	5,641
1	<u>2017</u>	
2	Total Oil	9,234
3	DHW	2,000
4	Zamboni Hot Water	5,200
5	Total Heating Load	2,034
	<u>2016</u>	
	Total Oil	14,121
	DHW	2,000
	Zamboni Hot Water	5,200
	Total Heating Load	6,921

Drain Water Heat Recovery on Low Flow Fixtures
Yearly Savings

Fixture	# of Fixtures	Cost per fixture	Installation cost/fixture	Total Cost
Powerpipe or similar	2	\$700	\$1,200	\$3,800
Total				\$3,800
Simple payback (years)				12.49

John wood Efficiency is 0.62

Oil Water Heater Savings	Gallons Heated	BTU/Gallon of Water	BTU Required	BTU/gal./no. 2 oil	Gal of Fuel Oil/Day	Days in Peak Season	Gal/Year	L/Year	Cost per year
Including Low Flow Fixtures	266.2	846.8	225389.5	139600.0	1.6	250.0	403.6	1527.8	\$1,268.04
With DWHR 24% Heat Recovery							306.8	1161.1	\$963.71
Savings								366.66	\$304.33

Zamboni Water Heater Cost Comparison

John wood EF is 0.62

Oil Water Heater Zamboni Cost	Gallons/year	EF	BTU/Gallon of Water	BTU Required	BTU/gal/no. 2 oil	Gal of Fuel Oil/yr	L/Year	kWh	\$/L	Cost per year
Before	227700.0	0.62	846.8	192810483.9	139600.0	1381.2	5227.7	55152.3	\$ 0.83	\$3,973.06
						682.2949787				

75 Gal Propane EF assumed 0.75

Propane Water Heater Zamboni Cost	Gallons/year	EF	BTU/Gallon of Water	BTU Required	BTU/gal/pro pane	Gal of Fuel Oil/yr	L/Year			Cost per year
Before	227700.0	0.75	700.0	159390000.0	91000.0	1751.5	6629.6	45713.7	\$ 0.49	\$3,248.49

Savings \$724.57

Desuperheater Raises incoming temperature from 55 to 120 degrees 80% of the time

$$Q = M c_p \Delta T$$

Q = Heat Gain by quantity of water in btu/hr

M = Mass in pounds/min

Cp = Specific Heat of Water = 1

ΔT = Change in Temp Farenheit

1) Water Flow Rate though heater of 2.3 US gallons/min = 19.48 lbs = M
19.4

2) Cp = 1

3) $\Delta T = 120 - 55 = 65$

$$Q = 19.48 \text{ lb/min} * 60 \text{ min/hr} * 1 * 65 = 75,972 \text{ btu/hr}$$

8 floods per day
607776 btu/day

1 Therm = 100,000 BTU
140000 BTU/Gallon of No. 2 Fuel Oil
62% water heater efficiency + 80% Desuperheater Efficiency

Using Fuel Oil 2 62% efficiency = output BTU/Gallon = $0.62 * 140,000 \text{ BTU} = 86,800 \text{ BTU/Gallon}$

BTU/Day / BTU/Gallon * 80% Desuperheater Efficiency =

5.60 Gallons per day
Gallons/Day * 7 months per year * 30 days per month * 3.8 Gallons/L =
4470 L of Fuel Oil/ year (Estimated 5200 total)

\$0.83/L of Fuel Oil
\$ 3,710.18

Based on 7 month ice season =
\$ 3,710.18

Capital Cost of \$42,500
Payback =
11.45



RETScreen[®] International

www.retscreen.net

Clean Energy Project Analysis Software

Project Information

[See project database](#)

Project name	North Dufferin Community Centre Solar
Project location	Mulmur, ON
Prepared for	Mulmur Township
Prepared by	RJ Burnside & Associates
Project type	Power
Technology	Photovoltaic
Grid type	Central-grid
Analysis type	Method 2
Heating value reference	Higher heating value (HHV)
Show settings	<input type="checkbox"/>

Site reference conditions

[Select climate data location](#)

Climate data location	Mount Forest (MARS)
Show data	<input type="checkbox"/>



[Complete Energy Model sheet](#)

Proposed case power system

Analysis type

- Method 1
- Method 2

Photovoltaic

Power capacity

kW 190.00

[See product database](#)

Manufacturer

Model

Capacity factor

% 14.0%

Electricity exported to grid

MWh 233.0

Electricity export rate

\$/MWh 134.00

RETScreen Cost Analysis - Power project

Settings		
<input checked="" type="radio"/> Method 1	<input type="radio"/> Notes/Range	Notes/Range
<input type="radio"/> Method 2	<input type="radio"/> Second currency	None
	<input type="radio"/> Cost allocation	

Initial costs (credits)	Unit	Quantity	Unit cost	Amount	Relative costs
Feasibility study					
Feasibility study	cost	1	\$ 5,000	\$ 5,000	
Subtotal:				\$ 5,000	1.1%
Development					
Development	cost	1	\$ 20,000	\$ 20,000	
Subtotal:				\$ 20,000	4.3%
Engineering					
Engineering	cost	1	\$ 10,000	\$ 10,000	
Subtotal:				\$ 10,000	2.2%
Power system					
Photovoltaic	kW	190.00	\$ 2,250	\$ 427,500	
Road construction	km			\$ -	
Transmission line	km			\$ -	
Substation	project			\$ -	
Energy efficiency measures	project			\$ -	
User-defined	cost			\$ -	
Subtotal:				\$ 427,500	92.4%
Balance of system & miscellaneous					
Spare parts	%			\$ -	
Transportation	project			\$ -	
Training & commissioning	p-d			\$ -	
User-defined	cost			\$ -	
Contingencies	%		\$ 462,500	\$ -	
Interest during construction			\$ 462,500	\$ -	
Subtotal:				\$ -	0.0%
Total Initial costs				\$ 462,500	100.0%

Annual costs (credits)	Unit	Quantity	Unit cost	Amount
O&M				
Parts & labour	project	190	\$ 39	\$ 7,410
User-defined	cost			\$ -
Contingencies	%		\$ 7,410	\$ -
Subtotal:				\$ 7,410

Periodic costs (credits)	Unit	Year	Unit cost	Amount
User-defined	cost			\$ -
End of project life	cost			\$ -

RETScreen Emission Reduction Analysis - Power project

Emission Analysis

- Method 1
- Method 2
- Method 3

Base case electricity system (Baseline)

Country - region	Fuel type	GHG emission factor (excl. T&D) tCO2/MWh	T&D losses %	GHG emission factor tCO2/MWh
Canada - Ontario	Other	0.131		0.131

Baseline changes during project life

Base case system GHG summary (Baseline)

Fuel type	Fuel mix %	Fuel consumption MWh	GHG emission factor tCO2/MWh	GHG emission tCO2
Electricity	100.0%	233	0.131	30.5
Total	100.0%	233	0.131	30.5

Proposed case system GHG summary (Power project)

Fuel type	Fuel mix %	Fuel consumption MWh	GHG emission factor tCO2/MWh	GHG emission tCO2
Solar	100.0%	233	0.000	0.0
Total	100.0%	233	0.000	0.0
Electricity exported to grid	MWh	233	T&D losses	0.0
				Total 0.0

GHG emission reduction summary

Power project	Base case GHG emission tCO2	Proposed case GHG emission tCO2	Gross annual GHG emission reduction tCO2	GHG credits transaction fee %	Net annual GHG emission reduction tCO2
Power project	30.5	0.0	30.5		30.5
Net annual GHG emission reduction	30.5	tCO2	is equivalent to	5.6	Cars & light trucks not used

RETScreen Financial Analysis - Power project

Financial parameters			
General			
Fuel cost escalation rate	%		0.0%
Inflation rate	%		2.0%
Discount rate	%		4.0%
Project life	yr		30

Finance			
Incentives and grants	\$		
Debt ratio	%		75.0%
Debt	\$		348,875
Equity	\$		115,625
Debt interest rate	%		2.50%
Debt term	yr		30
Debt payments	\$/yr		16,573

Income tax analysis

Annual income			
Electricity export income			
Electricity exported to grid	MWh		233
Electricity export rate	\$/MWh		134.00
Electricity export income	\$		31,224
Electricity export escalation rate	%		3.5%

GHG reduction income			
<input type="checkbox"/>			
Net GHG reduction	1002/yr		31
Net GHG reduction - 30 yrs	1002		816

Customer premium income (rebate)

Other income (cost)

Clean Energy (CE) production income

Project costs and savings/income summary			
Initial costs			
Feasibility study	1.1%	\$	5,000
Development	4.3%	\$	20,000
Engineering	2.2%	\$	10,000
Power system	92.4%	\$	427,500
Balance of system & misc. 0.0% \$ 0			
Total initial costs	100.0%	\$	462,500


Annual costs and debt payments			
O&M		\$	7,410
Fuel cost - proposed case		\$	0
Debt payments - 30 yrs		\$	16,573
Total annual costs		\$	23,983

Periodic costs (credits)

Annual savings and income			
Fuel cost - base case		\$	0
Electricity export income		\$	31,224
Total annual savings and income		\$	31,224

Financial viability			
Pre-tax IRR - equity	%		13.9%
Pre-tax IRR - assets	%		3.4%
After-tax IRR - equity	%		13.9%
After-tax IRR - assets	%		3.4%
Simple payback	yr		19.4
Equity payback	yr		9.2
Net Present Value (NPV)	\$		300,998
Annual life cycle savings	\$/yr		17,407
Benefit-Cost (B-C) ratio			3.60
Debt service coverage			1.49
Energy production cost	\$/MWh		87.63
GHG reduction cost	\$/1002		(570)

Yearly cash flows				
Year	Pre-tax	After-tax	Cumulative	
#	\$	\$	\$	\$
0	-115,625	-115,625	-115,625	
1	8,166	8,166	-107,439	
2	9,166	9,166	-98,273	
3	10,182	10,182	-88,091	
4	11,237	11,237	-76,854	
5	12,330	12,330	-64,524	
6	13,465	13,465	-51,059	
7	14,641	14,641	-36,418	
8	15,861	15,861	-20,556	
9	17,127	17,127	-3,430	
10	18,439	18,439	15,009	
11	19,800	19,800	34,809	
12	21,211	21,211	56,021	
13	22,675	22,675	78,695	
14	24,192	24,192	102,888	
15	25,766	25,766	128,653	
16	27,397	27,397	156,050	
17	29,089	29,089	185,139	
18	30,842	30,842	215,981	
19	32,651	32,651	248,642	
20	34,546	34,546	283,187	
21	36,500	36,500	319,687	
22	38,526	38,526	358,213	
23	40,626	40,626	398,840	
24	42,804	42,804	441,643	
25	45,061	45,061	486,704	
26	47,400	47,400	534,104	
27	49,825	49,825	583,929	
28	52,339	52,339	636,268	
29	54,944	54,944	691,212	
30	57,645	57,645	748,857	





BURNSIDE

[THE DIFFERENCE IS OUR PEOPLE]

Appendix C

Benchmark Report


ENERGY STAR[®] Energy Performance Scorecard

86

out of 100

Honeywood Arena Version 2

For Year Ending	December 31, 2018
Property Address	706114 County Rd 21 Mulmur, ON, Ontario L9V0W3
Primary Function	Ice/Curling Rink
Gross Floor Area (ft ²)	26,182
Year built	1965
Energy Use per sq. ft.*	58.8 kBtu



What is the ENERGY STAR Score?

The ENERGY STAR score rates commercial building's energy performance relative to similar buildings nationwide. Expressed as a number on a simple 1-100 scale, the score rates performance on a percentile basis: a building with a score of 50 performs better than 50% of its peers. Higher scores mean better energy efficiency, resulting in less energy use and fewer greenhouse gas emissions. If a 1-100 score for a specific building type has not been developed, Site Energy Use Intensity (EUI) will be displayed on this scorecard.

Learn more at:

energystar.gov/scorecard

*Site energy use



Natural Resources
Canada

Ressources naturelles
Canada

Date Generated: November 18, 2019




BURNSIDE

[THE DIFFERENCE IS OUR PEOPLE]

Appendix D

Drawings




Honeywood Arena
Township of Mulmur

MAIN FLOOR
EXISTING

Project 2714
Design BR
Drawn BR

Scale 1/8" = 1'-0"
Date September 2014
Issued





**Honeywood Arena
Township of Mulmur**

UPPER FLOOR
EXISTING

Project 2714
Design BR
Drawn HR

Scale 1/8" = 1' 0"
Date September 2014
Issued




**Honeywood Arena
Township of Mulmur**

**ELEVATIONS
EXISTING**


Project 2714
Design BR
Drawn BR

Scale 1/8" = 1' 0"
Date September 2014
Issued



Light & Ray
 50
 50

MAIN FLOOR PLAN



TYPE II (SEE DETAIL)
 TYPE III (SEE DETAIL)
 TYPE IV (SEE DETAIL)

GLAZED BLOCK (SEE DETAIL)

ICE STORAGE

ELEVATION 10000

ICE STORAGE

ELEVATION 10000

ICE STORAGE

ELEVATION 10000

ICE STORAGE

ELEVATION 10000

ICE STORAGE

ELEVATION 10000

ICE STORAGE

ELEVATION 10000

the 1990s, the number of people in the UK who are aged 65 and over has increased from 10.5 million to 13.5 million (15.5% of the population).

There is a growing awareness of the need to address the health care needs of the elderly population. The Department of Health (1998) has set out a strategy for the care of the elderly, and the Health Service Research Unit (1998) has produced a research agenda for the care of the elderly.

There is a need to understand the health care needs of the elderly population, and to develop strategies to meet these needs.

The purpose of this paper is to review the literature on the health care needs of the elderly population, and to identify areas for further research.

The paper is organized as follows. First, we discuss the demographic changes in the elderly population. Then, we review the literature on the health care needs of the elderly population. Finally, we identify areas for further research.

Demographics

The elderly population in the UK has increased significantly in the last few decades. In 1998, there were 13.5 million people aged 65 and over in the UK, up from 10.5 million in 1990.

The increase in the elderly population is due to a combination of factors, including a decline in mortality rates and an increase in life expectancy.

The increase in life expectancy is due to a combination of factors, including a decline in mortality rates and an increase in life expectancy.

The increase in life expectancy is due to a combination of factors, including a decline in mortality rates and an increase in life expectancy.

The increase in life expectancy is due to a combination of factors, including a decline in mortality rates and an increase in life expectancy.

Health care needs

The health care needs of the elderly population are complex and multifaceted. They include physical, mental, and social needs.

The physical needs of the elderly population include the need for medical care, nursing care, and social care.

The mental needs of the elderly population include the need for psychological support, counselling, and therapy.

The social needs of the elderly population include the need for social contact, support, and care.

The health care needs of the elderly population are complex and multifaceted. They include physical, mental, and social needs.

The physical needs of the elderly population include the need for medical care, nursing care, and social care.

The mental needs of the elderly population include the need for psychological support, counselling, and therapy.

The social needs of the elderly population include the need for social contact, support, and care.

The health care needs of the elderly population are complex and multifaceted. They include physical, mental, and social needs.

The physical needs of the elderly population include the need for medical care, nursing care, and social care.

The mental needs of the elderly population include the need for psychological support, counselling, and therapy.

The social needs of the elderly population include the need for social contact, support, and care.

