



**NORTH DUFFERIN COMMUNITY CENTRE  
BOARD OF MANAGEMENT  
AGENDA - ELECTRONIC MEETING - ZOOM  
TUESDAY, AUGUST 11, 2020 - 7:00 P.M.**



**1. Call to order by Chair**

**2. Additions/Deletions/Approval of the Agenda**

*Moved by----- Seconded by----- That the Agenda be approved as circulated.  
Carried.*

**3. Declaration of Pecuniary Interest or Conflict of Interest**

**4. Approval of Draft Minutes - July 7, 2020**

*Moved by----- Seconded by----- the minutes of the North Dufferin  
Community Centre Board of Management held on July 7, 2020 be approved as circulated.  
Carried*

**5. Business Arising from the Minutes**

**6. Facility Manager's Report**

**7. General Business**

1. Financial
  1. Accounts

*Moved by----- Seconded by----- the accounts in the amount  
of \$5,345.97 be approved to be paid. Carried*

2. A/R update including HMHA discrepancies explanation
3. YTD vs. Budget comparison
2. Email from Heather Boston regarding a contact for applying for Grants
3. Email from Tracey Atkinson - Responsibilities of Arena Board in regards to property repairs
4. Other
5. Unfinished Business
  1. Arena Manager and Part time staff Pay Grids
  2. Generator Switch for Mobile Generator
  3. Keystone Software Arena Billing (Member Lowry discuss at next regular in person meeting) - NDCC Agreement between Mulmur and Melancthon

**8. Information**

1. RJ Burnside Communtiy Energy Plan Volume 3 NDCC Energy Audit Report, June 2020

*Moved by----- Seconded by----- Item 8.1 be received as information.  
Carried.*

**9. Notice of Motion**

**10. Confirmation Motion**

*Moved by----- Seconded by----- all actions of the Members and Officers of the North Dufferin Community Centre Board of Management with respect to every matter addressed and/or adopted by the Board on the above date are hereby adopted, ratified and confirmed; and each motion, resolution and other actions taken by the Board Members and Officers at the meeting held on the above date are hereby adopted, ratified and confirmed. Carried.*

**11. Adjournment and Date of Next Meeting - Wednesday September 9, 2020 - 7:00 - 9:00 p.m.**

*Moved by ----- Seconded by-----we adjourn the North Dufferin Community Centre Board of Management meeting at -----:----- p.m. to meet again on Wednesday September 9, 2020 at 7:00 p.m. or at the call of the Chair. Carried.*



**NORTH DUFFERIN COMMUNITY CENTRE BOARD OF  
MANAGEMENT  
MINUTES  
WEDNESDAY, JULY 7, 2020 – 7:00 P.M.  
ELECTRONIC MEETING - ZOOM**



The North Dufferin Community Centre Board of Management known as “The Board” held its meeting on the 7<sup>th</sup> day of July, 2020 at 7:00 p.m., as an electronic meeting through ZOOM.

*Those present:*

Chester Tupling, Chair, Mulmur  
Patricia Clark, Councillor, Mulmur  
Dave Besley, Deputy Mayor, Melancthon  
Clayton Rowbotham, Melancthon  
Keith Lowry, Mulmur  
Nancy Noble, Mulmur  
Debbie Fawcett, Melancthon,  
Donna Funston, NDCC Secretary, Melancthon

*Regrets:*

Bert Tupling, Vice-Chair, Melancthon

**#1 Call to Order by Chair**

Chair Tupling called the meeting to order at 7:01 p.m.

**#2 Additions/Deletions/Approval of Agenda**

-Moved by Noble, Seconded by Fawcett that the Agenda be approved as amended. Carried.

Addition: 2.1 Library update,  
2.2 Efficiency plan

**#3 Declaration of Pecuniary Interest or Conflict of Interest**

None.

**#4 Approval of Draft Minutes**

-Moved by Clark, Seconded by Rowbotham, that the minutes of the North Dufferin Community Centre Board of Management held on June 10, 2020 be approved as circulated. Carried.

**#5 Business Arising from the Minutes**

None.

## **#6 Facility Manager's Report**

James Woods was in attendance for this portion of the meeting.

James reports his computer is really old and needs upgraded, Mulmur has suggested they might have a spare one to give to the Arena when the office gets new computers.

James request permission to purchase a new grinder and concrete drill for repairs around the Arena. He would also like a portable power washer to take into each dressing room and to do clean the Zamboni. The roof is also leaking board directs James to have a look and see what the issue is and report back.

The ball park benches need to be repaired as they are unsafe, James will replace the rotted wood. Member Clark will speak to Mulmur Council to get clarification on repairs to the Cenotaph fence and the ball park, is it Mulmur Staff or Arena Staff responsible for doing the repairs.

James will email the quote to fix the doorway near the mens washroom using 2 rolls of rubber mat.

James questions an item on the June accounts – an Intellicore bill that was divided between the Fire department and the Arena, is this correct? Board directs Donna to ask Heather about this invoice.

Sparlings has buried a line and James feels its needs to have cement pillars to block off the line so no one runs into the pipe.

Member Clark requests James to narrow down his to do list each month so the Board is aware of what was accomplished each month.

-Moved by Noble, Seconded by Fawcett, that the NDCC Board of Management approve the Arena Manager to purchase a contractor grade grinder and drill. Board also approves purchasing a power washer up to a maximum of \$500.00. Carried.

Discussion around Stage 3 and re-opening the Arena. Re-opening will be very different this year and a lot will depend on OMHA and how the hockey season will look. More discussion will take place next month.

## **#7 General Business**

1. Financial
  1. Accounts
  2. A/R update
  3. YTD vs. Budget comparison
2. Other
3. Unfinished Business
  1. Arena Manager and Part time staff Pay Grids
  2. Generator Switch for Mobile Generator

**3. Keystone Software Arena Billing (Member Lowry discuss at next regular in person meeting)**

**#1.1** -Moved by Fawcett, Seconded by Besley that the accounts in the amount of \$1,152.72 be approved to be paid. Carried.

**#1.2** Discussion on the A/R list that it is smaller and still being worked on.

**#1.3** No concerns raised.

**#2.1** Chair Tupling and member Rowbotham will take a look at the Library and see if the building would be movable or just crumble to pieces. Member Lowry offers to make arrangements with the current owner if the building is considered movable. Member Clark makes note that the Library cannot be placed on Mulmur property at this time, she will speak with Mulmur and see what would have to be done to be able to put the Library on the Arena property.

**#2.2** Member Clark advises the Board that a NDCC usage report will be going to Mulmur Council tomorrow (July 8) and she will request that the report be sent to the Board for the efficiency plan.

**#3** All unfinished business will be discussed when the regular in person meeting resume.

**#8 Information**

**#8.1** Board would like to wait for the final report from Sierra Planning before making any spending decisions. Chair Tupling advises he has an upcoming meeting with Tracey Atkinson regarding the grant process.

-Moved by Clark, Seconded by Lowry Item 8.1 and 8.2 be received as information. Carried.

**#10 Notice of Motion**

-None

**#11 Confirmation Motion**

-Moved by Lowry, Seconded by Besley that all actions of the Members and Officers of the North Dufferin Community Centre Board of Management with respect to every matter addressed and or adopted by the Board on the above date are hereby adopted, ratified and confirmed; and each motion, resolution and other actions taken by the Board Members and Officers at the meeting held on the above date are hereby adopted, ratified and confirmed. Carried.

## **#12 Adjournment**

-Moved by Clark, Seconded by Lowry that we adjourn the North Dufferin Community Centre Board of Management meeting at 8:18 p.m. to meet again on Tuesday August 11, 2020 at 7:00 p.m. or at the call of the Chair. Carried.

---

**CHAIR**

---

**SECRETARY**

## Accounts Payable

NDCC AP List 6/30/2020-7/27/2020

Vendor 000000 Through 999999

Invoice Entry Date 06/30/2020 to 07/27/2020 Paid Invoices Cheque Date 06/30/2020 to 07/27/2020

Vendor Number Name	Invoice Number	Invoice Desc	Invoice Date	Entry Date	Amount
000062 GFL ENVIRONMENTAL INC.	SD-0000301652	JUNE - 1 Lifts	06/30/2020	07/03/2020	58.20
		01-2000-7220 JUNE - 1 Lifts			58.20
000016 HYDRO ONE	July 8, 2020	ICE PLANT JUNE	07/08/2020	07/24/2020	209.72
		01-2000-7200 ICE PLANT JUNE			209.72
000016 HYDRO ONE	JUNE 11, 2020	BUILDING JUNE	06/11/2020	07/24/2020	214.82
		01-2000-7200 BUILDING JUNE			214.82
Vendor Total					424.54
<hr/>					
000014 RECEIVER GENERAL	June 30 2020	2ND QTR REMIT	06/30/2020	07/24/2020	2,341.10
		01-1000-2203 2ND QTR REMIT CPP			862.56
		01-1000-2202 2ND QTR REMIT EI			342.17
		01-1000-2201 2ND QTR REMIT FED TAX			1,136.37
000020 TD BANK	June 30 2020	JUNE EFT S/C	06/30/2020	06/30/2020	233.01
		01-2000-7150 JUNE EFT S/C			50.00
		01-2000-7150 JUNE EFT S/C			98.20
		01-2000-7150 JUNE EFT S/C			84.81
000020 TD BANK	June 2020	JULY EFT S/C	06/30/2020	07/24/2020	190.05
		01-2000-7150 JULY EFT S/C			190.05
Vendor Total					423.06
000006 TELIZON INC	03500420200713	ACCT #35004 - ARENA JUNE	07/13/2020	07/24/2020	68.08
		01-2000-7110 ACCT #35004 - ARENA JUNE			68.08
000015 TOWNSHIP OF MULMUR	034599	JULY 08 GRASS CUTTING	07/08/2020	07/09/2020	84.75
		01-2000-7220 JULY GRASS CUTTING			84.75
000015 TOWNSHIP OF MULMUR	01188	MAY GRASS CUTTING	06/30/2020	07/24/2020	1,080.00
		01-2000-7220 MAY GRASS CUTTING			1,080.00
Vendor Total					1,164.75
000017 WORKPLACE SAFETY & INSU June 2020		QTR 2 WSIB	06/30/2020	07/24/2020	63.18
		01-1000-2205 QTR 2 WSIB			63.18
Unpaid Invoices					803.08
Paid Invoices					4,542.89
Invoices Total					5,345.97
Selected G/L Account Total					5,345.97

**General Ledger**  
**Annual Department Budget vs. Actual Comparison Report**  
 Fiscal Year Ending: DEC 31, 2020 - From Period 1 To Period 7 Ending JUL 31, 2020

Account	Description	Previous Year Total		Current Year To Date		Budget Remaining	Total Budget
		Actual	Budget	Actual	Budget		
Fund: 01 OPERATING FUND							
Category: 27??							
2000 INCOME STATEMENT							
Revenue							
01-2000-4000	MULMUR GRANT	55,023.65	55,023.65	27,307.42	31,739.56	27,103.24	54,410.66
01-2000-4010	MELANCTHON GRANT	55,023.65	55,023.65	27,307.42	31,739.56	27,103.24	54,410.66
01-2000-4015	GRANT REVENUE	0.00	0.00	0.00	0.00	0.00	0.00
01-2000-4020	DONATION REVENUE	3,239.35	0.00	0.00	0.00	0.00	0.00
01-2000-4030	FUNDRAISING REVENUE	19,046.55	20,000.00	0.00	0.00	0.00	0.00
01-2000-4100	MINOR RATE ICE RENTAL REVEN	54,020.55	45,000.00	22,006.88	31,500.00	31,993.12	54,000.00
01-2000-4110	ICE RENTAL REVENUE (PRIME)	50,822.88	52,000.00	20,024.65	29,750.00	30,975.35	51,000.00
01-2000-4115	ICE RENTAL REVENUE (NON-PRIM	1,632.74	500.00	0.00	291.65	500.00	500.00
01-2000-4120	NON-RESIDENT USER FEES	3,696.16	3,250.00	2,363.12	1,895.85	886.88	3,250.00
01-2000-4200	BOOTH RENTAL REVENUE	2,169.96	5,000.00	846.78	1,225.00	1,253.22	2,100.00
01-2000-4210	HALL RENTAL REVENUE	4,011.50	2,600.00	0.00	2,333.35	4,000.00	4,000.00
01-2000-4220	FLOOR RENTAL REVENUE	97.34	0.00	0.00	0.00	0.00	0.00
01-2000-4230	SIGN RENTAL REVENUE	3,840.00	4,160.00	4,160.00	2,216.65	(360.00)	3,800.00
01-2000-4240	VENDING MACHINE REVENUE	109.39	0.00	0.00	0.00	0.00	0.00
01-2000-4300	PENALTIES & INTEREST	869.44	525.00	887.24	495.85	(37.24)	850.00
01-2000-4500	PR YR SURPLUS/DEFICIT	(29,582.29)	(29,582.30)	0.00	(3,418.51)	(5,860.31)	(5,860.31)
Total Revenue		224,020.87	213,500.00	104,903.51	129,768.96	117,557.50	222,461.01
Expense							
01-2000-7000	WAGES	68,452.29	55,000.00	29,586.00	40,833.35	40,414.00	70,000.00
01-2000-7005	BENEFITS-EI/CPP/WSIB/EHT	5,477.76	5,600.00	2,788.78	3,266.65	2,811.22	5,600.00
01-2000-7010	BENEFITS-OMERS	0.00	0.00	2,360.75	2,887.50	2,589.25	4,950.00
01-2000-7012	MILEAGE	284.23	0.00	0.00	175.00	300.00	300.00
01-2000-7015	STAFF TRAINING/DUES, FEES, SL	1,149.12	300.00	160.00	583.35	840.00	1,000.00
01-2000-7100	OFFICE/COMPUTER SUPPLIES	2,427.87	1,700.00	1,711.36	1,166.65	288.64	2,000.00
01-2000-7110	COMMUNICATION	1,968.35	3,000.00	569.76	1,166.65	1,430.24	2,000.00
01-2000-7115	INSURANCE	12,518.16	12,200.00	6,636.54	7,758.35	6,663.46	13,300.00
01-2000-7120	HEALTH & SAFETY	1,903.36	2,800.00	60.49	1,166.65	1,939.51	2,000.00
01-2000-7125	PROF FEES - AUDIT	610.56	1,400.00	(10.56)	356.41	621.57	611.01
01-2000-7130	PROF FEES - WATER TESTING	392.81	300.00	0.00	233.35	400.00	400.00
01-2000-7150	BANK CHARGES	771.70	400.00	1,218.31	291.65	(718.31)	500.00
01-2000-7200	HYDRO	50,085.34	60,000.00	16,054.27	29,166.65	33,945.73	50,000.00
01-2000-7210	FURNACE FUEL/ PROPANE	14,711.62	12,000.00	5,875.73	8,750.00	9,124.27	15,000.00
01-2000-7220	BLDG & GROUNDS MAINTENANCE	18,293.35	20,000.00	8,040.49	10,791.65	10,459.51	18,500.00
01-2000-7230	BOOTH MAINTENANCE	1,917.94	1,300.00	295.28	1,925.00	3,004.72	3,300.00
01-2000-7240	ICE PLANT/MACH MAINTENANCE	18,153.39	12,000.00	1,287.07	10,500.00	16,712.93	18,000.00
01-2000-7300	FUNDRAISING EXPENSE	10,992.69	10,500.00	0.00	0.00	0.00	0.00
01-2000-7400	BAD DEBT	398.63	0.00	85.73	0.00	(85.73)	0.00
01-2000-7450	TSFR TO CAPITAL RESERVES	420.00	0.00	0.00	0.00	0.00	0.00
01-2000-7500	CAPITAL PURCHASES	3,768.05	15,000.00	0.00	8,750.00	15,000.00	15,000.00
01-2000-7800	AMORTIZATION	1,560.40	0.00	0.00	0.00	0.00	0.00
Total Expense		216,257.62	213,500.00	76,720.00	129,768.86	145,741.01	222,461.01
Dept Excess Revenue Over (Under) Expenditures		7,763.25	0.00	28,183.51	0.10	(28,183.51)	0.00



**General Ledger****Annual Department Budget vs. Actual Comparison Report**

Fiscal Year Ending: DEC 31,2020 - From Period 1 To Period 7 Ending JUL 31,2020

Account	Description	Previous Year Total		Current Year To Date		Budget Remaining	Total Budget
		Actual	Budget	Actual	Budget		
Category Excess Revenue Over (Under) Expenditures		7,763.25	0.00	28,183.51	0.10	(28,183.51)	0.00

**General Ledger****Annual Department Budget vs. Actual Comparison Report**

Fiscal Year Ending: DEC 31, 2020 - From Period 1 To Period 7 Ending JUL 31, 2020

Account	Description	Previous Year Total		Current Year To Date		Budget Remaining	Total Budget
		Actual	Budget	Actual	Budget		

**REPORT SUMMARY**

01-2000	INCOME STATEMENT	224,020.87	213,500.00	104,903.51	129,768.96	117,557.50	222,461.01
Fund 01	Total Revenue	224,020.87	213,500.00	104,903.51	129,768.96	117,557.50	222,461.01
01-2000	INCOME STATEMENT	216,257.62	213,500.00	76,720.00	129,768.86	145,741.01	222,461.01
Fund 01	Total Expenditure	216,257.62	213,500.00	76,720.00	129,768.86	145,741.01	222,461.01
Fund 01	Excess Revenue Over (Under) Expenditures	7,763.25	0.00	28,183.51	0.10	(28,183.51)	0.00
Report	Total Revenue	224,020.87	213,500.00	104,903.51	129,768.96	117,557.50	222,461.01
Report	Total Expenditure	216,257.62	213,500.00	76,720.00	129,768.86	145,741.01	222,461.01
Report	Excess Revenue Over (Under) Expenditures	7,763.25	0.00	28,183.51	0.10	(28,183.51)	0.00

## Donna Funston

---

**From:** Heather Boston <hboston@mulmur.ca>  
**Sent:** Friday, July 10, 2020 6:05 PM  
**To:** Donna Funston  
**Cc:** Tracey Atkinson; Denise Holmes  
**Subject:** Grants (To be Included in the Next Agenda Package)

Good Afternoon NDCC Board of Management,

As a follow up to my previous email regarding grants, I would like to share the following information including the email below from Fairtax with the Board.

While we are currently short staffed we have used Fairtax Funding & Taxation Experts in the past to assist with identifying and applying for grants. This may be an option for the Board where Fairtax could make applications for various grants on the Boards behalf. They do charge a percentage of the grant money, but some grants do allow us to include their cost in the grant application.

When the Board is ready to apply for a grant, I am happy to review the grant applications or work with the Board, Arena Manager, Fairtax, and/or the Board's consultants, so that we can have the best application possible.

Please find my contacts info below.

### LYNDA RICKARD | SENIOR FUNDING SPECIALIST

GrantMatch™ Corp.  
2265 Upper Middle Rd East, Suite 101, Oakville, ON L6H 0G5  
M: (705) 328-4344 | T: (705) 439-2567 | F: (905) 823-5696  
E: [lrickard@grantmatch.com](mailto:lrickard@grantmatch.com) | W: [www.grantmatch.com](http://www.grantmatch.com)

Heather Boston, CPA, CA, CGA, BComm | Treasurer  
Township of Mulmur | 758070 2<sup>nd</sup> Line East | Mulmur, Ontario L9V 0G8  
Phone 705-466-3341 ext. 233 | Fax 705-466-2922 | [hboston@mulmur.ca](mailto:hboston@mulmur.ca)



*This message (including attachments, if any) is intended to be confidential and solely for the addressee. If you received this e-mail in error, please delete it and advise me immediately. E-mail transmission cannot be guaranteed to be secure or error-free and the sender does not accept liability for errors or omissions.*

The Township Municipal office will be closed to the public until further notice due to COVID-19. All Council meetings will be converted to electronic meetings. All public meetings, committee/board meetings and public gatherings will be cancelled and rescheduled at a later date. The Township will continue to provide services and appreciate your patience and understanding during this time. Please see our website for more information. Please note that the Township has declared this an Emergency, and has alternative procedures in place to deal with the continuance of services and safety.

**From:** Lynda Rickard <[lrickard@fairtax.ca](mailto:lrickard@fairtax.ca)>  
**Sent:** Tuesday, June 16, 2020 9:46 AM

**To:** Heather Boston <hboston@mulmur.ca>; Tracey Atkinson <tatkinson@mulmur.ca>  
**Subject:** Funding - Capital New Build (North Dufferin Community Centre)

Hi Heather/Tracey:

The Federation of Canadian Municipalities (FCM) will fund 80% of the build through a loan/grant arrangement. However, the first step to achieve that is to have a Feasibility Study completed by your engineers. FCM will cover 50% of the cost of the study to a maximum of \$175,000.

Enabling Accessibility Fund (EAF) is also open. It is a maximum grant of \$100,000 but the start date needs to be between Sept.–Dec. 2020, and it needs to be completed before Dec 2022.

Once the budget for the building has been finalized, and we have a projected start date, we can begin a funding campaign and source other grants that can be stacked or paired. Let me know if you want to have another meeting to discuss a grant funding strategy for this project.

**LYNDA RICKARD | SENIOR FUNDING SPECIALIST**

GrantMatch™ Corp.  
2265 Upper Middle Rd East, Suite 101, Oakville, ON L6H 0G5  
M: (705) 328-4344 | T: (705) 439-2567 | F: (905) 823-5696  
E: [lrickard@grantmatch.com](mailto:lrickard@grantmatch.com) | W: [www.grantmatch.com](http://www.grantmatch.com)

*Ask me about GrantMatch, our new Incentives & Funding Platform*

This message is intended for the addressees only. It may contain confidential or privileged information. No rights to privilege have been waived. Any copying, re-transmittal, taking of action in reliance on, or other use of the information in this communication by persons other than the addressees is prohibited. If you have received this message in error, please reply to the sender by e-mail and delete or destroy all copies of this message.

## Donna Funston

---

**From:** Tracey Atkinson <tatkinson@mulmur.ca>  
**Sent:** Friday, July 10, 2020 2:56 PM  
**To:** Patty Clark; James Woods; Chester Tupling; Donna Funston; Heather Boston; John Willmetts  
**Subject:** cenotaph, grass budget, snow removal  
**Attachments:** Signed NDCC Board of Managmenet Agreement 2017.pdf

Hi Patty,

In reading the agreement, a copy of which I have attached, it would appear that the NDCC include all lands, buildings, improvements, equipment and chattels pertaining to its operation. The Fire hall is on a separate parcel.

"Mulmur is the owner of the lands identified as Con 3 W E PT Lot25, RP 7R-4424Part3, on which the facility known as the North Dufferin Community Centre ("NDCC") is located. The NDCC includes all land, buildings, improvements, equipment and chattels pertaining to its operations."

The approximate \$3000 for the fence repair along the road allowance relates to a fence that was in poor condition when the NDCC assumed responsibility, and so the Township of Mulmur agreed to pay for the cost of this item. I understand that the invoice was included with the arena board invoices, but this has since been removed. Our understanding was the NDCC was going to ask for a volunteer to fix the stone work.

Future work on the cenotaph may be Mulmur's cost, as the cenotaph may not be considered "pertaining to its operation" as per the agreement. I have copied our Director of Public Works regarding this work, and anticipated the Arena Manager and Director of Public Works to be able to determine the best way to proceed with this work and to get quotes. This item is currently not within our 2020 budget, and we anticipate it will need to be pushed to next spring.

Heather will provide a response to the inquiry regarding snow removal and grass cutting billing proportions.

If you have any questions or concerns, please do not hesitate to contact me.

Kind regards,  
Tracey

The Township Municipal office will be closed to the public until further notice due to COVID-19. All Council meetings will be converted to electronic meetings. All public meetings, committee/board meetings and public gatherings will be cancelled and rescheduled at a later date. The Township will continue to provide services and appreciate your patience and understanding during this time. Please see our website for more information. Please note that the Township has declared this an Emergency, and has alternative procedures in place to deal with the continuance of services and safety.

Tracey Atkinson, Dipl.M.M. BES MCIP RPP | C.A.O. Planner  
Township of Mulmur | 758070 2<sup>nd</sup> Line East | Mulmur, Ontario L9V 0G8  
Phone 705-466-3341 ext. 222 | Fax 705-466-2922 | [tatkinson@mulmur.ca](mailto:tatkinson@mulmur.ca)



*Information provided herein is based on the information received and to the best of our abilities. For certainty, please request a Property Information and Compliance Certificate. A fee will apply.*

*This message (including attachments, if any) is intended to be confidential and solely for the addressee. If you received this e-mail in error, please delete it and advise me immediately. E-mail transmission cannot be guaranteed to be secure or error free and the sender does not accept liability for errors or omissions.*

AGREEMENT AS OF September 7, 2017

BETWEEN:

**THE CORPORATION OF THE TOWNSHIP OF MULMUR,**  
hereinafter referred to as "Mulmur"

-and-

**THE CORPORATION OF THE TOWNSHIP OF MELANCTHON,**  
hereinafter referred to as "Melancthon"

This Agreement witnesseth that, in consideration of the mutual covenants and conditions herein contained, Mulmur and Melancthon agree to the following:

1. Mulmur is the owner of the lands identified as Con 3 W E PT Lot 25, RP 7R-4424 Part 3, on which the facility known as the North Dufferin Community Centre ("NDCC") is located. The NDCC includes all land, buildings, improvements, equipment and chattels pertaining to its operations.
2. Mulmur Township shall continue to be the sole owner of the NDCC.
3. The NDCC shall be operated in compliance with the provisions of the *Municipal Act, 2001*, SO 2001, c 25, and any applicable regulations, as amended from time to time.
4. The NDCC shall be managed by a joint municipal service board of the Townships of Mulmur and Melancthon, constituted by this agreement pursuant to s. 202 of the *Municipal Act, 2001*. The said joint municipal service board shall be known as the NDCC Board of Management ("Board"), which shall have all the powers given by the *Municipal Act, 2001*, and those given by this Agreement.
5. The Board shall have eight (8) members, all of whom have voting rights. The Board shall be comprised of one (1) member of Council from each of Mulmur and Melancthon, two (2) community members from each of Mulmur and Melancthon, and two (2) other community members-at-large. The Board shall recommend nominated candidates, drawn from community applicants to the parties. The Board members shall be appointed by both parties by resolution. In the event of a disagreement, each party shall appoint 3 community members of its choice to the Board. Nominated candidates shall serve for a term of which they are appointed. The parties shall also have the power to designate the appointed Council representatives to the Board, and may set their term on the Board, not to exceed the term of the Council on which they sit. The quorum of the Board shall be five (5).
6. No person shall be appointed as a Board member unless that person has been appointed by the parties in accordance with the previous paragraph, and has received a Criminal Records Check to the satisfaction of both parties' Councils.
7. The Board shall elect a Chairperson (Chair) and Vice-Chairperson from among its members at the first meeting of the Board each calendar year. The Chair shall preside at all meetings of the Board and be charged with the general administration of the business and affairs of the Board. The minutes of that meeting shall identify the persons elected to each of the identified positions.
8. The Board shall hold an Annual General Meeting at the call of the Chair, with due prior notice to both parties
9. The Board shall operate under the Procedural By-law of Mulmur.
10. Insurance shall be provided through Mulmur's insurance provider and the cost will be billed to the Board.
11. A staff member from Melancthon shall act as the Secretary of the Board at no cost.

12. The Treasurer of Mulmur shall act as the Treasurer of the Board at no cost. The Treasurer shall keep full and accurate books and records of all transactions of the Board. The Treasurer shall render to the Board at the meetings thereof, or whenever required, an account of all transactions and of the financial position of the Board. The Treasurer shall pay only such items as are approved by the Board.
13. It shall be the policy of the Board that the current year's operating surplus or deficit be allocated to the followings year's budget over and above a \$40,000 operating reserve maintained for cash flow purposes.
14. Each Township shall contribute \$20,000 on January 1, 2018, to create an operating reserve for the Board to utilize for cash flow purposes.
15. Commencing 2018, levies shall be paid on February 1<sup>st</sup>, May 1<sup>st</sup>, August 1<sup>st</sup> and October 1<sup>st</sup> of each year.
16. The Board will maintain a recreational capital reserve account to hold any unused capital contributions each year. This reserve will be used to absorb the impact of large purchases and/or unforeseen emergency capital requirements as approved by the Board. A report on the balance of the reserves shall be provided on an annual basis or as requested by the parties.
17. The Board shall develop other organization structure and procedural rules as may be thought desirable.
18. The Board shall have responsibility and authority, including employment contracts, for staff for both the facilities and the programs.
19. Subject to statutory restrictions and those set out in this agreement, the Board shall develop policies, rules, and fee schedules to be approved by each Township.
20. The Board shall prepare the estimate of the Board's net financial requirements for the year ("Budget"). There shall be no deficit budgeting. The Board shall work co-operatively and equitably with the parties to the Agreement to fund all operational and developmental expenses.
21. The Budget shall be submitted annually to each Township for approval no later than October 31<sup>st</sup>. The parties shall have the right to amend the Budget by mutual agreement prior to approval.
22. Upon approval of the Budget by both parties, each party shall appropriate such monies as may be requisitioned by the Board from time to time not to exceed the monies identified in the approved Budget.
23. The Board shall not make or incur liability for any expenditure that is not approved as part of its Budget, and the parties shall not be liable for any expenditure that is not approved.
24. Regardless of the source and extent of funding, the Board must approve all development and improvements.
25. The parties shall be responsible for the approved operating and capital levies expenditures and any deficit of the Board as follows:

Mulmur 50%

Melancthon 50%
26. The Board shall keep books and records, approve expenditures and issue cheques in accordance with the Budget.
  - a. The Board shall maintain its own separate bank account.
  - b. All accounts to be paid shall be approved by the Board (this may occur after payment has happened in order to avoid late payment fees).



- c. All cheques shall be signed by the Chair or designate and the Treasurer or designate of the Board.
  - d. The Board's accounts shall be audited annually by the Municipal auditor or more frequently as may be required by the Board.
  - e. The draft minutes of the Board shall be promptly circulated to the respective municipal Councils.
27. In the event that either Mulmur or Melancthon wishes to cease participating in the Board, they may do so by providing one (1) year written notice of termination to the other party and the Board. Any written notice given as aforesaid shall terminate this Agreement as of the 31<sup>st</sup> of December of the next calendar year.
28. The parties shall renegotiate this agreement in the event that an additional municipality or other permitted party wishes to join in this agreement and is approved by all parties to this agreement.
29. This Agreement is personal to the parties and may not be assigned.
30. The parties covenant that they are entering into this Agreement in good faith and that they shall carry out its provisions in good faith.
31. All previous agreements signed are hereby null and void.

In WITNESS WHEREOF each of the parties hereto has affixed its corporate seal attested to by the proper officers duly authorized in that behalf;

SIGNED, SEALED AND DELIVERED  
in the presence of:

THE CORPORATION OF THE  
TOWNSHIP OF MULMUR

Deputy Earl Hawkins  
MAYOR

Darryl Hauer  
CLERK

THE CORPORATION OF THE  
TOWNSHIP OF MELANCTHON

[Signature]  
MAYOR

Dennis A. Palmer  
CLERK



BURNSIDE



## Community Energy Plan

Volume 3  
North Dufferin Community  
Centre, Honeywood Arena  
Energy Audit Report

Township of Mulmur

June 2020

**North Dufferin Community Centre  
(Honeywood Arena)  
CEP Volume 3: Energy Audit Report**

**Township of Mulmur  
758070 2 Line East  
Mulmur, ON L9V 0G8**

**R.J. Burnside & Associates Limited  
15 Townline  
Orangeville ON L9W 3R4 CANADA**

**June 2020  
300041822.0000**



**Distribution List**

No. of Hard Copies	PDF	Email	Organization Name
-	Yes	Yes	Initial Draft Submission to Township of Mulmur

**Record of Revisions**


Revision	Date	Description
-	December 6, 2019	Initial Draft Submission to Township of Mulmur
	June 5, 2020	Final Submission to Township of Mulmur

**R.J. Burnside & Associates Limited**

Report Prepared By:

Spencer Brown, P.Eng., C.E.A.  
Project Engineer  
SB:klPeter Mensinga, M.A.Sc., P.Eng.  
Manager, Building Restoration  
PM:kl

Report Reviewed By:

Dominic Garisto, C.E.T., LET  
Mechanical Technologist  
DG:klLyle Parsons, B.E.S.  
Vice President Environment  
LP:kl

## Executive Summary

### Introduction: Project Scope, Objective and Strategies

R.J. Burnside & Associates Limited (Burnside) was engaged by the Township of Mulmur (Mulumur) to develop a Community Energy Plan (CEP). As part of that CEP a number of demonstration projects were included to show the benefits of energy conservation. This particular component of the study was to conduct an Energy Audit (EA) of the North Dufferin Community Center building in Honeywood. Its address is 706114 County Rd 21, Mulmur, ON, L0N1H0. These kind of EAs can be conducted at any building and are case specific to the buildings being assessed.

Fourteen separate Energy Efficiency Measures (EEMs) were identified with implementation costs and annual energy savings estimates. Eight Energy Efficiency Measures (EEMs) recommendations were identified with implementation costs and annual energy savings estimates. The annualized savings of all recommendations totals \$21,996.00 (at projected energy prices). If fully implemented, the average weighted payback period from annual energy savings for these EEMs is estimated to be 8.0 years, and simple payback 5.4 years. A significant reduction in electricity and fuel usage would be achieved if recommendations were implemented. Details are outlined in the tables below.

**Table 1: North Dufferin Community Centre Energy Efficiency Recommendations**

EEM No.	Energy Efficiency Measure	Measure Type	Approx. Annual Savings	Net Estimated Costs	Simple Payback Years
1	LED Lighting – Interior Lights	Upgrade Building Systems	\$216.00	\$1,105.00	5.1
2	LED Lighting – Exterior Parking Lot Lights	Upgrade Building Systems	\$160.00	\$790.00	4.9
3	Install Programmable Thermostats	Upgrade Building Systems	\$750.00	\$400.00	0.5
4	Building Envelope Analysis – Roof Insulation	Upgrade Building Envelope	\$1,780.00	\$8,500.00	4.8
7	Water Conservation -Low Flow Fixtures	Upgrade Building Systems	\$490.00	\$1,800.00	3.7
10	New Zamboni Hot Water System	Upgrade Building Systems	\$1,165.00	\$8,000.00	6.9
12	DDC Controller	Upgrade Building Systems	\$5,000.00	\$41,154.00	8.2
14	Rooftop Solar	Renewable Technology	\$12,435.00	\$114,375.00	9.2
<b>Totals</b>			<b>\$21,996.00</b>	<b>\$176,124.00</b>	<b>5.4</b>

**Table 2: Summary of Utility Reductions from Recommendations**

	Electricity	Oil	GHG Reduction
	kWh	L	MTCDE
Total 2017/2018 Utility Consumptions	300,000	18,221	49
Percentage Reduction in Utility Consumption	90%	24%	24%
Total Projected Utility Consumptions	31,274	13,824	37

**Results and Recommendations with Climate Action Incentive Fund (CAIF)**

There is a program expected to be announced from the Federal government to provide incentives to Municipalities for energy efficiency and renewable energy projects. A similar program for private businesses was operational in 2019 providing 25% incentive on capital costs. With the capital incentive one additional measure was recommended for a total of nine measures, and overall paybacks were reduced. The tables below outline the revised paybacks for projects, should this program be launched.

The annualized savings of all recommendations with the CAIF Incentive totals \$25,706.00 (at projected energy prices). Details are outlined in the tables below. There could be further funding available from programs like FCM's Green Municipal Fund Capital Project: Retrofit of Municipal Facilities.

**Table 3: North Dufferin Community Centre Energy Efficiency Recommendations with CAIF Funding**

EEM No.	Energy Efficiency Measure	Measure Type	Approx. Annual Savings	CAIF Incentive	Net Estimated Costs	Simple Payback Years
1	LED Lighting – Interior Lights	Upgrade Building Systems	\$216.00	\$374.00	\$731.00	3.4
2	LED Lighting – Exterior Parking Lot Lights	Upgrade Building Systems	\$160.00	\$223.00	\$568.00	3.5
3	Install Programmable Thermostats	Upgrade Building Systems	\$750.00	\$100.00	\$300.00	0.4
4	Building Envelope Analysis – Roof Insulation	Upgrade Building Envelope	\$1,780.00	\$2,125.00	\$6,375.00	3.6
7	Water Conservation -Low Flow Fixtures	Upgrade Building Systems	\$490.00	\$450.00	\$1,350.00	2.8
10	New Zamboni Hot Water System	Upgrade Building Systems	\$1,165.00	\$2,000.00	\$6,000.00	5.2
11	Desuperheater	Upgrade Building Systems	\$3,710.00	\$10,625.00	\$31,875.00	8.6
12	DDC Controller	Upgrade Building Systems	\$5,000.00	\$11,250	\$29,904	6.0
14	Rooftop Solar	Renewable Technology	\$12,435.00	\$28,594.00	\$85,781.00	6.9
<b>Totals</b>			<b>\$25,706.00</b>	<b>\$55,740.00</b>	<b>\$162,884.00</b>	<b>4.5</b>

Note: Simple payback is an average of all projects



### **Energy Audit Strategies and Methods**

This report review includes all the energy and estimated cost saving measures as follows with regards to both functionality and code upgrades:

- Building Automation Systems (BAS);
- Boilers, furnaces, heaters;
- Toilet and fixture replacement;
- LED lighting;
- Roof insulation;
- Rooftop solar; and
- Heat Recovery.

The energy audit method was broken down into four phases which are described as follows:

#### **Baseline Development**

Gathering all pertinent data: billing information histories, drawings, specifications, engineering report, conduct site visit and interview building operators, generate equipment list and identify potential energy saving measures. Interview with building operators, generate equipment list and conduct site inspection for individual system to identify the potential energy saving measures.

#### **Analysis and Energy Efficiency Measures (EEMs)**

Collect all historic data for utility and energy consumption simulation, and building assessment report(s), drawings and other related information (provided by the Township). Provide an analysis of potential Energy Efficiency Measures for conventional and renewable energy technologies, taking into consideration of the building behavior, operational schedule changes and deficiencies. Review and calculation energy consumption before and after a potential retrofit.

#### **Draft and Final Report**

Produce the draft energy audit report and for the North Dufferin Community Centre review and incorporate comments and suggestion for the final report.

Table 4: North Dufferin Community Centre Energy Efficiency Details

EEM	Measure Category	Measure Type	Energy Efficiency Measure	Electricity	Oil	GHG Reduction	Total Savings per Year	Original Cost	Incentives	Net Costs	Cost (\$) / MTCDE	Simple Payback w/Incentives Years
				kWh	L	MTCDE						
1	No-Cost/Low-Cost	Upgrade Building Systems	EEM 1 - LED Lighting – Interior Lights	1,300	0	0	\$216.00	\$1,495.00	\$390.00	\$1,105.00	\$0.00	5.1
2	No-Cost/Low-Cost	Upgrade Building Systems	EEM 2 - LED Lighting – Exterior Parking Lot Lights	964	0	0	\$160.00	\$890.00	\$100.00	\$790.00	\$0.00	4.9
3	Capital Investment	Upgrade Building Systems	EEM 3 - Install Programmable Thermostats	0	1000	3	\$750.00	\$400.00	\$0.00	\$400.00	\$0.00	0.5
4	Capital Investment	Upgrade Building Envelope	EEM 4 – Building Envelope Analysis – Roof Insulation	0	2144	6	\$1,780.00	\$8,500.00	\$0.00	\$8,500.00	\$1,485.00	4.8
5	Capital Investment	Upgrade Building Envelope	EEM 5 – Building Envelope Analysis – New Doors	0	136	0	\$103.00	\$1,500.00	\$0.00	\$1,500.00	\$4,131.00	14.6
6	Capital Investment	Upgrade Building Envelope	EEM 6 – Building Envelope Analysis – New Windows	0	1075	3	\$806.00	\$38,000.00	\$0.00	\$38,000.00	\$13,239.00	47.1
7	Capital Investment	Upgrade Building Systems	EEM 7 – Water Conservation -Low Flow Fixtures	0	571	2	\$490.00	\$1,800.00	\$0.00	\$1,800.00	\$1,181.00	3.7
8	Capital Investment	Upgrade Building Systems	EEM 8 – Upgrade Furnace to Higher Efficiency	0	125	0	\$104.00	\$7,000.00	\$0.00	\$7,000.00	\$20,974.00	67.5
9	Capital Investment	Upgrade Building Systems	EEM 9 - Drain Water Heat Recovery	0	367	1	\$304.00	\$4,500.00	\$0.00	\$4,500.00	\$4,592.00	14.8
10	Capital Investment	Upgrade Building Systems	EEM 10 New Zamboni Hot Water System	0	682	2	\$1,165.00	\$8,000.00	\$0.00	\$8,000.00	\$4,393.00	6.9
11	Capital Investment	Upgrade Building Systems	EEM11 Desuperheater	0	4,470	12	\$3,710.00	\$42,500.00	\$0.00	\$42,500.00	\$3,561.00	11.5
12	Capital Investment	Upgrade Building Systems	EEM12 DDC Controller	38,462	0	0	\$5,000	\$45,000	\$3,846	\$41,154	\$0	8.2
13	Capital Investment	Upgrade Building Systems	EEM13 Electric Desiccant Humidifier	19,231	0	0	\$2,500	\$40,000	\$1,923	\$38,077	\$0	15.2
14	Capital Investment	Renewable Technology	EEM14 Rooftop Solar	228,000	0	0	\$12,435.00	\$114,375.00	\$0.00	\$114,375.00	\$0.00	9.2



**Table 5: Glossary of Terms**

Term	Description
Watt (W)	Unit of Power in Joules/s.
Kilowatt (kW)	1000 Watts
Megawatt (MW)	1000 kilowatts
ekWh	Equivalent Kilo-watt hours, standard unit of energy consumption to compare energy sources.
Watt-hour (Wh)	A measure of power over time – 1 Wh is 1W power consumption over 1 hour.
Kilowatt hour (kWh)	1000 Wh
Megawatt Hour (MWh)	1000 kWh
British Thermal Unit (BTU)	A measure of energy.
kBTU	One thousand BTUs.
m <sup>3</sup>	Meter cubed, a unit of volume.
ECI	The Energy Cost Index (ECI) of the building (expressed in dollars per floor area per year).
GHG	Green house fuel oil.
Source EUI	The Energy Utilization Index (EUI) of the Source (expressed in kBtu/ft <sup>2</sup> [MJ/m <sup>2</sup> ] per year).
Site EUI	The Energy Utilization Index (EUI) of the Site (expressed in kBtu/ft <sup>2</sup> [MJ/m <sup>2</sup> ] per year).
Demand Charge	Charge from Hydro distribution companies based on the capacity amount allocated to your building.
Peak Demand	The largest power consumption for a system, usually over a 1 year time period.
EEM	Energy Efficiency Measure.
ECM	Energy Conservation Measure.
Blended Rate	A rate \$/kWh for electricity including demand charges, regulatory charges, supply charges, global adjustment, and taxes.
Heating Degree Day (HDD)	The number of degrees that a day's average temperature is below 18 degrees Celsius.
Net Present Value (NPV)	The value of all the future cash flows added up and multiplied with the discount rate.
Discount Rate	Often considered the hurdle rate this is the rate which an entity can receive on other investments. A discount rate is used to discount future cash flows to measure project risk.
Simple Payback	The time in years it takes to recoup an initial capital investment. Comparing paybacks of different investments provides a good way to make financial decisions.
Return on Investment (ROI)	The ROI is the net profit of an investment divided by the capital cost. Comparing ROI's of different investments provides a good way to make financial decisions.

**Table of Contents**

<b>1.0</b>	<b>Energy Utility Analysis .....</b>	<b>11</b>
1.1	Audit Scope and Methodology .....	11
1.1.1	Preliminary Analysis .....	11
1.1.2	Audit Site Investigation .....	11
1.1.3	Water Consumption Review .....	11
1.2	Description of the Site and Building .....	11
1.3	Preliminary End Use Analysis .....	13
1.3.1	Billing Data Review .....	13
1.3.2	Fuel Oil Rates .....	14
1.3.3	Propane Rates .....	14
1.3.4	Water Rates .....	14
1.3.5	Monthly Energy Usage .....	14
1.3.6	Fuel Oil Adjusted Baseline for Heating .....	18
1.3.7	Electricity Adjusted Baseline .....	18
1.3.8	Breakdown of Energy Charges and Consumption .....	19
1.3.9	End Use Breakdown .....	20
1.3.10	Energy Benchmark .....	21
<b>2.0</b>	<b>Building Envelope .....</b>	<b>22</b>
2.1	Exterior Cladding System .....	22
2.2	Roofing .....	24
<b>3.0</b>	<b>Building Systems .....</b>	<b>26</b>
3.1	Lighting Systems .....	26
3.1.1	Interior Lighting .....	26
3.1.2	Exterior Lighting .....	28
3.2	Mechanical Systems .....	28
3.2.1	HVAC System .....	28
3.2.2	Plumbing and Fixtures .....	29
3.2.3	Domestic Hot Water .....	31
3.2.4	Zamboni Hot Water .....	31
3.2.5	Ice Refrigeration System .....	32
<b>4.0</b>	<b>Occupancy Schedule .....</b>	<b>33</b>
<b>5.0</b>	<b>Energy Efficiency Measures .....</b>	<b>34</b>
5.1	No-Cost/Low-Cost Measures .....	34
5.1.1	EEM 1 – Interior Lighting Analysis – LED Lighting .....	35
5.1.2	EEM 2 – Exterior Parking Lot Lights - LED Lighting .....	35
5.1.3	EEM 3 – Programmable Thermostats .....	36
5.2	Capital Investment Measures .....	37
5.2.1	EEM 4 – Building Envelope Analysis – Roof Insulation .....	37
5.2.2	EEM 5 – Building Envelope Analysis – New Doors .....	37
5.2.3	EEM 6 – Building Envelope Analysis – New Windows .....	37
5.2.4	EEM 7 – Water Conservation – Low Flow Fixtures .....	38
5.2.5	EEM 8 – Upgrade Furnace to Higher Efficiency Furnace .....	38
5.2.6	EEM 9 – Drain Water Heat Recovery .....	39
5.2.7	EEM 10 – New Zamboni Hot Water System .....	40

5.2.8	EEM 11 – Desuperheater - Heat Recovery .....	40
5.2.9	EEM 12 – DDC Controller on Refrigeration System .....	41
5.2.10	EEM 13 – Electric Desiccant Dehumidifier .....	41
5.3	Distributed Generation/Renewable Energy Measures .....	42
5.3.1	EEM 14 – Rooftop Solar with Net Metering Connections .....	42
6.0	Incentive Programs .....	43
6.1	Climate Action Initiative Fund .....	43
6.2	EEMs Recommended with CAIF .....	44
6.3	FCM Retrofit of Municipal Facilities .....	45
7.0	Summary .....	45

## Tables

Table 1:	North Dufferin Community Centre Energy Efficiency Recommendations .....	2
Table 2:	Summary of Utility Reductions from Recommendations .....	2
Table 3:	North Dufferin Community Centre Energy Efficiency Recommendations with CAIF Funding .....	3
Table 4:	North Dufferin Community Centre Energy Efficiency Details .....	5
Table 5:	Glossary of Terms .....	6
Table 6:	North Dufferin Community Centre Building Information .....	11
Table 7:	North Dufferin Community Centre Electricity Charges .....	13
Table 8:	Hydro One Charges General Service Greater than 50 kW .....	14
Table 9:	Fuel Oil Charges .....	14
Table 10:	North Dufferin Community Centre Electricity Consumption Summary .....	15
Table 11:	Average m <sup>3</sup> Consumption Per HDD .....	18
Table 12:	Adjusted Fuel oil Use Baseline .....	18
Table 13:	Combined kWh Breakdown for North Dufferin Community Centre .....	20
Table 14:	Occupancy Schedule .....	34
Table 15:	North Dufferin Community Centre Energy Efficiency Recommendations with CAIF Funding .....	44
Table 16:	North Dufferin Community Centre Energy Efficiency Recommendations .....	45
Table 17:	North Dufferin Community Centre EEMs not Recommended .....	46
Table 18:	Summary of Utility Reductions for Recommendations .....	46

## Figures

Figure 1:	North Dufferin Community Centre 2016-2018 Hydro Usage .....	16
Figure 2:	North Dufferin Community Centre 2016-2018 Fuel Oil Usage .....	16
Figure 3:	North Dufferin Community Centre 2016-2018 Estimated Propane Usage .....	17
Figure 4:	North Dufferin Community Centre 2016-2018 Estimated Fuel Usage .....	17
Figure 5:	North Dufferin Community Centre 2018 Total Energy Usage (kWh) .....	19
Figure 6:	North Dufferin Community Centre Total Energy Cost 2016 to 2017 .....	19
Figure 7:	Total kWh by End Use for North Dufferin Community Centre .....	21
Figure 8:	Total ekWh/ft <sup>2</sup> by End Use for North Dufferin Community Centre .....	22
Figure 9:	North Dufferin Community Centre Exterior Wall Assembly .....	23
Figure 10:	Common Area Window .....	23
Figure 11:	Common Area Single Pane Window to Unheated Arena .....	24
Figure 12:	Roof Over Rink .....	25

CEP Volume 3: Energy Audit Report  
June 2020

Figure 13: Changeroom Lighting Example .....	26
Figure 14: Rink Lighting .....	27
Figure 15: Auditorium Lighting .....	27
Figure 16: HPS Parking Lot Lights.....	28
Figure 17: LED Parking Lot Lights .....	28
Figure 18: Common Area Oil Furnaces .....	29
Figure 19: Typical Changeroom.....	30
Figure 20: Typical Sink Fixtures.....	30
Figure 21: Domestic Hot Water Tank.....	31
Figure 22: Zamboni Hot Water Storage Tank .....	32
Figure 23: Zamboni Hot Water Heating Tank and Electrical Heating Wall Mount .....	32
Figure 24: Ice Plant Compressors .....	33
Figure 25: Ice Plant.....	33
Figure 26: Drain Water Heat Recovery System.....	39

**Appendices**

Appendix A Data

Appendix B Calculations

Appendix C Benchmark Report

Appendix D Drawings

**Disclaimer**

Other than by the addressee, copying or distribution of this document, in whole or in part, is not permitted without the express written consent of R.J. Burnside & Associates Limited.

In the preparation of the various instruments of service contained herein, R.J. Burnside & Associates Limited was required to use and rely upon various sources of information (including but not limited to: reports, data, drawings, observations) produced by parties other than R.J. Burnside & Associates Limited. For its part R.J. Burnside & Associates Limited has proceeded based on the belief that the third party/parties in question produced this documentation using accepted industry standards and best practices and that all information was therefore accurate, correct and free of errors at the time of consultation. As such, the comments, recommendations and materials presented in this instrument of service reflect our best judgment in light of the information available at the time of preparation. R.J. Burnside & Associates Limited, its employees, affiliates and subcontractors accept no liability for inaccuracies or errors in the instruments of service provided to the client, arising from deficiencies in the aforementioned third-party materials and documents. Furthermore, energy savings projections, cost estimates and payback periods are estimates and could vary when implemented.

R.J. Burnside & Associates Limited makes no warranties, either express or implied, of merchantability and fitness of the documents and other instruments of service for any purpose other than that specified by the contract.

## 1.0 Energy Utility Analysis

### 1.1 Audit Scope and Methodology

R.J. Burnside & Associates Limited (Burnside) conducted a site visit at the North Dufferin Community Centre on July 1, 2019. Following the site visit, analysis was performed by Burnside and included a review of mechanical, electrical, building sciences, energy modelling, and renewable energy. Included in the analysis was a preliminary end use analysis, energy audit, and water consumption review. A review of safety features such as ammonia monitoring equipment was not included in this review.

#### 1.1.1 Preliminary Analysis

The preliminary analysis precedes an audit of a building. During the preliminary analysis the historic utility use, peak demand, and cost were analyzed. A comparison of electricity usage to similar buildings, where available (including the source, size and date of the sample) was completed. Monthly energy use and peak demand was reviewed to identify efficiency or behavioral modification opportunities. Sequence of operations reports, floor plan, mechanical, electrical, architectural, and structural drawings for each of the buildings that were received were reviewed.

#### 1.1.2 Audit Site Investigation

During the site investigation a description of the physical characteristics of the facility, as well as its current condition, state of repair and maintenance, approximate date of last major renovation, age and construction type were reviewed. The major existing electricity-using equipment including lighting, main sources of heating and cooling, their energy consumption and fuel type as well as the manufacturer, model number, age, physical condition and estimated remaining years of service were noted.

#### 1.1.3 Water Consumption Review

The water closets and faucets are manually operated and have not been fully retrofitted to low-flow fixtures. They may be consuming significant amounts of water, typically 6 Litres per flush (LPF) for toilet and 5.7 liters per minute (LPM) for lavatory faucet respectively. No significant water leakage is identified per building operator. An estimate of the base case of water consumption calibrated to annual water bills was completed.

## 1.2 Description of the Site and Building

**Table 6: North Dufferin Community Centre Building Information**

Address	706114 Regional Road 21, Mulmur, ON
Building Type	Recreation Facility
Height	Two Floors Above Grade
Parking Description	Outdoor parking spaces
Building Construction Type	Concrete and Wood
Year Constructed	1965
Gross Floor Area (GFA)	27,724 sq. ft.



**Building Energy Audit Summary**

The following items highlight the key observations of the Energy Audit by subject area.

<b>Energy Audit:</b>	<b>North Dufferin Community Centre</b>
<b>Year of Construction</b>	1965
<b>General Description</b>	The North Dufferin Community Center is an arena, with a two-story community centre complete with an ice rink, auditorium, canteen, changerooms, and viewing area. There are 4 changerooms, and 2 smaller changerooms, 2 male and 2 female washrooms. There is a community hall and stage on the 2nd floor above the foyer overlooking the arena. There are 2 main entrances both on the west side of the building. The parking lot is on the west side of the building, shared in part with the fire hall to the north. The building is generally occupied from September when ice making ramps up until the end of April with the facility being used sparingly for special events in the summer.
<b>Building Envelope</b>	Exterior walls are composed of metal siding over insulation and a concrete block back-up wall. Windows are composed of two sets of single pane glazing in metal frames. The Community Centre portion of the building is protected with a flat roof overtop an insulated attic space. The ice rink's is protected by an uninsulated, sloped metal roof with a urethane foam coating to reduce leakage.
<b>Heating, Domestic Hot Water, and Zamboni Hot Water Systems</b>	The domestic hot water heating consists of 1 John Wood oil-fired tank. Common areas at the front of the arena are heated with 2 oil furnaces and duct work to heat the areas. An electric heater is used at the back maintenance and Zamboni area in the wintertime. The Zamboni Hot Water heating consists of an oil-fired hot water tank that is pumped into an insulated holding tank. The holding tank is circulated by a Grundfos pump and the insulated water heater is kept hot by electrical resistance heating.
<b>Cooling System</b>	The building doesn't have central cooling system.
<b>Dehumidification System</b>	The building contains 2 dehumidifiers at opposite corners of the rink.
<b>Ventilation System</b>	The building is equipped with 2 make-up air unit (MUA) with indirect fuel oil-fired heaters to supply conditioned (heating only) fresh air in heating season to the common areas in the foyer and the auditorium.
<b>Lighting System</b>	<b>Interior Lighting:</b> Most common area lighting on the 1st level including the foyer, front entrance, canteen, changerooms, bathrooms, front entrance, hallways, laundry and stair ways has been converted to electronic ballasts and LED tubes. It is estimated about 75% of lights have been switched to LED. However, some areas are still using fluorescent bulbs so there is still an opportunity for savings by implementing a complete conversion.

	<b>Exterior Lighting:</b> Consists of 2 mounted 50 w LED fixtures on front face of building, 1 High-Pressure Sodium (HPS) fixtures on a hydro pole, 1 HPS fixture on the exterior wall and 3 wall-mounted LED fixtures. These exterior lights provide lighting to the building and parking area.
<b>Building Automation System (BAS)</b>	There is currently no BAS system in operation.

### 1.3 Preliminary End Use Analysis

#### 1.3.1 Billing Data Review

Consumption data for 2016 to 2018 was reviewed for Propane, Fuel oil and Electricity. Water bills and consumption for the last year were also reviewed. The following section describes the various charges and consumption related data and discusses trends in the data and opportunities for recommending Energy Efficiency Measures (EEM).

##### 1.3.1.1 Electricity Rates

**Table 7: North Dufferin Community Centre Electricity Charges**

Charge	Supplier	Current Cost	Forecast Cost c/kwh
Base Electricity Price	Hydro One	2.430	3.013
Global Adjustment	OEB	9.318	11.555
Delivery	Hydro One	0.127	0.157
Regulatory Charges	OEB	0.004	0.005
Debt Retirement Charge	OEB	0.007	0.008
H.S.T.		13%	13%
<b>Total Cost</b>		<b>13.43</b>	<b>16.65</b>

Electricity rates vary with the Ontario electricity market. Mulmur is currently purchasing energy at an average cost of 2.43 c/kWh. The global adjustment rate varies every month and is difficult to predict a rate going forward. Due to Ontario's Fair Hydro Plan the global adjustment was been reduced. This credit is assumed to continue for the foreseeable future. The global adjustment charge over the past year is currently \$9.32 c/kWh; however, electricity rates are expected to increase. Assuming an average rate of increase of 4% the average increase over the next 10 years is 24%. Therefore, multiplying the current cost by 24% yields a forecasted cost of \$16.65 kwh.



**Table 8: Hydro One Charges General Service Greater than 50 kW**

Item	Rates	Unit of Measure	Rate as of Jan 1, 2019
Electricity	RPP – Tiered Rate, Spot Market or Weighted Average Spot Market	Per kWh*	
Delivery	Fixed Monthly Charge	Per Month	\$89.48
	Distribution Volume Charge	Per kW	\$16.0236
	Transmission Network Charge	Per kW	\$1.6048
	Transmission Connection Charge	Per kW	\$1.0743
	Line Loss Adjustment Factor		\$1.061
Regulatory	Wholesale Market Service Charge	Per kWh*	\$0.0030
	Rural Rate Protection Charge	Per kWh*	\$0.0005
	SSS Administration Charge	Per Month	\$0.25

**1.3.2 Fuel Oil Rates****Table 9: Fuel Oil Charges**

Description	Charge c/L
Average Cost for 2016	63.1
Average Cost for 2017	76.1
Average Cost for 2018	88.0

Current Cost of Fuel Oil 83 c/L.

**1.3.3 Propane Rates**

Current Cost of Propane .49 c/L.

**1.3.4 Water Rates**


There is no municipal water at North Dufferin Community Centre. Groundwater is pumped from a well onsite.

**1.3.5 Monthly Energy Usage**


Monthly energy data was received from Mulmur. Below in Table 11 Hydro and Fuel consumption tables are shown. The total for Hydro is averaging approximately 330,000 kWh per year for 2016 to 2018. Total fuel oil usage averages approximately 12,000 L per year for 2016 to 2018. Total Propane usage averages approximately 6400 L per year.

**Table 10: North Dufferin Community Centre Electricity Consumption Summary**

North Dufferin Community Centre - Utilities Summary													
Year Over Year Hydro consumption in kWh:													
	July	August	September	October	November	December	January	February	March	April	May	June	Total
<b>2016</b>	9,878	8,145	12,122	55,976	43,820	43,560	53,703	44,870	44,597	29,003	16,762	10,167	<b>372,603</b>
<b>2017</b>	2,228	2,090	7,924	49,805	43,825	44,600	47,558	46,909	42,451	24,154	5,398	1,544	<b>318,486</b>
<b>2018</b>	3,760	1,320	20,381	52,373	43,140	46,680	37,129	33,126	37,440	20,121	1,507	1,940	<b>298,917</b>


**Figure 1: North Dufferin Community Centre 2016-2018 Hydro Usage**

Electricity usage goes up significantly in the winter months as the ice rink is in full operation. The highest usage being in October when ice is being made, and high through November to March when the ice is being used extensively. The total kWh usage in 2018 was approximately 300,000 kWh which is less than 2016, 2017 and the average of the 3 years. This reduction is assumed to be due in large part to the replacement of lighting within the arena to LED. No other large changes in use have been identified during the audit. The average kWh usage per month in 2018 was approximately 24,910 kWh.

**Figure 2: North Dufferin Community Centre 2016-2018 Fuel Oil Usage**


The amount of fuel oil varies year by year and month by month. Fuel oil consumption increases in the winter as fuel oil provides the main source of heat. The average amount of fuel per year is around 12,000 L.

**Figure 3: North Dufferin Community Centre 2016-2018 Estimated Propane Usage**



The amount of propane varies year by year and month by month. Propane is used to operate the Zamboni as well as the cooking equipment in the canteen. The average amount of propane used per year is around 6,400 L.

**Figure 4: North Dufferin Community Centre 2016-2018 Estimated Fuel Usage**



The amount of propane and fuel oil varies year by year and month by month, however the total fuel use over 2016-2018 has remained fairly constant. The total L of fuel usage has ranged from approximately 17,500 in 2016 to 19,400 in 2018 for an average amount of approximately 18,500 L.

### 1.3.6 Fuel Oil Adjusted Baseline for Heating

The average fuel oil consumption from 2016 to 2018 is 12,065 L. Using 2016 to 2018 data, the heating load can be correlated to Heating Degree Data (HDD) to determine the adjusted baseline for an average year. Taking the total fuel and dividing by the heating degree days (HDD) per year gives an average m<sup>3</sup> fuel oil used per HDD as shown in Table 11

**Table 11: Average m<sup>3</sup> Consumption Per HDD**

Year	Total Fuel Oil (L)	HDD	L/HDD
2016	12841	3,588	3.58
2017	9234	3,734	2.47
2018	14121	4,018	3.51

The average L/HDD can be multiplied by the average HDD per year, which for Mulmur in the last 10 years is approximately 3,855<sup>1</sup>. This results in 12,293 L which is the fuel oil consumption that would be used in an average year. This can be used as the fuel oil consumption baseline.



**Table 12: Adjusted Fuel oil Use Baseline**

HDD Average	L/HDD	Adjusted Average Fuel Oil (L)
3,855	3.2	12,293

### 1.3.7 Electricity Adjusted Baseline

The average kWh usage for North Dufferin Community Centre over the last 3 years is 330,002 kWh per year. However, the 2018 performance is likely more indicative of future performance. Occupancy is assumed to have remained constant for the time-period of analysis. Approximately 50% of common areas have been retrofitted to LED; as well as the arena area significantly reducing electricity and total energy consumption. The 2018 usage was 298,917 kWh therefore an approximation of the 2018 electricity usage of 300,000 kWh will be carried forward as the electricity baseline usage.

<sup>1</sup> Environment and Climate Change Canada "Collingwood Historical Heating Degree Days". November 22, 2017. Accessed November 22, 2017. <https://sarnia.weatherstats.ca/metrics/hdd.html>

**1.3.8 Breakdown of Energy Charges and Consumption****Figure 5: North Dufferin Community Centre 2018 Total Energy Usage (kWh)****Figure 6: North Dufferin Community Centre Total Energy Cost 2016 to 2017**


**1.3.9 End Use Breakdown**

An end use breakdown for all the different uses within the building was estimated and calibrated to the actual usage from the energy bills.

**Table 13: Combined kWh Breakdown for North Dufferin Community Centre**

End Use	Input Energy Units		Combined Energy Use	
	Electric	Fuel Oil/Propane		
	kWh	kWh	kWh	Percent
Appliances + Canteen	24000	5000	29,000	6%
Space Heating	15000	72000	87,000	18%
Fans	10000		10,000	2%
Lighting - Exterior	2500		2,500	1%
Lighting - Interior	12000		12,000	3%
Pumps + Ventilation + Dehumidification	50000		50,000	11%
Zamboni Hot Water	3500	55000	58,500	12%
Domestic Hot Water	1000		1,000	0%
Ice Plant	170000		170,000	36%
Well & Septic Pump	2000		2,000	0%
Zamboni & Canteen Propane		40312	40,312	9%
Plug Loads	10000		10,000	2%
<b>Total Estimated</b>	<b>300,000</b>	<b>172,312</b>	<b>472,312</b>	<b>100%</b>
<b>Historical Billing</b>	<b>300,000</b>	<b>172,000</b>	<b>472,000</b>	
<b>Percent of Actual</b>	<b>100.0%</b>	<b>100.2%</b>	<b>100.1%</b>	
<b>Total per ft^2</b>	<b>11.5</b>	<b>6.6</b>	<b>18.0</b>	




**Figure 7: Total kWh by End Use for North Dufferin Community Centre**

### 1.3.10 Energy Benchmark

An energy benchmark is important to compare building usage to similar buildings as well as comparing current usage to past usage. It is an effective way to identify poorly performing buildings, and to establish a baseline for measuring improvement in energy consumptions for all buildings<sup>2</sup>. A rating has been determined from energy star portfolio manager for North Dufferin Community Centre from details about the buildings, utility bills, and regional and climate data. In Appendix A the score of 86 is shown. This means that the arena is operating in the 86th percentile, compared to other buildings, which means it is operating well. Furthermore, some local data was used to benchmark the building against other local arenas. In Figure 8 summary table is below and a copy of the analysis is in Appendix B.

<sup>2</sup> Natural Resources Canada "Energy benchmarking: the basics", Government of Canada June 09, 2017, Accessed November 10, 2017. <http://www.nrcan.gc.ca/energy/efficiency/buildings/energy-benchmarking/building/18260#details-panel20>



**Figure 8: Total ekWh/ft<sup>2</sup> by End Use for North Dufferin Community Centre**

Per Survey of Energy Consumption of Arenas 2014<sup>3</sup>, the Energy Use Index (EUI) Benchmark for similar buildings is 29.9 ekWh/ft<sup>2</sup>. The EUI for North Dufferin Community Centre in 2016 was 21.3 ekWh/ft<sup>2</sup>. Benchmarking analysis indicates that North Dufferin Community Centre is operating better than average and is in the first quartile relative to the energy efficiency benchmark window. Although, it is operating at a higher energy intensity than Hillsburgh Arena<sup>4</sup>. Currently the Community Centre is operating well from an energy efficiency perspective, however there are still opportunities for energy efficiency, and renewable generation within the arena.

## 2.0 Building Envelope

### 2.1 Exterior Cladding System

The building's exterior walls generally consist of a concrete block back-up wall with insulation and metal siding outboard of it. Based on the depth of the window flashing we estimate that insulation is between 100 to 125 mm thick, however destructive openings to confirm the actual thickness were outside the scope of our review.

The windows generally consist of two, single pane operable (horizontal sliding) and fixed windows. The windows appear to be approximately 30 years old and are nearing the end of their service life. The windows separating the Community Centre to the ice rink are single pane in metal frames.

<sup>3</sup> <https://www.nrcan.gc.ca/energy-efficiency/energy-star-benchmarking-commercial-and-institutional-buildings/energy-benchmarking-technical-information/building-energy-use-surveys/19454>


<sup>4</sup> Data from Burnside Energy Conservation Measures for the Hillsburgh and Erin Community Centre Arenas

**Figure 9: North Dufferin Community Centre Exterior Wall Assembly**



**Figure 10: Common Area Window**



**Figure 11: Common Area Single Pane Window to Unheated Arena**

## 2.2 Roofing

The Community Centre has both a flat roof, located over the community centre, and a sloped roof supported by wood trusses located above the ice rink. The flat roof has an unheated attic space below it that is insulated with 90 mm [3.5 in.] fibreglass batt insulation in ceiling and wall cavities with wood frame construction. The ice rink roof is uninsulated, the Urethane Foam/Gascosil coating is for leak protection rather than thermal insulation.



**Figure 12: Community Centre Attic Space Insulation**



**Figure 12: Roof Over Rink**



### 3.0 Building Systems

#### 3.1 Lighting Systems

##### 3.1.1 Interior Lighting

Most common area lighting on the first level including the foyer, front entrance, canteen, changerooms, bathrooms front entrance, hallways, laundry and stair ways has been converted to electronic ballasts and LED tubes. It is estimated about 75% of lights have been switched to LED. These retrofits have been completed within the last 3 years. However, some units are still using incandescent, and fluorescent bulbs so there is still a significant opportunity for savings by implementing a complete conversion. The lighting in the rink has been completely converted to LED, and the lighting upstairs in the auditorium is generally still fluorescent. There is no opportunity for improvement in the rink, and in the auditorium, there is limited opportunity as the occupancy of the space is only a few hours per week, not allowing for a benefit to outlay capital.

**Figure 13: Changeroom Lighting Example**



**Figure 14: Rink Lighting**



**Figure 15: Auditorium Lighting**





### 3.1.2 Exterior Lighting

The lighting on the exterior consists of 2 mounted 50 W LED fixtures on front face of building, 1 High-Pressure Sodium (HPS) fixtures on a hydro pole, 1 HPS fixture on the exterior wall and 3 wall-mounted LED fixtures.

**Figure 16: HPS Parking Lot Lights**



**Figure 17: LED Parking Lot Lights**



## 3.2 Mechanical Systems

### 3.2.1 HVAC System

#### 3.2.1.1 Heating

Common areas at the front of the arena are heated with 2 oil furnaces and duct work to heat the areas. An electric heater is used at the back maintenance and Zamboni area in the wintertime.

**Figure 18: Common Area Oil Furnaces****3.2.1.2 Ventilation**

The building is not equipped with Ventilation units. Only the fans within the oil furnaces deliver air to the heated common areas.

**3.2.1.3 Cooling**


There is large fan that is used rarely for ventilation in the rink area only required for fumes that are present from maintenance activities.

**3.2.2 Plumbing and Fixtures**

Plumbing is mostly original to the building. The 4 changerooms each generally have 1 toilet, 1 sink, and 1 shower. There is also a men's washroom, a women's washroom, a referee's room and a girls changeroom. Upstairs there is a women's and a men's washroom. Upgrades to low flow showerheads and low flow kitchen and bathroom sinks have not taken place.



**Figure 19: Typical Changeroom**



**Figure 20: Typical Sink Fixtures**



### 3.2.3 Domestic Hot Water


The Domestic Hot Water heating consists of 1 John Wood oil-fired tank.

**Figure 21: Domestic Hot Water Tank**



### 3.2.4 Zamboni Hot Water

The Zamboni Hot Water heating consists of an oil-fired hot water tank that is pumped into an insulated holding tank. The holding tank is circulated by a Grundfos pump and the insulated water heater is kept hot by electrical resistance heating. The current hot water system is old and showing signs of wear.

**Figure 22: Zamboni Hot Water Storage Tank****Figure 23: Zamboni Hot Water Heating Tank and Electrical Heating Wall Mount**

### 3.2.5 Ice Refrigeration System

The ice refrigeration system is ammonia based. The primary refrigeration side consists of 2 compressors, 1 cooling tower/condenser, 1 chiller, circulation pumps and piping. The secondary refrigeration side consists of circulation pumps and the arena slab piping. The refrigeration system was replaced in 2009. Typical ammonia-based refrigeration systems last for 30 years<sup>5</sup>. Therefore, only 1/3 into its useable life it was not analyzed for replacement or major retrofit.

<sup>5</sup> [https://www.nrcan.gc.ca/energy/efficiency/buildings/research/publications/16002#\\_Toc364163192](https://www.nrcan.gc.ca/energy/efficiency/buildings/research/publications/16002#_Toc364163192)



**Figure 24: Ice Plant Compressors****Figure 25: Ice Plant**

#### **4.0 Occupancy Schedule**

Below is the occupancy schedule for North Dufferin Community Centre. Typically, the Arena is used in the winter from September to April and follows this occupancy schedule below.

**Table 14: Occupancy Schedule**

Zone Name / Description	Winter Operation of North Dufferin Community Centre Occupancy (Number of People) Per Hour							
	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday	Holiday
0:00 - 1:00								
1:00 - 2:00								
2:00 - 3:00								
3:00 - 4:00								
4:00 - 5:00								
5:00 - 6:00								
6:00 - 7:00							2	2
7:00 - 8:00						2	100	100
8:00 - 9:00						100	100	100
9:00 - 10:00						100	100	100
10:00 - 11:00						100	100	100
11:00 - 12:00						100	100	100
12:00-13:00						100	100	100
13:00-14:00						100	100	100
14:00-15:00						100	100	100
15:00-16:00						100	100	100
16:00-17:00	2	2	2	2	2	100	100	100
17:00-18:00	30	30	30	30	100	125	100	100
18:00-19:00	30	30	30	30	100	125	100	100
19:00-20:00	30	30	30	30	100	125	100	100
20:00-21:00	30	30	30	30	100	125	100	100
21:00-22:00	30	30	30	30	100	125	2	2
22:00-23:00	30	30	30	30	100	125		
23:00-24:00	2	2	2	2	2	2		
Total Showers Estimated	30	12	15	30	30	20	100	
Note: Plus, every other week 50 people for 6 hours in auditorium.								

## 5.0 Energy Efficiency Measures

### 5.1 No-Cost/Low-Cost Measures

Please note that savings calculations reflect savings from individual measures only and do not assume that other recommendations have been implemented. Calculations and assumptions used are solely based on the existing equipment and usage schedules.

**5.1.1 EEM 1 – Interior Lighting Analysis – LED Lighting**

Budget Cost	Annual Utility Savings		MTCDE	Total Savings/Year	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
1,105	1,300	-	-	216.45	390	5.11	6.91

**Existing Condition: Inefficient Lighting**

Some common area lighting including the foyer, front entrance, changerooms, laundry and stair ways has been converted to electronic ballasts and LED tubes. These retrofits have been completed within the last 3 years. However, some lighting is still fluorescent bulbs so there is still an opportunity for savings by implementing a complete conversion.

**Recommendations**

Replace existing fluorescent lighting with LED lighting. The replacement LEDs also have a rated lifespan of 45,000 hours versus approximately 20,000 hours for the existing fluorescent lamps, which will help reduce maintenance costs associated with replacing burn outs.

**Implementation**

Estimate includes the cost for supply of lamps and fixtures and installation. In order to estimate the electric savings assumptions for daily usage were made based on space type. Save on Energy offers incentives for each of these lamps installed and these incentives are included in the price calculations. Further information regarding assumptions and the calculations made for this EEM can be found in Appendix B.

**5.1.2 EEM 2 – Exterior Parking Lot Lights - LED Lighting**

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
890	964	-		160	100	5.6	6.2

**Existing Condition: Inefficient Lighting**

Based on a visual inspection from the ground, the lighting on the exterior consists of 2 mounted 30 W LED fixtures on front face of building, 1 High-Pressure Sodium (HPS) fixtures on a hydro pole, 1 HPS fixture on the exterior wall, and 3 wall-mounted LED fixtures.

## Recommendations

Replace existing lighting with LED lighting when the lamps burn out. There is a significant cost for a lift truck rental (\$500 to 600/day) to reach the height of the lights. Therefore, when the lamps need to be replaced it makes sense to replace the remaining halogen lamps with LED. The replacement LEDs also have a rated lifespan of 45,000 hours versus 2,000 hours for the existing halogen lamps, which will help reduce maintenance costs associated with replacing burn outs. Furthermore, a comment was received at a Public Information Consultation that recommended the lights to be turned off at night. If turning off the lights was acceptable from a safety perspective, there would be additional savings from the reduced electricity during nighttime hours.

### 5.1.3 EEM 3 – Programmable Thermostats

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
400		1,000	2.5	750	-	0.5	0.5

### Existing Condition

Currently the heated portion of the arena is heated at 20°C during the heating season from mid-October to mid-May.

### Recommendations

Replace thermostats with programmable thermostats which would reduce costs by about 15% if the heat was turned down from 20°C to 16°C when unoccupied. Calculations are provided in Appendix B. There would be also be electricity savings from a reduced fan operating schedule.

The auditorium of the arena is mostly unoccupied, and the arena's occupied hours are about 70 hours per week. By reducing the temperature in unoccupied spaces and at night significant savings in heating fuel can be made at a low cost.

## 5.2 Capital Investment Measures

### 5.2.1 EEM 4 – Building Envelope Analysis – Roof Insulation

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
8,500	0	2,144	6	1,780	0	4.8	4.8

**Existing Condition:** Low R Value Roof Insulation.

Currently this is just one 3.5 in. layer of insulation in the attic space below the flat roof area with an approximate R-value of R-12.

#### Recommendations

Blow-in additional insulation into the attic space to bring up to Ontario Building Code (OBC) 2012 requirements of R-50.

### 5.2.2 EEM 5 – Building Envelope Analysis – New Doors

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
1,500	0	136	0.4	102.8	0	14.6	14.6

**Existing Condition:** Interior doors from unheated arena to heated foyer have significant air leakage, as well as 1 exterior door on second floor Auditorium.

#### Recommendations

Replace doors at the end of their useful life with new doors to limit air leakage. The payback is not appealing enough to replace doors before their useful life is over.

### 5.2.3 EEM 6 – Building Envelope Analysis – New Windows

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
38,000	0	1,075	2.9	806	0	47.1	47.1

**Existing Condition:** Existing windows between the heated area of the arena and the unheated rink part of the arena are single pane.



**Recommendations**

Install new windows assumed to be equivalent to thermally unbroken aluminum frame with fixed, double glazing, low- $\epsilon=0.2$ , 12.7 mm argon space, fire rated coating.

**5.2.4 EEM 7 – Water Conservation – Low Flow Fixtures**

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
1,800	100	571	1.5	490	0	3.7	3.7

**Existing Condition:** Inefficient Plumbing Fixtures.

Our visual inspection revealed the following:

- The showerheads in the units were rated 2.5 GPM;
- The washroom faucet aerators were rated 2.2 GPM; and
- Kitchen aerators were typically rated at 2.2 GPM.

**Recommendations**

In order to reduce the water consumption and the energy used for DHW, we recommend the following measures:

- Replace all showerheads as 1.6 GPM (or less) showerheads;
- Replace the existing washroom faucet aerators rated with low-flow aerators rated for 0.5 GPM; and
- Replace the existing kitchen faucet aerators rated with low-flow aerators rated for 1.0 GPM.

**Note:** The cost of pumping and disinfecting water does not allow for significant cost savings to change to low flow toilets.

**5.2.5 EEM 8 – Upgrade Furnace to Higher Efficiency Furnace**

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
7,000	-	125	0.3	104	0	67.5	67.5

**Existing Condition: Minimal Control of Common Area Heating**

The building is equipped with 2 forced air oil furnaces. The furnaces come with one 1/2 HP supply fan. The units provide approximately 1,000 CFM of ventilation each. The supply fan is manually operating at full speed. The current efficiency of both units is assumed to be 84%. Between the two furnaces approximately 5,000 L of oil is used.

**Recommendations**


When the life of the furnace is over replacement of either a new 90% efficiency oil furnace or a 95% propane furnace should be installed, or an air source or ground source heat pump. A heat pump could offer cost savings as well as air conditioning in the summer for arena activities. Assuming 1 furnace uses approximately 2,500 L of oil, an increase in 5% efficiency saves approximately 125 L. It is not recommended to replace the furnace until useful life is over.

**5.2.6 EEM 9 – Drain Water Heat Recovery**

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	NG					
\$	kWh	m <sup>3</sup>	Metric Tons	\$	\$	Years	Years
4,500	0	367	1.0	304	0	14.8	14.8

**Existing Condition: Heat Recovery Opportunity**

Drain-water heat exchangers can recover heat from the hot water used in showers, bathtubs, sinks, dishwashers, and clothes washers. They generally have the ability to store recovered heat for later use.

**Figure 26: Drain Water Heat Recovery System**

**Recommendation**

Implementing a drain water heat recover system is not recommended as the payback is close to 15 years.

**5.2.7 EEM 10 – New Zamboni Hot Water System**

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	L	Metric Tons	\$	\$	Years	Years
8,000	2,600	682	1.8	1,165	0	6.9	6.9

**Existing Condition: Inefficient Hot Water System**

The Zamboni Hot Water heating consists of an oil-fired hot water tank that is pumped into an insulated holding tank. The holding tank is circulated by a Grundfos pump and the insulated water heater is kept hot by electrical resistance heating. The existing hot water storage tank is large and has inefficient insulation.

**Recommendations**

Remove the existing storage tank with electrical resistance heating and circulation pump with two 75-gal propane tanks, this will reduce the Arena's electricity bill. New propane heaters are assumed to have greater efficiency than the existing oil furnace, furthermore, propane delivery prices are more economical for the Arena than oil.

**5.2.8 EEM 11 – Desuperheater - Heat Recovery**

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	m <sup>3</sup>	Metric Tons	\$	\$	Years	Years
42,500		4,470	11.9	3,710		11.5	11.5

**Existing Condition: No heat recovery**

Currently Zamboni hot water is pumped to the oil heater for heating then into the holding tank circulated and heated by electricity. Compressors within the compressor room give off waste heat that is vented to the outside wasting that energy.

**Recommendations**

A desuperheater can take the waste heat from the compressors and heat the incoming groundwater from the well. This hot water can be used for the Zamboni hot water rather than heating it with propane. The desuperheater is assumed to be functional to pre-heat the water to 120°Fahrenheit (F) approximately 80% of the time.

Unfortunately, the capital cost is quite high, and the payback period falls outside of 10 years. For that reason, this measure is not recommended at this time. With an incentive from the government this could make this project viable.

#### 5.2.9 EEM 12 – DDC Controller on Refrigeration System

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	m <sup>3</sup>	Metric Tons	\$	\$	Years	Years
45,000	38,500		0	6,000	\$3,850	8.2	9.0

#### Existing Condition: No Automation

The existing refrigeration system was replaced around 2009. There appear to be no automatic controls or setbacks with the system.

#### Recommendations

There is currently no automation on the refrigeration system. It is recommended to install a seasonal controller with infrared camera as well as a VFD on the condenser FAN motor and a new condenser fan inverter duty motor. The controller can monitor outside temperature and control the refrigeration system for optimal energy use. The controller can also provide the customer with a host of other features like "game mode", "nighttime set back", that can also further reduce energy, as well as an interface with remote alarming, plant readings, and temperature control. Based on a discussion with a qualified refrigeration contractor cost savings per year can be between \$5,000-\$10,000. A conservative estimate of \$5,000 was used in analysis. Typically, a save on energy will provide an incentive for \$0.10/kwh of energy savings. This is to be confirmed should the project move forward.

#### 5.2.10 EEM 13 – Electric Desiccant Dehumidifier

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	Oil					
\$	kWh	m <sup>3</sup>	Metric Tons	\$	\$	Years	Years
40,000	19,000		0	\$2,500	\$1,900	15.2	16.0

#### Existing Condition: 1 Mechanical dehumidifier

The arena currently has 2 dehumidifiers, 1 electric desiccant dehumidifier and 1 mechanical dehumidifier (refrigerator coil technology).

## Recommendations

Typically, electric desiccant dehumidifiers are 2.5 times more energy efficient than mechanical dehumidifiers. Since the payback with incentives is over 10 years, it is recommended to replace the mechanical dehumidifier when the mechanical dehumidifier is at the end of its life. Based on a discussion with a qualified contractor cost savings per year can be between \$2,500-\$4,000. A conservative estimate of \$2,500 was used in analysis. Typically, save on energy will provide an incentive for \$0.10/kwh of energy savings. This is to be confirmed should the project move forward.

### 5.3 Distributed Generation/Renewable Energy Measures

#### 5.3.1 EEM 14 – Rooftop Solar with Net Metering Connections

Budget Cost	Annual Utility Savings		MTCDE	Total Savings	Available Incentives	Payback with Incentives	Payback without Incentives
	Electricity	NG					
\$	kWh	m <sup>3</sup>	Metric Tons	\$	\$	Years	Years
114,375	228,000	-	-	12,435	-	7.0	9.3

#### Existing Condition: Renewable Generation

The roof of the building has been considered for a solar PV installation. Applying safety setbacks from roof edges and impacts of shading, the panels are modeled to cover most of the south facing roof area. This space accommodates a total of approximately 190 kW.

Net metering allows you to send electricity generated from Renewable Energy Technologies (RETs) to the distribution system for a credit towards your electricity costs. Excess generation credits can be carried forward for a consecutive 12-month period to offset future electricity costs. Net-metered customers can now pair energy storage with renewable energy systems.

#### Recommendations

With a total nameplate capacity of approximately 190 kW, and consideration of system losses, the system is modeled to produce approximately 233 MWh of electricity per year. This will offset approximately 77% of the Community Centre's electricity use. With a simple payback on the equity of 9.3 years, Mulmur should consider developing this EEM.

Mulmur should keep an eye on the Climate Action Incentive Fund (CAIF) program outlined in the section below. This fund is scheduled to be announced in late 2019 or early 2020. The current program is for private businesses only. It is the writer's opinion that if a program were to be announced for municipalities as scheduled, that fund would likely be similar by providing 25% of the capital costs in a rebate. This would significantly improve the economics for the Community Centre solar project.

Investigate a loan from Infrastructure Ontario. Infrastructure Ontario states they have flexible terms designed to match the life of the asset. Receiving a loan for 30 years to match the life of the asset at a low interest rate would maximize the return on investment (ROI) of the system.

The Loan Program provides various benefits to public sector borrowers:

- Affordable interest rates;
- Flexible terms of up to 30 years, designed to match the life of the asset;
- Access to dedicated and experienced staff throughout the loan process;
- Instant access to capital markets with no extra fees or commissions; and
- No need to refinance over the life of the loan.

### **Implementation**

The next step would be a structural and roof assessment of the arena, connection feasibility assessment with Hydro One, and create a bid package for installation pricing. A ground mount solar project could also be considered, if Mulmur wanted to dedicate some ground space to solar.

## **6.0 Incentive Programs**

### **6.1 Climate Action Initiative Fund**

The Climate Action Incentive Fund (CAIF) SME Project stream provides support to small- and medium-sized enterprises (SMEs) for retrofit projects in sectors such as building, transportation, industry, waste, agriculture, and more. Up to 25% of the project's total eligible costs are applicable. Project minimum funding is \$20,000.00 and maximum is \$250,000.00. Currently they are accepting applications.

Eligible project category for building retrofits are below:

#### **Building Retrofits**

- Enhancements to building envelope (with direct energy savings), including energy efficient windows/doors/skylights, increased insulation, weatherproofing, and glazing;
- Energy efficient lighting system;
- Heating, ventilation, and air conditioning (HVAC) equipment/systems/controls;
- Water heating retrofits, including high efficiency condensing water heating;
- High-efficiency motors and controls;
- Energy management controls, including building automation systems; and
- Fuel switching to lower emitting energy sources in existing buildings.

Currently this funding is only available for small to medium sized business. However, Funding for municipalities, universities/colleges and hospitals under the Municipalities, Universities, Schools and Hospitals (MUSH) Retrofit stream will be announced later in 2019 to 2020.



Additional information about funding for energy efficiency and retrofit projects will be posted on their website as it becomes available.

Presumably, under the MUSH program the government will announce a similar level of funding for municipalities as private businesses. If that is true and an incentive fund of 25% becomes available some of the measures for Mulmur would become much more appealing. To illustrate this point, a new table of measures has been outlined below with updated payback periods.

## 6.2 EEMs Recommended with CAIF

If the CAIF was applied for and received for these energy efficiency projects the updated economics are presented in the below table. Including the potential 25 percent savings from the CAIF fund, eight Energy Efficiency Measures (EEMs) are recommended. The annualized savings of all recommendations totals more than \$20,706.00 (at projected energy prices). If fully implemented, the average weighted payback period from annual energy savings for these EEMs is estimated to be 6.4 years. Details are outlined in the table below.

**Table 15: North Dufferin Community Centre Energy Efficiency Recommendations with CAIF Funding**

EEM No.	Energy Efficiency Measure	Measure Type	Approx. Annual Savings	CAIF Incentive	Estimated Net Costs	Simple Payback Years
1	LED Lighting – Interior Lights	Upgrade Building Systems	\$216.00	\$374.00	\$731.00	3.4
2	LED Lighting – Exterior Parking Lot Lights	Upgrade Building Systems	\$160.00	\$223.00	\$568.00	3.5
3	Install Programmable Thermostats	Upgrade Building Systems	\$750.00	\$100.00	\$300.00	0.4
4	Building Envelope Analysis – Roof Insulation	Upgrade Building Envelope	\$1,780.00	\$2,125.00	\$6,375.00	3.6
7	Water Conservation - Low Flow Fixtures	Upgrade Building Systems	\$490.00	\$450.00	\$1,350.00	2.8
10	New Zamboni Hot Water System	Upgrade Building Systems	\$1,165.00	\$2,000.00	\$6,000.00	5.2
11	Desuperheater	Upgrade Building Systems	\$3,710.00	\$10,625.00	\$31,875.00	8.6
12	Controller	Upgrade Building Systems	\$5,000.00	\$11,250	\$29,904	6.0
14	Rooftop Solar	Renewable Technology	\$12,435.00	\$28,594.00	\$85,781.00	6.9
<b>Totals</b>			<b>\$25,706.00</b>	<b>\$55,740.00</b>	<b>\$162,884.00</b>	<b>4.5</b>

### 6.3 FCM Retrofit of Municipal Facilities

Another program available is the Green Municipal Fund Capital Project: Retrofit of Municipal Facilities. A minimum of 30% energy efficiency of the municipal facility must be met to be approved for this funding with a minimum 20% coming from energy efficiency and 10% from onsite renewable energy. A low-interest loan of up to \$5 million and a grant of up to 15% of the loan; to cover up to 80% of eligible costs can be attained.

## 7.0 Summary

Fourteen separate Energy Efficiency Measures (EEMs) were identified with implementation costs and annual energy savings estimates. Eight Energy Efficiency Measures (EEMs) recommendations were identified with implementation costs and annual energy savings estimates. The annualized savings of all recommendations totals \$21,996.00 (at projected energy prices). If fully implemented, the average weighted payback period from annual energy savings for these EEMs is estimated to be 8.0 years. Details are outlined in the tables below.

If all recommendations are implemented a substantial reduction in utility consumption will be achieved. If solar is implemented, the electricity consumption could be close to net zero, and significant savings in fuel savings can be achieved as well approximated at 24% savings.

**Table 16: North Dufferin Community Centre Energy Efficiency Recommendations**

EEM No.	Energy Efficiency Measure	Measure Type	Approx. Annual Savings	Estimated Net Costs	Simple Payback Years
1	LED Lighting – Interior Lights	Upgrade Building Systems	\$216.00	\$1,105.00	5.1
2	LED Lighting – Exterior Parking Lot Lights	Upgrade Building Systems	\$160.00	\$790.00	4.9
3	Install Programmable Thermostats	Upgrade Building Systems	\$750.00	\$400.00	0.5
4	Building Envelope Analysis – Roof Insulation	Upgrade Building Envelope	\$1,780.00	\$8,500.00	4.8
7	Water Conservation - Low Flow Fixtures	Upgrade Building Systems	\$490.00	\$1,800.00	3.7
10	New Zamboni Hot Water System	Upgrade Building Systems	\$1,165.00	\$8,000.00	6.9
12	DDC Controller	Upgrade Building Systems	\$5,000.00	\$41,154	8.2
14	Rooftop Solar	Renewable Technology	\$12,435.00	\$114,375.00	9.2
<b>Totals</b>			<b>\$21,996.00</b>	<b>\$180,460.00</b>	<b>5.4</b>

Note: Simple payback is an average of all projects.



**Table 17: North Dufferin Community Centre EEMs not Recommended**

<b>EEM No.</b>	<b>Energy Efficiency Measure</b>	<b>Measure Type</b>	<b>Approx. Annual Savings</b>	<b>Net Costs</b>	<b>Simple Payback Years</b>
5	Building Envelope Analysis – New Doors	Upgrade Building Envelope	\$103.00	\$1,500.00	14.6
6	Building Envelope Analysis – New Windows	Upgrade Building Envelope	\$806.00	\$38,000.00	47.1
8	Upgrade Furnace to Higher Efficiency	Upgrade Building Systems	\$104.00	\$7,000.00	67.5
9	Drain Water Heat Recovery	Upgrade Building Systems	\$304.00	\$4,500.00	14.8
11	Desuperheater	Upgrade Building Systems	\$3,710.00	\$42,500.00	11.5
13	Electric Desiccant Humidifier	Upgrade Building Systems	\$2,500	\$38,077	15.2
<b>Totals</b>			<b>\$7,527.00</b>	<b>\$93,500.00</b>	<b>28.4</b>

**Table 18: Summary of Utility Reductions for Recommendations**

	<b>Electricity</b>	<b>Oil</b>	<b>GHG Reduction</b>
	<b>kWh</b>	<b>L</b>	<b>MTCDE</b>
<b>Total 2017/2018 Utility Consumptions</b>	300,000	18,221	49
<b>Percentage Reduction in Utility Consumption</b>	90%	24%	24%
<b>Total Projected Utility Consumptions</b>	31,274	13,824	37



BURNSIDE

[THE DIFFERENCE IS OUR PEOPLE]



## Appendix A

### Data

**Honeywood Arena Ice Plant 2000 5377 1313  
2016 - 2018**

Year over year Hydro consumption in kWh:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
2006													0
2007													0
2008													0
2009													0
2010													0
2011													0
2012													0
2013													0
2014													0
2016	8,658	7,385	9,422	52,456	40,000	38,960	51,183	42,270	40,997	26,483	16,042	9,167	341,023
2017	1,528	1,273	6,111	46,599	40,000	40,000	43,798	43,289	38,451	22,154	4,838	764	288,805
2018	2,292	509	18,843	48,127	38,451	42,016	33,358	29,029	33,358	18,589	764	764	266,100

**Honeywood Arena Building 2000 6638 4343  
2016 - 2018**

Year over year Hydro consumption in kWh:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
2006													0
2007													0
2008													0
2009													0
2010													0
2011													0
2012													0
2013													0
2014													0
2016	1,220	760	2,700	3,520	3,820	4,600	2,520	2,600	3,600	2,520	720	1,000	29,580
2017	700	817	1,813	3,206	3,825	4,600	3,760	3,620	4,000	2,000	560	780	29,681
2018	1,468	811	1,538	4,246	4,689	4,664	3,771	4,097	4,082	1,532	743	1,176	32,817

**Honeywood Arena Building + Ice Plant 2000 6638 4343 + 2000 5377 1313  
2016 - 2018**

Year over year Hydro consumption in kWh:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total
2006													0
2007													0
2008													0
2009													0
2010													0
2011													0
2012													0
2013													0
2014													0
2016	9,878	8,145	12,122	55,976	43,820	43,560	53,703	44,870	44,597	29,003	16,762	10,167	372,603
2017	2,228	2,090	7,924	49,805	43,825	44,600	47,558	46,909	42,451	24,154	5,398	1,544	318,486
2018	3,760	1,320	20,381	52,373	43,140	46,680	37,129	33,126	37,440	20,121	1,507	1,940	298,917

Year over year Furnace Oil consumption in Litres:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total	kWh/L	Total kWh
2006													0	10.557	0
2007													0	10.557	0
2008													0	10.557	0
2009													0	10.557	0
2010													0	10.557	0
2011													0	10.557	0
2012													0	10.557	0
2013													0	10.557	0
2014													0	10.557	0
2015/2016												2016	12,841	10.557	135,562
2016/2017												2017	9,234	10.557	97,483
2017/2018												2018	14,121	10.557	149,075

Year over year Propane consumption Estimate in Litres:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total	kWh/L	Total kWh
2006													0	7.08	0
2007													0	7.08	0
2008													0	7.08	0
2009													0	7.08	0
2010													0	7.08	0
2011													0	7.08	0
2012													0	7.08	0
2013													0	7.08	0
2014													0	7.08	0
2015/2016												2016	4,695	7.08	33,241
2016/2017												2017	9,461	7.08	66,984
2017/2018												2018	5,259	7.08	37,234

Year over year Total Fuel consumption Estimate in Litres:

	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May	Jun	Total	kWh/L	Total kWh
2006													0		0
2007													0		0
2008													0		0
2009													0		0
2010													0		0
2011													0		0
2012													0		0
2013													0		0
2014													0		0
2015/2016												2016	17,536	9.63	168,803
2016/2017												2017	18,695	8.80	164,467
2017/2018												2018	19,380	9.61	186,309



	Input	Output
Propane	1 L Propane	7.08 kWh
Fuel Oil	1 L Fuel Oil	10.57 kWh

Total Energy Use

	2016	2017	2018
Electricity	372,603	318,486	298,917
Fuel Oil	135,562	97,483	149,075
Propane	33,241	66,984	37,234
Total	541,406	482,953	485,226

2018 Energy Cost

Electricity	\$40,145
Fuel Oil	\$12,437
Propane	\$2,629
Total	\$55,211



NDCC Oil Usage for 2016, 2017, 2018

Date	Litres	Price	Total
12/28/2016	475.2	0.718	341.19
12/28/2016	5.6	0.718	4.02
12/21/2016	544.6	0.709	386.12
12/21/2016	11	0.79	8.69
12/14/2016	25.3	0.701	17.74
12/14/2016	590.1	0.701	413.66
12/7/2016	58.5	0.713	41.71
12/7/2016	1197.7	0.713	853.96
11/25/2016	1500.3	0.689	1,033.71
11/25/2016	361.8	0.689	249.28
9/21/2016	211.5	0.571	120.77
9/21/2016	14.7	0.571	8.39
5/2/2016	1442.6	0.639	921.82
5/2/2016	157.1	0.639	100.39
3/31/2016	668.5	0.689	460.60
3/31/2016	34.1	0.689	23.49
3/18/2016	438.6	0.585	256.58
3/18/2016	93.8	0.585	54.87
3/7/2016	146.4	0.576	84.33
3/7/2016	894.6	0.576	515.29
2/3/2016	681.7	0.565	385.16
2/18/2016	346.3	0.568	196.70
2/18/2016	1024.5	0.568	581.92
2/24/2016	53.5	0.556	29.75
2/24/2016	342.2	0.556	190.26
1/13/2016	13.8	0.572	7.89
1/13/2016	880.4	0.572	503.59
1/22/2016	595	0.54	321.30
1/22/2016	32.5	0.54	17.55
	<u>12,841.90</u>	<u>0.631</u>	<u>8,130.73</u>

Furnace Maintenance  
10/3/2016 470.00

11/22/2017	750.9	0.87	653.28
11/22/2017	19.5	0.87	16.97
11/6/2017	466.6	0.804	375.15
11/6/2017	30.5	0.804	24.52
10/4/2017	42.7	0.767	32.75
10/4/2017	1245.8	0.767	955.53
10/25/2017	56.5	0.776	43.84
10/25/2017	464.8	0.776	360.68

Furnace Maintenance  
11/1/2017 367.25  
10/10/2017 470.00  
837.25

4/6/2017	396.9	0.727	288.55
3/16/2017	700	0.705	493.50
3/7/2017	415.6	0.748	310.87
3/23/2017	74.3	0.699	51.94
3/23/2017	278.9	0.699	194.95
3/29/2017	409.8	0.703	288.09
2/28/2017	306.9	0.751	230.48
2/22/2017	24.6	0.75	18.45
2/22/2017	235.9	0.75	176.93
2/15/2017	350.1	0.738	258.37
2/9/2017	568.3	0.778	442.14
2/9/2017	24.3	0.778	18.91
2/1/2017	838.8	0.738	619.03
1/19/2017	395	0.749	295.86
1/13/2017	8.6	0.75	6.45
1/13/2017	600.3	0.75	450.23
1/6/2017	529	0.788	416.85
	9234.6	0.761	7,024.31

12/7/2018	1350.8	0.816	1,102.25
12/7/2018	442.6	0.816	361.16
11/15/2018	189.6	0.879	166.66
11/15/2018	734.1	0.897	658.49
11/2/2018	2275.2	0.926	2,106.84
11/2/2018	466.3	0.926	431.79
4/26/2018	423	0.921	389.58
4/26/2018	176.7	0.921	162.74
4/18/2008	1129.7	0.887	1,002.04
3/29/2018	443.1	0.904	400.56
3/29/2018	44.5	0.904	40.23
3/19/2018	1065.1	0.854	909.60
3/19/2018	209.9	0.854	179.25
2/28/2018	918.8	0.881	809.46
2/28/2018	249.5	0.881	219.81
2/14/2018	290.8	0.832	241.95
2/9/2018	327.25	0.858	280.78
2/9/2018	1762.2	0.858	1,511.97
1/16/2018	1622.6	0.901	1,461.96
	14121.75	0.880	12,437.13

#### Furnace Maintenance

3/8/2018	295.00
12/10/2018	269.99
12/10/2018	269.99
12/20/2018	154.91
12/20/2018	564.47
	1,554.36

Year	Total Cost	Furnace Oil Cost	Propane Cost	Assumed Cost/L	Propane L
2016	\$ 10,009	8,130.73	\$ 1,878.27	0.4	4695.7
2017	\$ 11,282	7,024.31	\$ 4,257.69	0.45	9461.5
2018	\$ 15,067	12,437.13	\$ 2,629.87	0.5	5259.7
Average		\$ 9,197.39	\$ 2,921.95		6472.3

**NDCC Board of Management  
2018 Budget**

Account	Description	2016 Actual	2016 Budget	2017 Actuals	2017 Budget	2018 Draft 1	2018 Draft 2	Budget Change	Comments
01-2000-4000	MULMUR GRANT	(27,000)	(27,000)	(47,240)	(47,240)	(20,758)	(25,042)	22,199	
01-2000-4010	MELANCTHON GRANT	(17,500)	(17,500)	(17,500)	(17,500)	(20,758)	(25,042)	(7,542)	
01-2000-4020	DONATION REVENUE	(7,200)	0	0	0	0	0	0	
01-2000-4030	FUNDRAISING REVENUE	(19,922)	(14,500)	(17,382)	(19,380)	(20,000)	(20,000)	(620)	Incl. BBQ
01-2000-4100	MINOR RATE RENTAL REVENUE	(55,131)	(53,997)	(48,069)	(56,300)	(50,000)	(45,000)	11,300	half the year at lower amt so next yr lower
01-2000-4110	ICE RENTAL REVENUE (PRIME)	(44,955)	(50,719)	(50,442)	(42,000)	(49,000)	(52,000)	(10,000)	renting more to other groups
01-2000-4115	ICE RENTAL REVENUE (NON-PRIME)	(1,301)	(1,200)	(743)	(500)	(500)	(500)	0	
01-2000-4120	NON-RESIDENT USER FEES	(3,044)		(3,396)	(2,250)	(3,000)	(3,000)	(750)	
01-2000-4200	BOOTH RENTAL REVENUE	(4,331)	(5,000)	(5,328)	(5,000)	(4,300)	(4,300)	700	includes \$1000 for Strawberry supper
01-2000-4210	HALL RENTAL REVENUE	(2,628)	(2,400)	(2,850)	(2,400)	(2,400)	(2,600)	(200)	
01-2000-4220	FLOOR RENTAL REVENUE	(372)	(100)	0	(100)	(100)	0	100	
01-2000-4230	SIGN RENTAL REVENUE	(4,168)	(4,200)	(4,160)	(4,500)	(4,160)	(4,160)	340	
01-2000-4240	VENDING MACHINE REVENUE	(304)	(300)	(251)	(300)	(300)	(250)	50	
01-2000-4300	PENALTIES & INTEREST	(885)	(300)	(527)	(450)	(525)	(525)	(75)	
01-2000-7000	WAGES	50,561	47,000	42,898	50,000	50,000	45,000	(5,000)	
01-2000-7005	BENEFITS-EI/CPP/WSIB/EHT	5,969	5,000	5,192	5,600	6,000	5,600	0	
01-2000-7010	BENEFITS-OMERS	590		2,913	4,500	0	3,000	(1,500)	
01-2000-7015	STAFF TRAINING/DUES, FEES, SUBSCRIP	303	0	145	484	300	300	(184)	billed from County at end of year
01-2000-7100	OFFICE/COMPUTER SUPPLIES	480	100	1,171	1,680	730	730	(950)	
									incl advertising, phone, internet, 1 email acct
01-2000-7110	COMMUNICATION	2,422	1,553	3,075	1,500	2,425	3,000	1,500	\$73.20
01-2000-7115	INSURANCE	20,605	19,000	16,445	21,225	12,200	12,200	(9,025)	RFQ large decrease in insurance
01-2000-7120	HEALTH & SAFETY	2,527	3,248	2,723	2,800	2,600	2,800	0	billed from County at end of year
01-2000-7125	PROF FEES - AUDIT	1,120	1,089	1,153	1,075	1,120	1,188	113	
01-2000-7130	PROF FEES - WATER TESTING	300	300	300	300	300	300	0	
01-2000-7150	BANK CHARGES	251	500	108	250	25	500	250	
01-2000-7200	HYDRO	78,970	56,206	58,050	56,206	56,500	60,000	3,794	increase in hydro rates
01-2000-7210	FURNACE FUEL/ZAMB PROPANE	10,009	16,240	11,282	9,000	10,000	12,000	3,000	
01-2000-7220	BLDG/GROUNDS MAINTENANCE	16,489	12,180	15,863	14,500	14,000	15,000	500	includes grounds mtne, snow removal
01-2000-7230	BOOTH MAINTENANCE	1,048	1,300	1,280	1,300	1,100	1,300	0	
01-2000-7240	ICE PLANT/MACH MAINT	15,406	6,000	8,581	12,000	8,000	9,000	(3,000)	
01-2000-7300	FUNDRAISING EXPENSE	10,395	7,500	7,324	10,500	10,500	10,500	0	Incl. BBQ
01-2000-7400	BAD DEBT	26		33	0	0	0	0	
01-2000-6010	TSFR TO REC RESERVES			5,000	5,000				
01-2000-6015	TSFR TO BLDG RESERVES			1,105	0				
	Amount needed	28,732	0	(13,245)	0	41,515	50,083		

# 7.6.4

FEB - 8 2018  
MARCH 8, 2018



# NDCC Board of Management

## 2020 Budget

Account	Description	2018 Actuals	2018 Budget	2019 Actual	2019 Budget	Draft #1 2020 Budget	Draft #2 2020 Budget	Budget Variance	Comments
<b>REVENUES</b>									
01-2000-4000	MULMUR GRANT	25,277	25,277	40,966	55,024	49,262	48,812	(6,212)	-10.47%
01-2000-4010	MELANCHTHON GRANT	25,277	25,277	40,966	55,024	49,262	48,812	(6,212)	-10.47%
01-2000-4020	DONATION REVENUE	100	-	-	-	-	-	0	
									BBQ, Straw.
01-2000-4030	FUNDRAISING REVENUE	20,273	20,000	19,047	20,000	20,000	20,000	0	Supper
01-2000-4100	MINOR RATE RENTAL REVENUE	45,901	45,000	26,079	45,000	45,000	45,000	0	
01-2000-4110	ICE RENTAL REVENUE (PRIME)	47,663	52,000	25,342	52,000	51,000	51,000	(1,000)	
01-2000-4115	ICE RENTAL REVENUE (NON-PRIME)	697	500	186	500	500	500	0	
01-2000-4120	NON-RESIDENT USER FEES	3,578	3,000	2,617	3,250	3,250	3,250	0	
01-2000-4200	BOOTH RENTAL REVENUE	3,561	4,300	1,120	5,000	3,500	3,500	(1,500)	
01-2000-4210	HALL RENTAL REVENUE	2,230	2,600	3,035	2,600	2,600	2,600	0	
01-2000-4220	FLOOR RENTAL REVENUE	463	-	-	-	-	-	0	
01-2000-4230	SIGN RENTAL REVENUE	3,980	4,160	3,620	4,160	3,700	3,700	(460)	
01-2000-4240	VENDING MACHINE REVENUE	238	250	109	-	-	-	0	
01-2000-4300	PENALTIES & INTEREST	773	525	451	525	676	788	263	
01-2000-4500	PRIOR YEAR DEFICIT			(29,582)	(29,582)			29,582	
<b>TOTAL REVENUE</b>		<b>180,011</b>	<b>182,888</b>	<b>133,955</b>	<b>213,500</b>	<b>228,750</b>	<b>227,961</b>		
<b>EXPENSES</b>									
									\$12,000 on fuel oil -> \$3000 on Zamboni Propane
01-2000-7000	WAGES	52,760	45,000	36,634	55,000	65,000	65,000	10,000	based on 2018/19 actuals
01-2000-7005	BENEFITS-EI/CPP/WSIB/EHT	5,066	5,600	3,510	5,600	5,600	5,600	0	
									OMERS must be offered
01-2000-7010	BENEFITS-OMERS	1,740	3,000	-	-	4,950	4,950	4,950	
01-2000-7015	STAFF TRAINING/DUES, FEES, SUBSCRIP	1,556	300	940	300	1,000	1,000	700	
01-2000-7100	OFFICE/COMPUTER SUPPLIES	1,901	1,200	1,823	1,700	2,000	2,000	300	
01-2000-7110	COMMUNICATION	2,512	3,000	1,378	3,000	3,000	3,000	0	
01-2000-7115	INSURANCE	11,763	12,200	12,518	12,200	13,300	13,300	1,100	
01-2000-7120	HEALTH & SAFETY	2,087	2,800	39	2,800	2,500	2,500	(300)	billed at y/e
01-2000-7125	PROF FEES - AUDIT	1,403	1,188	-	1,400	1,400	611	(789)	per quote
01-2000-7130	PROF FEES - WATER TESTING	232	300	168	300	300	300	0	
01-2000-7150	BANK CHARGES	388	500	302	400	500	500	100	
01-2000-7200	HYDRO	55,360	60,000	24,049	60,000	60,000	60,000	0	
01-2000-7210	FURNACE FUEL/ZAMB PROPANE	15,067	12,000	8,792	12,000	15,000	15,000	3,000	
01-2000-7220	BLDG/GROUNDS MAINTENANCE	23,665	15,000	9,044	20,000	17,400	17,400	(2,600)	
01-2000-7230	BOOTH MAINTENANCE	4,462	1,300	404	1,300	1,300	1,300	0	
01-2000-7240	ICE PLANT/MACH MAINT	18,771	9,000	3,334	12,000	10,000	10,000	(2,000)	
01-2000-7300	FUNDRAISING EXPENSE	10,859	10,500	9,965	10,500	10,500	10,500	0	
01-2000-7400	BAD DEBT	0	-	203	-	-	-	0	
01-2000-7500	CAPITAL PURCHASES	0	-	-	15,000	15,000	15,000	0	
<b>TOTAL EXPENSES</b>		<b>209,593</b>	<b>182,888</b>	<b>113,103</b>	<b>213,500</b>	<b>228,750</b>	<b>227,961</b>	<b>14,461</b>	<b>6.77%</b>
<b>Net Income/(Deficit)</b>		<b>(29,582)</b>	<b>0</b>	<b>20,852</b>	<b>0</b>	<b>0</b>	<b>0</b>		
<b>Operating Reserve Continuity</b>									
			<b>2018</b>	<b>2019</b>	<b>2020</b>				
Opening Reserve Balance			-	40,000	40,000				
Operating Levy Mulmur			20,000	-	-				
Operating Levy Melanchthon			20,000	-	-				
Ending Reserve Balance			40,000	40,000	40,000				

GIB# 1.4  
NOV 14 2019



# BURNSIDE

[THE DIFFERENCE IS OUR PEOPLE]

---

## Appendix B

### Calculations

Appendix B

## Appendix B1 EEM1 Interior Light Calculation

### Incandescent Area

Current Features													
	Area	Fixture Type	Number of Lamps in this Fixture	Type of Lamp	# Fixtures	KW/Fixture	hrs/day	Peak Demand (KW)	kwh/day	working days	kwh/year	\$/kwh (variable)	cost per year
1	FOYER	A1	2x28	28w Fluorescent	3	0.06	10	0.18	1.80	250	450.00	0.1665	\$18.90
2		B	2x10	10w Inc	9	0.02	10	0.18	1.80	250	450.00	0.1665	\$18.90
3	4 Change Rooms	A1	2x28	28w Fluorescent	4	0.06	10	0.24	2.40	250	600.00	0.1665	\$39.96
4		B	2x10	10w Inc	4	0.02	10	0.08	0.80	250	200.00	0.1665	\$18.90
5	GIRLS CHANGE ROOM	A1	2x28	28w Fluorescent	2	0.06	10	0.12	1.20	250	300.00	0.1665	\$49.99
6	MENS & WOMENS BATHROOM	A	2x28	28w Fluorescent	2	0.06	10	0.12	1.20	250	300.00	0.1665	\$49.99
7	OFFICE & REFEREES ROOM	A	2x28	28w Fluorescent	2	0.06	10	0.12	1.20	250	300.00	0.1665	\$49.99
8	CANTINE	C	4x32	32w Fluorescent	3	0.178	12	0.54	4.8	110	506.88	0.1665	\$84.40
9		G	3x100	100w Incandescent	2	0	12	0.20	2.40	110	264.00	0.1665	\$43.96
10	ICE RINK	A	4x10	9w LTD	50	0.04	10	2.00	20.00	250	5000.00	0.1665	\$832.50
11	Maintenance area	A	2x10	2x10 warts	4	0.02	10	0.00	0.00	250	250.00	0.1665	\$19.95
12	Auditorium	D	2x32	2x32 w Fluorescent	18	0.064	10	1.15	11.5	20	230.40	0.1665	\$19.95
13	Auditorium Kitchen	C	4x32	32w Fluorescent	3	0.178	10	0.54	5.4	20	76.80	0.1665	\$12.78
									4.86	49.73		8801.28	\$1,457.05

New Fixtures													
	Area	Fixture Type	Number of Lamps in the Fixture	Type of Lamp	# Fixtures	KW	hrs/day	Peak Demand (KW)	kwh/day	working days	kwh/year	\$/kwh (variable)	cost per year
1	FOYER	A1	2x28	20w Inc	3	0.02	10	0.06	0.60	250	150.00	0.1665	\$24.98
2		A1	2x10	10w Inc	9	0.02	10	0.18	1.80	250	450.00	0.1665	\$74.93
3	4 Change Rooms	A1	2x28	10w Inc	4	0.02	10	0.08	0.80	250	200.00	0.1665	\$33.96
4		A1	2x10	10w Inc	4	0.02	10	0.08	0.80	250	200.00	0.1665	\$33.96
5	GIRLS CHANGE ROOM	A1	2x28	20w Inc	2	0.02	10	0.04	0.40	250	100.00	0.1665	\$16.65
6	MENS & WOMENS BATHROOM	A1	2x28	20w Inc	2	0.02	10	0.04	0.40	250	100.00	0.1665	\$16.65
7	OFFICE & REFEREES ROOM	A1	2x28	20w Inc	2	0.02	10	0.04	0.40	250	100.00	0.1665	\$16.65
8	CANTINE	C	4x32	32w Incandescent	3	0.178	12	0.54	4.8	110	506.88	0.1665	\$84.40
9		G	3x100	100w Incandescent	2	0	12	0.20	2.40	110	264.00	0.1665	\$43.96
10	ICE RINK	A	4x10	9w LTD	50	0.04	10	2.00	20.00	250	5000.00	0.1665	\$832.50
11	Maintenance Area	A	2x10	2x10 warts	4	0	10	0.00	0.00	250	250.00	0.1665	\$19.95
12	Auditorium	D	2x32	2x32 w Incandescent	18	0.064	10	1.15	11.5	20	230.40	0.1665	\$19.95
13	Auditorium Kitchen	C	4x32	32w Incandescent	3	0.178	10	0.54	5.4	20	76.80	0.1665	\$12.78
								4.72	48.37		7170.88		\$1,203.73

Lampings & Lamp Replacement													
	Area	Savings and Payback	Number of Lamps in the Fixture	Type of Lamp	# Fixtures	KW	hrs/day	Peak Demand (KW)	kwh/day	working days	kwh/year	\$/kwh (variable)	cost per year
1	FOYER	A1	2x28	10w Inc	3	0.04	10	0.12	1.20	250	300.00	0.1665	\$49.95
2		A1	2x10	10w Inc	9	0	10	0.00	0.00	250	0.00	0.1665	\$0.00
3	4 Change Rooms	A1	2x28	10w Inc	4	0.04	10	0.16	1.60	250	400.00	0.1665	\$66.60
4		A1	2x10	10w Inc	4	0	10	0.00	0.00	250	0.00	0.1665	\$0.00
5	GIRLS CHANGE ROOM	A1	2x28	10w Inc	2	0.04	10	0.08	0.80	250	200.00	0.1665	\$33.30
6	MENS & WOMENS BATHROOM	A1	2x28	10w Inc	2	0.04	10	0.08	0.80	250	200.00	0.1665	\$33.30
7	OFFICE & REFEREES ROOM	A1	2x28	10w Inc	2	0.04	10	0.08	0.80	250	200.00	0.1665	\$33.30
8	CANTINE	C	4x32	32w Incandescent	3	0	12	0.00	0.00	110	0.00	0.1665	\$0.00
9		G	3x100	100w Incandescent	2	0	12	0.00	0.00	110	0.00	0.1665	\$0.00
10	ICE RINK	A	4x10	9w LTD	50	0	10	0.00	0.00	250	0.00	0.1665	\$0.00
11	Maintenance area	A	2x10	2x10 warts	4	0	10	0.00	0.00	250	0.00	0.1665	\$0.00
12	Auditorium	D	2x32	2x32 w Incandescent	18	0	10	0.00	0.00	20	0.00	0.1665	\$0.00
13	Auditorium Kitchen	C	4x32	32w Incandescent	3	0	10	0.00	0.00	20	0.00	0.1665	\$0.00
								0.53	5.3				\$216.45

Payback without incentives  
 1 year Savings \$216.45  
 Implementation cost \$1,495.00  
 Simple Payback (years) 6.91

Payback with incentives  
 1 year Savings \$216.45  
 Implementation cost \$1,495.00  
 Simple Payback (years) 3.11

## Appendix B2 EEM2 Exterior Light Calculation

### Exterior Lighting Powerwood Arch

Current Features													
	Area	Fixture Type	Number of Lamp in the Fixture	Type of Lamp	# Fixtures	KW	hrs/day	Peak Demand (KW)	lumens/day	working days	lumens/year	\$/lum (yearly)	cost per year
1	Exterior Lighting	J	1x70	70w HPS	1	0.07	12	0.07	0.84	365	306.60	0.1665	\$51.05
2	Exterior Lighting	L	1x750	750w HPS	1	0.25	12	0.25	6.00	365	1,899.00	0.1665	\$187.32
3	Exterior Lighting	P	1x25	25w LED	2	0.03	12	0.06	0.72	365	262.80	0.1665	\$43.76
4	Wall Packs	Z	1x16	16w LED wall pack	1	0.016	12	0.04	0.50	365	183.96	0.1665	\$30.63
								0.32	9.04		3,848.36		\$398.97

New Features													
	Area	Fixture Type	Number of Lamp in the Fixture	Type of Lamp	# Fixtures	W	hrs/day	Peak Demand (KW)	lumens/day	working days	lumens/year	\$/lum (yearly)	cost per year
1	Exterior Lighting	J	1x80	LED bulb	1	0.07	12	0.07	0.56	365	131.40	0.1665	\$21.89
2	Exterior Lighting	L	1x70	LED bulb	1	0.07	12	0.07	0.64	365	306.60	0.1665	\$51.05
								0.10	1.28		438.00		\$72.93

Need to add lumens track or discuss beam track

Savings @ Lamp Replacement																							
		Savings and Payback	Number of Lamp in the Fixture	Type of Lamp	# Fixtures	W	hrs/day	Peak Demand (KW)	lumens/day	working days	lumens/year	\$/lum (yearly)	Savings	Material Cost	Fixture Cost Total	Discount per Fixture	Incentive Total	Labor / Fixture	LPI Rental	Labor	Total Cost w/o Incentives	Total Cost w/ Incentives	Simple Payback
1	Exterior Lighting	J	1x70	LED Bulb	1	0.07	12	0.04	0.48	365	175.20	0.1665	\$29.17	\$200.00	\$200.00	\$25.00	\$25.00	\$120.00	\$50.00	\$120.00	\$170.00	\$295.00	10.11
2	Exterior Lighting	L	1x750	LED Bulb	1	0.25	12	0.10	2.16	365	780.40	0.1665	\$111.37	\$600.00	\$600.00	\$75.00	\$75.00	\$70.00		\$70.00	\$670.00	\$559.00	4.51
								0.22			963.60		\$160.49				\$180.00				\$180.00	\$499.00	5.55

#### Payback without incentives

1 year savings	\$160.49
implementation cost	\$950.00
Simple Payback (years)	6.17

#### Payback with incentives

1 year savings	\$160.49
implementation cost	\$690.00
Simple Payback (years)	5.55

# Appendix B3 EEM3 Programmable Thermostat

Subscribe

Building envelope

Description

Building envelope

Note

Building envelope

Base case

Proposed case

Building north

350

350

Schedule

24/7

Schedule

Incremental initial costs

\$

Walls

Area

m<sup>2</sup>

72

180

72

180

72

180

72

180

Net area

m<sup>2</sup>

68.4

162

68.4

171

68.4

162

68.4

171

U-value

(W/m<sup>2</sup>)/°C

0.75

0.75

0.75

0.75

0.75

0.75

0.75

0.75

Incremental initial costs

\$

Windows

Area

%

5%

10%

5%

5%

5%

10%

5%

5%

R-value

m<sup>2</sup> - °C/W

Solar heat gain coefficient

Incremental initial costs

\$

Solar shading - season of use

Solar shading - winter

%

Solar shading - summer

%

Incremental initial costs

\$

Doors

Roof

Area

ft<sup>2</sup>

4,000

4,000

U-value

(W/m<sup>2</sup>)/°C

0.5

0.5

Incremental initial costs

\$

Skylight

Floor

Wall - below-grade

Floor - below-grade

Natural air infiltration

Method

Calculated

Walls

Medium

Medium

Window

Medium

Medium

Doors

Medium

Medium

Natural air infiltration

L/s

269

269

Incremental initial costs

\$

Incremental initial costs - total

\$

0

Incremental O&M savings

\$

Number of building envelope units

1

1

System selection

Heating

Heating

Heating system

Furnace

Furnace

Heating

kWh

70,071

59,133

Energy saved

10,938

15.6%

## Appendix B4 EEM4 Roof Insulation

### Heat Profile for Lobby to Exterior

			Annual Heating $\Delta T$ between Interior and Exterior		
Month	Time (hr)	Avg. Exterior <sup>1</sup> (°C)	$T_{int}$ <sup>2</sup> (°C)	$\Delta T_{int-ext}$ (K)	$\Delta T_{int-ext} \cdot \text{Time}$ (K·h)
January	744	-9	20	29	21576
February	672	-8.4	20	28.4	19085
March	744	-3.1	20	23.1	17186
April	720	4.4	20	15.6	11232
May	744	10.8	20	9.2	6845
June	720	15.6	20	4.4	3168
July	744	18.1	20	1.9	1414
August	744	17.3	20	2.7	2009
September	720	13.5	20	6.5	4680
October	744	7.8	20	12.2	9077
November	720	1.7	20	18.3	13176
December	744	-5.2	20	25.2	18749
<sup>1</sup> Source: RETScreen - Mount Forest Station				$\Sigma =$	128196

<sup>2</sup>Interior temperature assumed to be constant at 20°C

# Energy Efficiency Measure - Roof Insulation

Project Description	$R_{imp,existing}$ (hr·ft <sup>2</sup> ·°F/BTU)	$U_{existing}$ (W/m <sup>2</sup> ·K)	$R_{imp,improved}$ (hr·ft <sup>2</sup> ·°F/BTU)	$U_{improved}$ (W/m <sup>2</sup> ·K)	$ \Delta U $ (W/m <sup>2</sup> ·K)	$\Delta T \cdot Time$ (K·h)	Roof Area (m <sup>2</sup> )	Energy (kWh)
Increase Lobby Roof Insulation to R-50	12	0.47	50	0.11	0.36	104940	372	14,024

Oil Furnace Efficiency	Oil L	Cost of Oil Per L	Total Cost of Oil	Comments
0.62	2,144	\$ 0.83	\$ 1,779.48	Lobby Roof Area



### OPINION OF COST

Our opinion of costs is based on our experience with contractors specializing in these fields, historical cost data from similar projects, and/or current construction cost data published by the R.S. Means Company. These cost estimates should be used as a guide only, as costs may vary according to the time of year, quality of materials used, volume of work, actual site conditions, etc.

#### Door Weatherstripping

Item No.	Item	Cost
A	Mobilization/Demobilization	\$ 700
B	Blown Insulation	\$ 6,800
<i>Construction Sub-Total</i>		<i>\$ 7,500</i>
C	HST (13%)	\$ 975
<b><i>TOTAL (ROUNDED)</i></b>		<b><i>\$ 8,500</i></b>

## Appendix B5 EEM5 Air Leakage

### Heat Profile for Lobby to Exterior and Arena

Month	Time (hr)	Avg. Exterior <sup>1</sup> (°C)	Estimated Arena <sup>2</sup> (°C)	Annual Heating $\Delta T$ between Interior and Exterior			Annual Heating $\Delta T$ between Interior and Arena		
				$T_{int}$ <sup>3</sup> (°C)	$\Delta T_{int-ext}$ (K)	$\Delta T_{int-ext} \cdot \text{Time}$ (K·h)	$T_{int}$ <sup>3</sup> (°C)	$\Delta T_{int-arena}$ (K)	$\Delta T_{int-arena} \cdot \text{Time}$ (K·h)
January	744	-9	-7	20	29	21576	20	27	20088
February	672	-8.4	-6.4	20	28.4	19085	20	26.4	17741
March	744	-3.1	-1.1	20	23.1	17186	20	21.1	15698
April	720	4.4	5.4	20	15.6	11232	20	14.6	10512
May	744	10.8	10.8	20	9.2	6845	20	9.2	6845
June	720	15.6	15.6	20	4.4	3168	20	4.4	3168
July	744	18.1	18.1	20	1.9	1414	20	1.9	1414
August	744	17.3	17.3	20	2.7	2009	20	2.7	2009
September	720	13.5	13.5	20	6.5	4680	20	6.5	4680
October	744	7.8	8.8	20	12.2	9077	20	11.2	8333
November	720	1.7	2.7	20	18.3	13176	20	17.3	12456
December	744	-5.2	-3.2	20	25.2	18749	20	23.2	17261
<sup>1</sup> Source: RETScreen - Mount Forest Station				$\Sigma =$ 128196			$\Sigma =$ 120204		

<sup>2</sup> Estimated service room interior temp is +2°C when exterior is <0°C; +1°C when exterior is 0°C to 10°C; same as exterior when >10°C.

<sup>3</sup> Interior lobby temperature assumed to be constant at 20°C

# Energy Efficiency Measure - Door Air Leakage

		Air Leakage Rates <sup>1</sup>			U <sup>3</sup> (W/K)	ΔT·Time (K-h)	Energy (kWh)
Door Area <sup>2</sup> (m <sup>2</sup> )		Q <sub>existing</sub> (L/s·m <sup>2</sup> )	Q <sub>improved</sub> (L/s·m <sup>2</sup> )	Δq (L/s·m <sup>2</sup> )			
Lobby to Arena							
1	2.2	3.0	1.5	1.5	3.9	120204	469
2	2.2	3.0	1.5	1.5	3.9	120204	469
Lobby to Exterior							
3	2.2	3.0	1.5	1.5	3.9	128196	500
					ΣE= 1438		

L of Fuel	Cost of Fuel	Measure Cost	Simple Payback
10.56kWh/L	\$0.75/L		

136	\$ 102.18	\$ 1,500.00	14.68
-----	-----------	-------------	-------

<sup>1</sup> Air Leakage values taken from AAMA/WDMA/CSA 101/1.5.2/A440-17, Table 6.2:

- Existing air leakage rates of service doors assumed to be double A2 rating (2 x 1.5 L/s m<sup>2</sup>)
- Improved air leakage rates of original doors assumed to be equivalent to A2 air leakage of 1.5 L/s·m<sup>2</sup>)

<sup>2</sup> Door dimensions assumed to be 3'-6" wide by 6'-8" tall

<sup>3</sup> U= Door area x Δq x heat capacity of air

Heat Capacity of Air is 1.0 kJ/kg·K = 1.2 W s/L·K assuming air density of 1.2kg/m<sup>3</sup>

### OPINION OF COST

Our opinion of costs is based on our experience with contractors specializing in these fields, historical cost data from similar projects, and/or current construction cost data published by the R.S. Means Company. These cost estimates should be used as a guide only, as costs may vary according to the time of year, quality of materials used, volume of work, actual site conditions, etc.

#### Door Weatherstripping

Item No.	Item	Cost
A	Mobilization/Demobilization	\$ 200
B	Door Weatherstripping	\$ 1,100
Construction Sub-Total		\$ 1,300
C	HST (13%)	\$ 169
TOTAL (ROUNDED)		\$ 1,500

## Appendix B6 EEM6 Interior Windows

### Heat Profile for Tank to Service Room Heat Transfer

				Annual Heating $\Delta T$ between Interior and Arena		
Month	Time (hr)	Avg. Exterior <sup>1</sup> (°C)	Estimated Arena <sup>2</sup> (°C)	T <sub>Int</sub> <sup>3</sup> (°C)	$\Delta T_{Int-arena}$ (K)	$\Delta T_{Int-arena} \cdot \text{Time}$ (K·h)
January	744	-9	-7	20	27	20088
February	672	-8.4	-6.4	20	26.4	17741
March	744	-3.1	-1.1	20	21.1	15698
April	720	4.4	5.4	20	14.6	10512
May	744	10.8	10.8	20	9.2	6845
June	720	15.6	15.6	20	4.4	3168
July	744	18.1	18.1	20	1.9	1414
August	744	17.3	17.3	20	2.7	2009
September	720	13.5	13.5	20	6.5	4680
October	744	7.8	8.8	20	11.2	8333
November	720	1.7	2.7	20	17.3	12456
December	744	-5.2	-3.2	20	23.2	17261
				$\Sigma =$		120204

<sup>1</sup>Source: RETScreen - Mount Forest Station

<sup>2</sup>Estimated service room interior temp is +2°C when exterior is <0°C; +1°C when exterior is 0°C to 10°C; same as exterior when >10°C.

<sup>3</sup>Interior lobby temperature assumed to be constant at 20°C

# Energy Efficiency Measure - Interior Window Replacement

Description	U <sub>existing</sub> (W/m <sup>2</sup> -K)	U <sub>improved</sub> (W/m <sup>2</sup> -K)	ΔT-Time (K-h)	Area (m <sup>2</sup> )	Energy (kWh)
EEM-X Replace Thermally Unbroken Hollow Metal Frame Windows between Arena and Interior Lobby	6.42	3.47	120204	32.0	11347

L of Fuel	Cost of Fuel	Measure Cost	Simple Payback
10.56kWh/L	\$0.75/L		
1075	\$ 806.14	\$ 38,000.00	47.14

\*Window U-values taken from 2011 ASHRAE fundamentals handbook (Table 4, page 30.8):

- Existing windows assumed to be equivalent to thermally unbroken aluminum frame with fixed, 3.2mm thick, single glazing
- Upgraded windows assumed to be equivalent to thermally unbroken aluminum frame with fixed, double glazing, low-e=0.2, 12.7mm argon space, fire rated coating (e.g. Pyrostop by Pilkington). Aluminum frames cannot be thermally broken as the butyl break compromises its fire rating.

### OPINION OF COST

Our opinion of costs is based on our experience with contractors specializing in these fields, historical cost data from similar projects, and/or current construction cost data published by the R.S. Means Company. These cost estimates should be used as a guide only, as costs may vary according to the time of year, quality of materials used, volume of work, actual site conditions, etc.

#### EEM-X: Interior Window Replacement

Item No.	Item	Cost
A	Mobilization/Access/Protection/Demobilization	\$ 2,000
B	Window Replacement	\$ 23,400
C	Allowances	
i)	Building Permit	\$ 200
D	Construction Contingency	\$ 3,000
<i>Construction Sub-Total</i>		<i>\$ 28,600</i>
E1	Engineering Services: Design & Tender	\$ 3,500
E2	Engineering Services: Construction Review (Based on a 1 week construction schedule)	\$ 1,800
<i>Sub-Total</i>		<i>\$ 33,900</i>
F	HST (13%)	\$ 4,407
<b><i>TOTAL (ROUNDED)</i></b>		<b><i>\$ 38,000</i></b>



## Appendix B7 EEM7 Water Conservation

### Honeywood Arena Water Usage Calculation

Baseline Case: change occupant values to reflect anticipated occupancy

Fixture Type	Number of Fixtures	Consumption (l)	Daily Uses	Duration (min)	Occupants	Daily Water Use (gal)	Notes
3.5 gpf toilet - male (gallons per flush) changerooms	4	3.5	2.5	1	60	525	75 people in the arena per day on average for 8.5 hour day - 60 hours per week Assur
3.5 gpf toilet - female (gallons per flush)	3	3.5	3	1	15	158	
2.0 gpf urinal - male (gallons per flush) 1st Floor Lobby	2	2	0.5	1	60	60	Only two urinals in lobby - most flushing would be from changerooms toilets
Commercial Lavatory Faucets - 2.2 gpm	9	2.2	3	0.3	75	149	
Canteen sink - 2.2 gpm	1	2.2	20	0.25	2	22	Used only on weekends
Dishwasher	1	6	2	1	1	12	Used only on weekends
Coffee/Tea/Water	1	2			75	150	2 L of water per occupant
Showerhead - 2.5 gpm	4	2.5	1	4	34	339	237 Showers per week across 4 showers
Total Daily Volume						1,414	Pumping Costs
Monthly						29,685	Assumption 12Gal/min pump
m^3/month						112	1.1kw pump
Annual Work Days						250	m3 Gal Min hours kwh
Total Annual Usage (g)						353,393	1,337.6 353,354.3 29,446.2 490.8 539.8
Total Annual Usage (m')						1,338	Heating Costs
							L/Year Cost per year
							2098.6 \$1,741.83

Calculator: To determine estimated savings, insert occupant values (same as Baseline) and consumption values based on fixtures and fixture fittings installed

Fixture Type	Number of Fixtures	Consumption	Daily Uses	Duration	Occupants	Daily Water Use (gal)	
3.5 gpf toilet - male (gallons per flush) changerooms	4	3.5	2.5	1	60	525	
3.5 gpf toilet - female (gallons per flush)	3	3.5	3	1	15	158	
2.0 gpf urinal - male (gallons per flush) 1st Floor Lobby	2	2	0.5	1	60	60	
Commercial Lavatory Faucet - 0.5 gpm	9	0.5	3	0.3	75	34	
Canteen sink - 1.0 gpm	1	1	20	0.25	2	10	
Dishwasher	1	6	2	1	1	12	
Coffee/Tea/Water	1	2			75	150	
Low Flow Showerhead - 1.6 gpm	4	1.6	1	4	34	217	
Total Daily Volume						1,165	Assumption 12Gal/min pump
Monthly						24,464	1.1kw pump
m^3/month						93	m3 Gal Min hours kwh
Annual Operation Days						250	235.3 62,152.2 5,179.3 86.3 95.0
Total Annual Usage (g)						291,234	Heating Costs
Total Annual Usage (m')						1,102	L/Year Cost per year
Annual Savings						62,159	1527.8 \$1,268.04
% Reduction						-17.6%	
m^3 reduction						235	Yearly Savings
							Pumping kwh saved 94.95
							\$ (\$0.01665/kwh) \$ 15.81
							Cost Savings \$ 489.60
							Implementation Cost \$ 1,800.00
							Total Savings \$ 1,800.00
							Simple Payback 3.68 years

**Low Flow Fixtures Domestic Water Heater Cost Savings from Reduced Oil Consumption**  
**Yearly Savings**

Fixture	# of Fixtures	Cost per fixture	Installation cost/fixture	Total Cost
Commercial Lavatory Faucet - 0.5 gpm	9	\$100	\$100	\$1,800
Kitchen sink - 0.5 gpm	1	\$100	\$100	\$200
Dishwasher	1			\$0
Low Flow Shower Head	4	\$25	\$10	\$140
Total				\$1,800
Simple payback (years)				3.68

**John wood Efficiency is 0.62**

[illegible]

## Appendix B8 EEM8 Furnace Calculation

### Honeywood Arena

#### Furnace Oil Consumption Calculation

2018 Consumption	12,841
2017 Consumption	9,234
2016 Consumption	14,121

#### Average 3 Year Oil Usage

	L of Oil	kWh/L	kWh
Annual	12,065	10.5570	127,374
DHW	2,000	10.5570	21,114
Zamboni	5,200	10.5570	54,896
Furnace	4,865	10.5570	51,363

#### L of Oil

Replace 1 Furnace 5% More Efficient Savings	121.63
--	--------

#### Estimated Oil Usage by Arena Use

1		
2	<u>2018</u>	
3	Total Oil	12,841
4	DHW	2,000
	Zamboni Hot Water	5,200
5	Total Heating Load	5,641
1	<u>2017</u>	
2	Total Oil	9,234
3	DHW	2,000
4	Zamboni Hot Water	5,200
5	Total Heating Load	2,034
	<u>2016</u>	
	Total Oil	14,121
	DHW	2,000
	Zamboni Hot Water	5,200
	Total Heating Load	6,921

### Drain Water Heat Recovery on Low Flow Fixtures

John wood Efficiency is 0.62									
Oil Water Heater Savings	Gallons Heated	BTU/Gallon of Water	BTU Required	BTU/gal/no. 2 oil	Gal of Fuel Oil/Day	Days in Peak Season	Gal/Year	L/Year	Cost per year
Including Low Flow Fixtures	266.2	846.8	225389.5	139600.0	1.6	250.0	403.6	1527.8	\$1,268.04
With DWHR 24% Heat Recovery							306.8	1161.1	\$963.71
Savings								366.66	\$304.33

## Appendix B10 EEM10 New Zamboni Hot Water System

### Zamboni Water Heater Cost Comparison

John wood EF is 0.62

Oil Water Heater Zamboni Cost	Gallons/year	EF	BTU/Gallon of Water	BTU Required	BTU/gal/no. 2 oil	Gal of Fuel Oil/yr	L/Year	kWh	\$/L	Cost per year
Before	227700.0	0.62	846.8	192810483.9	139600.0	1381.2	5227.7	55152.3	\$ 0.83	\$3,973.06
						682.2949787				

75 Gal Propane EF assumed 0.75

Propane Water Heater Zamboni Cost	Gallons/year	EF	BTU/Gallon of Water	BTU Required	BTU/gal/pro pane	Gal of Fuel Oil/yr	L/Year			Cost per year
Before	227700.0	0.75	700.0	159390000.0	91000.0	1751.5	6629.6	45713.7	\$ 0.49	\$3,248.49

Savings \$724.57

## Appendix B11 EEM11 Desuperheater Heat Recovery

Desuperheater Raises incoming temperature from 55 to 120 degrees 80% of the time

$$Q = M c_p \Delta T$$

Q= Heat Gain by quantity of water in btu/hr

M=Mass in pounds/min

Cp=Specific Heat of Water =1

$\Delta T$ = Change in Temp Farenheit

1) Water Flow Rate though heater of 2.3 US gallons/min = 19.48 lbs= M  
19.4

2) Cp=1

3)  $\Delta T = 120 - 55 = 65$

$$Q = 19.48 \text{ lb/min} \times 60 \text{ min/hr} \times 1 \times 65 = 75,972 \text{ btu/hr}$$

8 floods per day  
607776 btu/day

1 Therm=100,000 BTU

140000 BTU/Gallon of No. 2 Fuel Oil

62% water heater efficiency + 80% Desuperheater Efficiency

Using Fuel Oil 2 62% efficiency = output BTU/Gallon=  $0.62 \times 140,000 \text{ BTU} = 86,800 \text{ BTU/Gallon}$

BTU/Day/BTU/Gallon\*80% Desuperheater Efficiency =

5.60 Gallons per day  
Gallons/Day \* 7 months per year\* 30 days per month \* 3.8 Gallons/L=  
4470 L of Fuel Oil/ year (Estimated 5200 total)

\$0.83/L of Fuel Oil  
\$ 3,710.18

Based on 7 month ice season =  
\$ 3,710.18

Capital Cost of \$42,500  
Payback =  
11.45

## Appendix B12 EEM12 DDC Controller

From Qualified Refrigeration Contractor

Proper Operation of DDC controller for 1 rink arena with 6.5 month operation yields  
\$5,000-\$10,000 yearly savings for ice plant

Conservatively estimated at \$5,000 per year

Current Rate of energy is approximately \$0.13/kWh

Total Energy Savings for \$5,000 yearly savings

=  $\$5,000 / 0.13$

= 38461.538 kwh

Rounded 38500 kwh

Potential Incentive from Hydro One

Estimated at \$0.10/kWh saved

Incentive = \$ 3,850.00

Budget Cost from Contractor \$45,000

Payback

without

Incentive 9 years

Payback with

Incentive 8.2 years



## Appendix B13 EEM13 Electric Desiccant De-Humidifier

From Qualified Refrigeration Contractor

Electric Desiccant De-humidifier provides savings of \$2500-\$4,000 for single rink operation

Conservatively estimated at \$2,500 per year

Current Rate of energy is approximately \$0.13/kWh

Total Energy Savings for \$5,000 yearly savings

= \$2500/0.13

= 19230.769 kWh

Rounded 19000 kWh

Potential Incentive from Hydro One

Estimated at \$0.10/kWh saved

Incentive = \$1,900.00

Budget Cost from Contractor \$40,000

Payback

without

Incentive 16 years

Payback with

Incentive 15.2 years

## Appendix B14 EEM14 Solar Photovoltaic



**RETScreen<sup>®</sup> International**  
www.etscreen.net

Clean Energy Project Analysis Software

**Project Information**  
[See project database](#)

Project name

Project location

Prepared for

Prepared by

Project type

Technology

Gnd type

Analysis type

Heating value reference

Show settings

North Dufferin Community Centre Solar

Mulmur, ON

Mulmur Township

RJ Burnside & Associates

Power

Photovoltaic

Central-grid

Method 2

Higher heating value (HHV)

☐

**Site reference conditions**  
[Select climate data location](#)

Climate data location

Show data

Mount Forest (MARS)

☐



[Complete Energy Model sheet](#)

RETScreen4 2013-08-27

© Minister of Natural Resources Canada 1997-2013.

NRCan/CanmetENERGY

Proposed base power system		
Analysis type	<input checked="" type="radio"/> Method 1 <input type="radio"/> Method 2	
Photovoltaic		
Power capacity	kW	190.00
Manufacturer		
Model		
Capacity factor	%	14.0%
Electricity exported to grid	MWh	273.0
Electricity export rate	\$/MWh	134.00

[See product database](#)

# RETScreen Cost Analysis - Power project

Settings		
<input checked="" type="radio"/> Method 1	<input checked="" type="radio"/> Notes/Range	Notes/Range
<input type="radio"/> Method 2	<input type="radio"/> Second currency	None
	<input type="radio"/> Cost allocation	

Initial costs (credits)	Unit	Quantity	Unit cost	Amount	Relative costs
Feasibility study					
Feasibility study	cost	1	\$ 5,000	\$ 5,000	
Subtotal				\$ 5,000	1.1%
Development					
Development	cost	1	\$ 20,000	\$ 20,000	
Subtotal				\$ 20,000	4.3%
Engineering					
Engineering	cost	1	\$ 10,000	\$ 10,000	
Subtotal				\$ 10,000	2.2%
Power system					
Photovoltaic	kW	190.00	\$ 2,250	\$ 427,500	
Road construction	km			\$ -	
Transmission line	km			\$ -	
Substation	project			\$ -	
Energy efficiency measures	project			\$ -	
User-defined	cost			\$ -	
Subtotal				\$ 427,500	92.4%
Balance of system & miscellaneous					
Spare parts	%			\$ -	
Transportation	project			\$ -	
Training & commissioning	p-d			\$ -	
User-defined	cost			\$ -	
Contingencies	%		\$ 482,500	\$ -	
Interest during construction			\$ 482,500	\$ -	
Subtotal				\$ -	0.0%
Total initial costs				\$ 462,500	100.0%

Annual costs (credits)	Unit	Quantity	Unit cost	Amount
O&M				
Parts & labour	project	190	\$ 39	\$ 7,410
User-defined	cost			\$ -
Contingencies	%		\$ 7,410	\$ -
Subtotal				\$ 7,410

Periodic costs (credits)	Unit	Year	Unit cost	Amount
User-defined	cost			\$ -
				\$ -
End of project life	cost			\$ -

# RETScreen Emission Reduction Analysis - Power project

## Emission Analysis

- ☒ Method 1
- ☐ Method 2
- ☐ Method 3

## Base case electricity system (Baseline)

Country - region	Fuel type	GHG emission factor (excl. T&D) tCO <sub>2</sub> /MWh	T&D losses %	GHG emission factor tCO <sub>2</sub> /MWh
Canada - Ontario	Other	0.131		0.131

☐ Baseline changes during project life

## Base case system GHG summary (Baseline)

Fuel type	Fuel mix %	Fuel consumption MWh	GHG emission factor tCO <sub>2</sub> /MWh	GHG emission tCO <sub>2</sub>
Electricity	100.0%	233	0.131	30.5
Total	100.0%	233	0.131	30.5

## Proposed case system GHG summary (Power project)

Fuel type	Fuel mix %	Fuel consumption MWh	GHG emission factor tCO <sub>2</sub> /MWh	GHG emission tCO <sub>2</sub>
Solar	100.0%	233	0.000	0.0
Total	100.0%	233	0.000	0.0

Electricity exported to grid	MWh	233	T&D losses	0	0.131	0.0
Total						0.0

## GHG emission reduction summary

	Base case GHG emission tCO <sub>2</sub>	Proposed case GHG emission tCO <sub>2</sub>	Gross annual GHG emission reduction tCO <sub>2</sub>	GHG credits transaction fee %	Net annual GHG emission reduction tCO <sub>2</sub>
Power project	30.5	0.0	30.5		30.5

Net annual GHG emission reduction	30.5	tCO <sub>2</sub>	is equivalent to	5.6	Cars & light trucks not used
-----------------------------------	------	------------------	------------------	-----	------------------------------

# RETScreen Financial Analysis - Power project

Financial parameters			
General			
Fuel cost escalation rate	%		0.0%
Inflation rate	%		2.0%
Discount rate	%		4.0%
Project life	yr		30

Finance			
Incentives and grants	\$		
Debt ratio	%		75.0%
Debt	\$		346,875
Equity	\$		115,625
Debt interest rate	%		2.50%
Debt term	yr		30
Debt payments	\$/yr		16,573

Income tax analysis ☐

Annual income			
Electricity export income			
Electricity exported to grid	MWh		233
Electricity export rate	\$/MWh		134.00
Electricity export income	\$		31,224
Electricity export escalation rate	%		3.5%

GHG reduction income			
Net GHG reduction	ICO2/yr		31
Net GHG reduction - 30 yrs	ICO2		916

Customer premium income (rebate) ☐

Other income (cost) ☐

Clean Energy (CE) production income ☐

Project costs and savings/income summary			
Initial costs			
Feasibility study	1.1%	\$	5,000
Development	4.3%	\$	20,000
Engineering	2.2%	\$	10,000
Power system	92.4%	\$	427,500

Balance of system & misc.	0.0%	\$	0
<b>Total initial costs</b>	<b>100.0%</b>	<b>\$</b>	<b>462,500</b>

Annual costs and debt payments			
O&M		\$	7,410
Fuel cost - proposed case		\$	0
Debt payments - 30 yrs		\$	16,573
<b>Total annual costs</b>		<b>\$</b>	<b>23,983</b>


Periodic costs (credits)

Annual savings and income			
Fuel cost - base case		\$	0
Electricity export income		\$	31,224

<b>Total annual savings and income</b>		<b>\$</b>	<b>31,224</b>
--	--	-----------	---------------

Financial viability			
Pre-tax IRR - equity	%		13.9%
Pre-tax IRR - assets	%		3.4%
After-tax IRR - equity	%		13.9%
After-tax IRR - assets	%		3.4%
Simple payback	yr		19.4
Equity payback	yr		9.2
Net Present Value (NPV)	\$		300,998
Annual life cycle savings	\$/yr		17,407
Benefit-Cost (B-C) ratio			3.60
Debt service coverage			1.49
Energy production cost	\$/MWh		87.63
GHG reduction cost	\$/ICO2		(\$70)

Yearly cash flows				
Year	Pre-tax	After-tax	Cumulative	
#	\$	\$	\$	\$
0	-115,625	-115,625	-115,625	
1	8,188	8,188	-107,439	
2	9,186	9,186	-98,253	
3	10,182	10,182	-88,071	
4	11,237	11,237	-76,834	
5	12,330	12,330	-64,524	
6	13,465	13,465	-51,059	
7	14,641	14,641	-36,418	
8	15,861	15,861	-20,556	
9	17,127	17,127	-3,430	
10	18,439	18,439	15,009	
11	19,800	19,800	34,809	
12	21,211	21,211	56,021	
13	22,675	22,675	78,695	
14	24,192	24,192	102,888	
15	25,766	25,766	128,653	
16	27,397	27,397	156,050	
17	29,089	29,089	185,139	
18	30,842	30,842	215,981	
19	32,661	32,661	248,642	
20	34,546	34,546	283,187	
21	36,500	36,500	319,687	
22	38,526	38,526	358,213	
23	40,626	40,626	398,840	
24	42,804	42,804	441,643	
25	45,061	45,061	486,704	
26	47,400	47,400	534,104	
27	49,825	49,825	583,929	
28	52,336	52,336	636,268	
29	54,944	54,944	691,212	
30	57,645	57,645	748,857	





# BURNSIDE

[THE DIFFERENCE IS OUR PEOPLE]


---

## Appendix D

### Drawings



612800 Drawings




Honeywood Arena  
Township of Mulmur

MAIN FLOOR  
EXISTING

Project 2714  
Design HA  
Drawn RR

Scale 1/8" = 1'-0"  
Date September 2014  
(Issued)





Honeywood Arena  
Township of Mulmur

UPPER FLOOR  
EXISTING

Project 2714  
Design BR  
Drawn BR

Scale 1/8" = 1' 0"  
Date September 2014  
Issued



**Honeywood Arena  
Township of Mulmur**

**ELEVATIONS  
EXISTING**

Project 2714	Scale 1/8" = 1'-0"
Design BR	Date September 2014
Drawn BR	Issued

